



**Ontario Clean Water Agency**  
**Agence Ontarienne Des Eaux**

136 Main Street East  
Shelburne, Ontario  
Canada L9V 3K5

TEL: 1 866 214 6987  
TEL: 519 925 1938  
FAX: 519 925 0322  
WWW.OCWA.COM

February 22, 2019

Denyse Morrissey  
CAO  
Town of Shelburne  
203 Main Street East, Box 69  
Shelburne, ON  
L9V 3K7

**Re: Section 11 Report of Ontario Regulation 170/03**

Ms. Morrissey,

Please find attached the 2018 Annual Report for the Shelburne Water System, water works # 220004965. The reports have been prepared as per Section 11 of O.Reg. 170/03 by the Ontario Clean Water Agency on behalf of the Town of Shelburne. These reports no longer have to be submitted to the Ministry of the Environment and Climate Change.

As per O.Reg. 170/03; Section 12 (4); these reports must be made available to any member of the public during normal business hours without charge at the office of the owner. If the office of the owner is not reasonably convenient to users of water from the system, the reports must be made available at a location that is reasonably convenient to those users.

Should you have any further questions regarding the attached report, please contact the undersigned at (519) 925-1938.

Sincerely,

A handwritten signature in blue ink, appearing to read "Don Irvine".

Don Irvine  
Senior Operations Manager  
Highlands Hub

DI/mc

cc: Melissa Cortes, PCT

<b>Drinking-Water System Number:</b>	220004965
<b>Drinking-Water System Name:</b>	Shelburne Drinking Water System
<b>Drinking-Water System Owner:</b>	The Corporation of the Town of Shelburne
<b>Drinking-Water System Category:</b>	Large Municipal Residential
<b>Period being reported:</b>	January 1, 2018 – December 31, 2018

<b><u>Complete if your Category is Large Municipal Residential or Small Municipal Residential</u></b>	<b><u>Complete for all other Categories.</u></b>
<p><b>Does your Drinking-Water System serve more than 10,000 people?</b>                      Yes [ ] No [X]</p> <p><b>Is your annual report available to the public at no charge on a web site on the Internet?</b>                      Yes [X] No [ ]</p> <p><b>Location where Summary Report required under O. Reg. 170/03 Schedule 22 will be available for inspection.</b>                      Office of Town of Shelburne                      203 Main St East                      Shelburne                      Ontario, L9V 3K7</p>	<p><b>Number of Designated Facilities served:</b>                      Not applicable.</p> <p><b>Did you provide a copy of your annual report to all Designated Facilities you serve?</b>                      Not applicable.</p> <p><b>Number of Interested Authorities you report to:</b>                      Not applicable.</p> <p><b>Did you provide a copy of your annual report to all Interested Authorities you report to for each Designated Facility?</b>                      Not applicable.</p>

Note: For the following tables below, additional rows or columns may be added or an appendix may be attached to the report

**List all Drinking-Water Systems (if any), which receive all of their drinking water from your system:**

<b>Drinking Water System Name</b>	<b>Drinking Water System Number</b>
Not Applicable.	Not Applicable.

**Did you provide a copy of your annual report to all Drinking-Water System owners that are connected to you and to whom you provide all of its drinking water?**

Not applicable.

**Indicate how you notified system users that your annual report is available, and is free of charge.**

<input checked="" type="checkbox"/>	Public access/notice via the web
<input checked="" type="checkbox"/>	Public access/notice via Government Office
<input type="checkbox"/>	Public access/notice via a newspaper
<input checked="" type="checkbox"/>	Public access/notice via Public Request
<input type="checkbox"/>	Public access/notice via a Public Library
<input type="checkbox"/>	Public access/notice via other method: _____

### Describe your Drinking-Water System

The Town of Shelburne's water is derived from six drilled groundwater wells, noted as well numbers 1, 3, 5, 6, 7 and 8. Water from these wells is pumped into the distribution system, which consists of approximately 47 kilometers of watermain and into the Town's elevated storage reservoir.

Shelburne's groundwater wells, draws its water from underground aquifers, which are generally protected from above-ground sources of contamination by overlying layers of clay. To prevent the direct entry of surface water or foreign materials into these wells all wellheads are maintained and secure.

Primary disinfection is achieved by the addition of sodium hypochlorite for Well # 3, 5, 6, 7 and 8 with contact time. At Pumphouse PH 1, a complete two-stage primary disinfection system consisting of UV light combined with chemical disinfection is necessary to ensure that the water is adequately treated for consumption. Secondary disinfection is achieved through Primary Disinfection at all wells supplying the Shelburne Water System.

Residual chlorine levels are maintained in the distribution system to effectively provide secondary disinfection throughout the system.

Shelburne's ground water supply contains high iron levels and is an aesthetic concern due to its potential for staining of fixtures and clothing. To control the release of iron into the water Shelburne's raw water goes through another step in treatment called iron sequestering.

### List all water treatment chemicals used over this reporting period

- Sodium Hypochlorite (12% solution) NSF - disinfection
- Waterworx (28% solution) NSF – iron sequestering

### Were any significant expenses incurred to?

- |                                     |                                       |
|-------------------------------------|---------------------------------------|
| <input checked="" type="checkbox"/> | Install required equipment            |
| <input checked="" type="checkbox"/> | Repair required equipment             |
| <input checked="" type="checkbox"/> | Replace required equipment            |
| <input type="checkbox"/>            | No significant expenses were incurred |

### Please provide a brief description of any significant expenses incurred

- Diesel Generator Annual Service completed by Sommers
- Gerrits on site to install new check valves on riser pipes of wells 7 and 8
- Syntec on site to check function and condition of check valves – ok
- UV service by H2Flow
- Annual flow meter calibrations by Flowmetrix
- H2Flow on site for 6-month service

**Provide details on the notices submitted in accordance with subsection 18(1) of the Safe Drinking-Water Act or section 16-4 of Schedule 16 of O.Reg.170/03 and reported to Spills Action Centre**

Incident Date (yyyy/mm/dd)	Parameter	Result	Unit of Measure	Corrective Action	Corrective Action Date (yyyy/mm/dd)
2018/01/11	AWQI# 138539 – Well 5 – Arsenic Level	14.5	µg/L	Change chain of custody to reflect sample to be taken as a blended sample with either Well 7 or Well 8 running	2018/01/11
2018/01/17	AWQI# 138590 - Well 3 – Arsenic Level	11.5	µg/L	On-going	On-going
2018/02/21	AWQI# 138776 – Well 1 – Sodium Level	82.0	mg/L	Operator resampled	2018/03/06
2018/04/20	AWQI# 139155 - Well 3 – Arsenic Level	11.1	µg/L	On-going	On-going
2018/06/28	AWQI# 140105 – Well 3 – Arsenic Level	11.4	µg/L	On-going	On-going

**Table 1. Microbiological testing done under the Schedule 10, 11 or 12 of Regulation 170/03, during this reporting period.**

Location	Number of Samples	Range of E.coli Results		Range of Total Coliforms Results		Number of HPC Samples	Range of HPC Samples	
		Min.	Max.	Min.	Max.		Min.	Max.
Raw Water - Well 1	52	0	0	0	2	n/a	n/a	n/a
Raw Water - Well 3	52	0	0	0	0	n/a	n/a	n/a
Raw Water - Well 5	52	0	0	0	1	n/a	n/a	n/a
Raw Water - Well 6	52	0	0	0	0	n/a	n/a	n/a
Raw Water - Well 7	52	0	0	0	1	n/a	n/a	n/a
Raw Water - Well 8	52	0	0	0	0	n/a	n/a	n/a
Treated Water - Well 1	46	0	0	0	0	46	0	1
Treated Water - Well 3	52	0	0	0	0	52	0	2
Treated Water - Well 5	52	0	0	0	0	51	0	3
Treated Water - Well 6	51	0	0	0	0	50	0	2
Treated Water - Well 7	52	0	0	0	0	51	0	1
Treated Water - Well 8	52	0	0	0	0	51	0	2
DW location	211	0	0	0	0	204	0	52

**Table 2. Operational testing done under Schedule 7, 8 or 9 during the period covered by this Annual Report.**

	Number of Grab Samples	Range of Results	
		Minimum	Maximum
<b>Raw Water</b>			
Turbidity, Well 1 (NTU)	12	0.01	0.35
Turbidity, Well 3 (NTU)	13	0	0.39
Turbidity, Well 5 (NTU)	12	0.06	0.63
Turbidity, Well 6 (NTU)	12	0.07	0.37
Turbidity, Well 7 (NTU)	12	0.08	0.47
Turbidity, Well 8 (NTU)	12	0.07	0.41
<b>Treated Water</b>			
Free Chlorine Residual, TW1 (mg/L)	8760	0.62	1.69
Free Chlorine Residual, TW3 (mg/L)	8760	0.17	1.95
Free Chlorine Residual, TW5 (mg/L)	8760	0.31	2.54
Free Chlorine Residual, TW6 (mg/L)	8760	0.33	2.41
Free Chlorine Residual, TW7 (mg/L)	8760	0.54	1.96
Free Chlorine Residual, TW8 (mg/L)	8760	0.64	2.01
<b>Distribution Water</b>			
Free Chlorine Residual, DW (mg/L)	364	0.09	1.58

NOTE: For continuous monitors use 8760 as the number of sample.

**Table 3. Summary of additional testing and sampling carried out in accordance with the requirement of an approval, order or other legal instrument.**

Date of legal instrument issued	Parameter	Date Sampled	Result	Unit of Measure
MDWL#109-101 Issue #4 2017/06/09	Arsenic Well 5/6 with Well 7/8	Jan-Dec 2018 (Monthly)	6.7-9.2  5.6-8.3  5.5-7.2	µg/L
	Blending Building			
	Water Tower			
	First Service from Blending Building			

**Table 4. Summary of Inorganic parameters tested during this reporting period or most recent sample results**

TREATED WATER	Sample Date (yyyy/mm/dd)	Sample Result	MAC	No. of Exceedances	
				MAC	1/2 MAC
Antimony: Sb (ug/L) - TW1	2018/01/15	<MDL 0.02	6.0	No	No
Antimony: Sb (ug/L) - TW3	2016/01/11	0.04	6.0	No	No
Antimony: Sb (ug/L) - TW5	2016/01/11	<MDL 0.02	6.0	No	No
Antimony: Sb (ug/L) - TW6	2016/01/11	<MDL 0.02	6.0	No	No
Antimony: Sb (ug/L) - TW7	2016/04/06	1.0	6.0	No	No
Antimony: Sb (ug/L) - TW8	2016/04/06	1.0	6.0	No	No
Arsenic: As (ug/L) - TW1	2018/10/23	7.1	10.0	No	Yes
Arsenic: As (ug/L) - TW3	2018/10/01	9.8	10.0	No	Yes
Arsenic: As (ug/L) - TW5	2018/10/01	7.8	10.0	No	Yes
Arsenic: As (ug/L) - TW6	2018/10/01	7.9	10.0	No	Yes
Arsenic: As (ug/L) - TW7	2018/10/01	0.9	10.0	No	No
Arsenic: As (ug/L) - TW8	2018/10/01	1.2	10.0	No	No
Barium: Ba (ug/L) - TW1	2018/01/15	143.0	1000.0	No	No
Barium: Ba (ug/L) - TW3	2016/01/11	133.0	1000.0	No	No
Barium: Ba (ug/L) - TW5	2016/01/11	106.0	1000.0	No	No
Barium: Ba (ug/L) - TW6	2016/01/11	110.0	1000.0	No	No
Barium: Ba (ug/L) - TW7	2016/04/06	14.5	1000.0	No	No
Barium: Ba (ug/L) - TW8	2016/04/06	14.6	1000.0	No	No
Boron: B (ug/L) - TW1	2018/01/15	38.0	5000.0	No	No
Boron: B (ug/L) - TW3	2016/01/11	34.0	5000.0	No	No
Boron: B (ug/L) - TW5	2016/01/11	35.9	5000.0	No	No
Boron: B (ug/L) - TW6	2016/01/11	35.6	5000.0	No	No
Boron: B (ug/L) - TW7	2016/04/06	7.0	5000.0	No	No
Boron: B (ug/L) - TW8	2016/04/06	7.0	5000.0	No	No
Cadmium: Cd (ug/L) - TW1	2018/01/15	0.021	5.0	No	No
Cadmium: Cd (ug/L) - TW3	2016/01/11	<MDL 0.003	5.0	No	No
Cadmium: Cd (ug/L) - TW5	2016/01/11	<MDL 0.003	5.0	No	No
Cadmium: Cd (ug/L) - TW6	2016/01/11	<MDL 0.003	5.0	No	No
Cadmium: Cd (ug/L) - TW7	2016/04/06	0.016	5.0	No	No
Cadmium: Cd (ug/L) - TW8	2016/04/06	0.067	5.0	No	No
Chromium: Cr (ug/L) - TW1	2018/01/15	0.11	50.0	No	No
Chromium: Cr (ug/L) - TW3	2016/01/11	0.24	50.0	No	No
Chromium: Cr (ug/L) - TW5	2016/01/11	<MDL 0.03	50.0	No	No
Chromium: Cr (ug/L) - TW6	2016/01/11	<MDL 0.03	50.0	No	No
Chromium: Cr (ug/L) - TW7	2016/04/06	0.28	50.0	No	No
Chromium: Cr (ug/L) - TW8	2016/04/06	0.35	50.0	No	No
Mercury: Hg (ug/L) - TW1	2018/01/15	<MDL 0.01	1.0	No	No

Mercury: Hg (ug/L) - TW3	2016/01/11	<MDL 0.01	1.0	No	No
Mercury: Hg (ug/L) - TW5	2016/01/11	<MDL 0.01	1.0	No	No
Mercury: Hg (ug/L) - TW6	2016/01/11	<MDL 0.01	1.0	No	No
Mercury: Hg (ug/L) - TW7	2016/04/06	<MDL 0.01	1.0	No	No
Mercury: Hg (ug/L) - TW8	2016/04/06	<MDL 0.01	1.0	No	No
Selenium: Se (ug/L) - TW1	2018/01/15	0.05	50.0	No	No
Selenium: Se (ug/L) - TW3	2016/01/11	<MDL 0.04	50.0	No	No
Selenium: Se (ug/L) - TW5	2016/01/11	<MDL 0.04	50.0	No	No
Selenium: Se (ug/L) - TW6	2016/01/11	0.06	50.0	No	No
Selenium: Se (ug/L) - TW7	2016/04/06	1.23	50.0	No	No
Selenium: Se (ug/L) - TW8	2016/04/06	1.21	50.0	No	No
Uranium: U (ug/L) - TW1	2018/01/15	0.969	20.0	No	No
Uranium: U (ug/L) - TW3	2016/01/11	0.504	20.0	No	No
Uranium: U (ug/L) - TW5	2016/01/11	0.624	20.0	No	No
Uranium: U (ug/L) - TW6	2016/01/11	0.591	20.0	No	No
Uranium: U (ug/L) - TW7	2016/04/06	0.597	20.0	No	No
Uranium: U (ug/L) - TW8	2016/04/06	0.591	20.0	No	No
<b>Additional Inorganics</b>					
Fluoride (mg/L) - TW1	2018/02/14	1.05	1.5	No	Yes
Fluoride (mg/L) - TW3	2018/02/14	1.1	1.5	No	Yes
Fluoride (mg/L) - TW5	2018/02/14	1.2	1.5	No	Yes
Fluoride (mg/L) - TW6	2018/02/14	1.12	1.5	No	Yes
Fluoride (mg/L) - TW7	2018/02/14	0.16	1.5	No	No
Fluoride (mg/L) - TW8	2018/02/14	0.14	1.5	No	No
Nitrite (mg/L) - TW1	2018/01/15	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	2018/06/25	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW1	2018/04/17	0.004	1.0	No	No
Nitrite (mg/L) - TW1	2018/10/23	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	2018/01/15	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	2018/06/25	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	2018/04/17	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW3	2018/10/01	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW5	2018/01/15	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW5	2018/06/25	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW5	2018/04/18	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW5	2018/10/01	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW6	2018/01/15	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW6	2018/06/25	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW6	2018/04/18	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW6	2018/10/01	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW7	2018/01/15	<MDL 0.003	1.0	No	No

Nitrite (mg/L) - TW7	2018/06/25	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW7	2018/04/17	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW7	2018/10/01	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW8	2018/01/15	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW8	2018/06/25	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW8	2018/04/17	<MDL 0.003	1.0	No	No
Nitrite (mg/L) - TW8	2018/10/01	<MDL 0.003	1.0	No	No
Nitrate (mg/L) - TW1	2018/01/15	0.019	10.0	No	No
Nitrate (mg/L) - TW1	2018/06/25	0.07	10.0	No	No
Nitrate (mg/L) - TW1	2018/04/17	0.098	10.0	No	No
Nitrate (mg/L) - TW1	2018/10/23	0.254	10.0	No	No
Nitrate (mg/L) - TW3	2018/01/15	0.01	10.0	No	No
Nitrate (mg/L) - TW3	2018/06/25	<MDL 0.006	10.0	No	No
Nitrate (mg/L) - TW3	2018/04/17	0.025	10.0	No	No
Nitrate (mg/L) - TW3	2018/10/01	<MDL 0.006	10.0	No	No
Nitrate (mg/L) - TW5	2018/01/15	0.01	10.0	No	No
Nitrate (mg/L) - TW5	2018/06/25	<MDL 0.006	10.0	No	No
Nitrate (mg/L) - TW5	2018/04/18	0.013	10.0	No	No
Nitrate (mg/L) - TW5	2018/10/01	0.019	10.0	No	No
Nitrate (mg/L) - TW6	2018/01/15	<MDL 0.006	10.0	No	No
Nitrate (mg/L) - TW6	2018/06/25	0.016	10.0	No	No
Nitrate (mg/L) - TW6	2018/04/18	0.312	10.0	No	No
Nitrate (mg/L) - TW6	2018/10/01	<MDL 0.006	10.0	No	No
Nitrate (mg/L) - TW7	2018/01/15	0.532	10.0	No	No
Nitrate (mg/L) - TW7	2018/06/25	0.674	10.0	No	No
Nitrate (mg/L) - TW7	2018/04/17	0.577	10.0	No	No
Nitrate (mg/L) - TW7	2018/10/01	0.663	10.0	No	No
Nitrate (mg/L) - TW8	2018/01/15	0.431	10.0	No	No
Nitrate (mg/L) - TW8	2018/06/25	0.48	10.0	No	No
Nitrate (mg/L) - TW8	2018/04/17	0.471	10.0	No	No
Nitrate (mg/L) - TW8	2018/10/01	0.494	10.0	No	No
Sodium: Na (mg/L) - TW1	2018/02/22	105.0	20*	n/a	n/a
Sodium: Na (mg/L) - TW3	2018/02/14	12.7	20*	n/a	n/a
Sodium: Na (mg/L) - TW5	2018/02/14	11.9	20*	n/a	n/a
Sodium: Na (mg/L) - TW6	2018/02/14	13.0	20*	n/a	n/a
Sodium: Na (mg/L) - TW7	2018/02/14	2.11	20*	n/a	n/a
Sodium: Na (mg/L) - TW8	2018/02/14	2.02	20*	n/a	n/a

\*There is no "MAC" for Sodium. The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L so that this information may be communicated to local physicians for their use with patients on sodium restricted diets.



**Table 5. Summary of lead testing under Schedule 15.1 during this reporting period (applicable to the following drinking water systems; large municipal residential systems, small municipal residential systems, and non-municipal year-round residential systems)**

Location Type	Number of Samples	Range of Results		MAC	Number of Exceedances
		Minimum	Maximum		
Distribution - Lead Results (µg/L)	3	0.24	0.84	10	0
Distribution - Alkalinity (mg/L)	6	203	218	n/a	n/a
DW location - pH In-House	6	7.65	7.83	n/a	n/a

The Shelburne Drinking Water Systems qualifies for plumbing exemption.

**Table 6. Summary of Organic parameters sampled during this reporting period or the most recent sample results**

TREATED WATER	Sample Date (yyyy/mm/dd)	Sample Result	MAC	Number of Exceedances	
				MAC	1/2 MAC
Alachlor (µg/L) - TW1	2018/01/15	<MDL 0.02	5.00	No	No
Alachlor (µg/L) - TW3	2016/01/11	<MDL 0.02	5.00	No	No
Alachlor (µg/L) - TW5	2016/01/11	<MDL 0.02	5.00	No	No
Alachlor (µg/L) - TW6	2016/01/11	<MDL 0.02	5.00	No	No
Alachlor (µg/L) - TW7	2016/04/06	<MDL 0.02	5.00	No	No
Alachlor (µg/L) - TW8	2016/04/06	<MDL 0.02	5.00	No	No
Atrazine + N-dealkylated metabolites (µg/L) - TW1	2018/01/15	<MDL 0.01	5.00	No	No
Atrazine + N-dealkylated metabolites (µg/L) - TW3	2016/01/11	<MDL 0.01	5.00	No	No
Atrazine + N-dealkylated metabolites (µg/L) - TW5	2016/01/11	<MDL 0.01	5.00	No	No
Atrazine + N-dealkylated metabolites (µg/L) - TW6	2016/01/11	<MDL 0.01	5.00	No	No
Atrazine + N-dealkylated metabolites (µg/L) - TW7	2016/04/06	<MDL 0.01	5.00	No	No
Atrazine + N-dealkylated metabolites (µg/L) - TW8	2016/04/06	<MDL 0.01	5.00	No	No
Azinphos-methyl (µg/L) - TW1	2018/01/15	<MDL 0.05	20.00	No	No
Azinphos-methyl (µg/L) - TW3	2016/01/11	<MDL 0.05	20.00	No	No
Azinphos-methyl (µg/L) - TW5	2016/01/11	<MDL 0.05	20.00	No	No
Azinphos-methyl (µg/L) - TW6	2016/01/11	<MDL 0.05	20.00	No	No
Azinphos-methyl (µg/L) - TW7	2016/04/06	<MDL 0.05	20.00	No	No
Azinphos-methyl (µg/L) - TW8	2016/04/06	<MDL 0.05	20.00	No	No
Benzene (µg/L) - TW1	2018/01/15	<MDL 0.32	1.00	No	No
Benzene (µg/L) - TW3	2016/01/11	<MDL 0.32	1.00	No	No
Benzene (µg/L) - TW5	2016/01/11	<MDL 0.32	1.00	No	No
Benzene (µg/L) - TW6	2016/01/11	<MDL 0.32	1.00	No	No
Benzene (µg/L) - TW7	2016/04/06	<MDL 0.32	1.00	No	No
Benzene (µg/L) - TW8	2016/04/06	<MDL 0.32	1.00	No	No
Benzo(a)pyrene (µg/L) - TW1	2018/01/15	<MDL 0.004	0.01	No	No

Benzo(a)pyrene (µg/L) - TW3	2016/01/11	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (µg/L) - TW5	2016/01/11	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (µg/L) - TW6	2016/01/11	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (µg/L) - TW7	2016/04/06	<MDL 0.004	0.01	No	No
Benzo(a)pyrene (µg/L) - TW8	2016/04/06	<MDL 0.004	0.01	No	No
Bromoxynil (µg/L) - TW1	2018/01/15	<MDL 0.33	5.00	No	No
Bromoxynil (µg/L) - TW3	2016/01/11	<MDL 0.33	5.00	No	No
Bromoxynil (µg/L) - TW5	2016/01/11	<MDL 0.33	5.00	No	No
Bromoxynil (µg/L) - TW6	2016/01/11	<MDL 0.33	5.00	No	No
Bromoxynil (µg/L) - TW7	2016/04/06	<MDL 0.33	5.00	No	No
Bromoxynil (µg/L) - TW8	2016/04/06	<MDL 0.33	5.00	No	No
Carbaryl (µg/L) - TW1	2018/01/15	<MDL 0.05	90.00	No	No
Carbaryl (µg/L) - TW3	2016/01/11	<MDL 0.05	90.00	No	No
Carbaryl (µg/L) - TW5	2016/01/11	<MDL 0.05	90.00	No	No
Carbaryl (µg/L) - TW6	2016/01/11	<MDL 0.05	90.00	No	No
Carbaryl (µg/L) - TW7	2016/04/06	<MDL 0.05	90.00	No	No
Carbaryl (µg/L) - TW8	2016/04/06	<MDL 0.05	90.00	No	No
Carbofuran (µg/L) - TW1	2018/01/15	<MDL 0.01	90.00	No	No
Carbofuran (µg/L) - TW3	2016/01/11	<MDL 0.01	90.00	No	No
Carbofuran (µg/L) - TW5	2016/01/11	<MDL 0.01	90.00	No	No
Carbofuran (µg/L) - TW6	2016/01/11	<MDL 0.01	90.00	No	No
Carbofuran (µg/L) - TW7	2016/04/06	<MDL 0.01	90.00	No	No
Carbofuran (µg/L) - TW8	2016/04/06	<MDL 0.01	90.00	No	No
Carbon Tetrachloride (µg/L) - TW1	2018/01/15	<MDL 0.16	2.00	No	No
Carbon Tetrachloride (µg/L) - TW3	2016/01/11	<MDL 0.16	2.00	No	No
Carbon Tetrachloride (µg/L) - TW5	2016/01/11	<MDL 0.16	2.00	No	No
Carbon Tetrachloride (µg/L) - TW6	2016/01/11	<MDL 0.16	2.00	No	No
Carbon Tetrachloride (µg/L) - TW7	2016/04/06	<MDL 0.16	2.00	No	No
Carbon Tetrachloride (µg/L) - TW8	2016/04/06	<MDL 0.16	2.00	No	No
Chlorpyrifos (µg/L) - TW1	2018/01/15	<MDL 0.02	90.00	No	No
Chlorpyrifos (µg/L) - TW3	2016/01/11	<MDL 0.02	90.00	No	No
Chlorpyrifos (µg/L) - TW5	2016/01/11	<MDL 0.02	90.00	No	No
Chlorpyrifos (µg/L) - TW6	2016/01/11	<MDL 0.02	90.00	No	No
Chlorpyrifos (µg/L) - TW7	2016/04/06	<MDL 0.02	90.00	No	No
Chlorpyrifos (µg/L) - TW8	2016/04/06	<MDL 0.02	90.00	No	No
Diazinon (µg/L) - TW1	2018/01/15	<MDL 0.02	20.00	No	No
Diazinon (µg/L) - TW3	2016/01/11	<MDL 0.02	20.00	No	No
Diazinon (µg/L) - TW5	2016/01/11	<MDL 0.02	20.00	No	No
Diazinon (µg/L) - TW6	2016/01/11	<MDL 0.02	20.00	No	No
Diazinon (µg/L) - TW7	2016/04/06	<MDL 0.02	20.00	No	No
Diazinon (µg/L) - TW8	2016/04/06	<MDL 0.02	20.00	No	No

Dicamba (µg/L) - TW1	2018/01/15	<MDL 0.2	120.00	No	No
Dicamba (µg/L) - TW3	2016/01/11	<MDL 0.2	120.00	No	No
Dicamba (µg/L) - TW5	2016/01/11	<MDL 0.2	120.00	No	No
Dicamba (µg/L) - TW6	2016/01/11	<MDL 0.2	120.00	No	No
Dicamba (µg/L) - TW7	2016/04/06	<MDL 0.2	120.00	No	No
Dicamba (µg/L) - TW8	2016/04/06	<MDL 0.2	120.00	No	No
1,2-Dichlorobenzene (µg/L) - TW1	2018/01/15	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (µg/L) - TW3	2016/01/11	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (µg/L) - TW5	2016/01/11	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (µg/L) - TW6	2016/01/11	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (µg/L) - TW7	2016/04/06	<MDL 0.41	200.00	No	No
1,2-Dichlorobenzene (µg/L) - TW8	2016/04/06	<MDL 0.41	200.00	No	No
1,4-Dichlorobenzene (µg/L) - TW1	2018/01/15	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (µg/L) - TW3	2016/01/11	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (µg/L) - TW5	2016/01/11	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (µg/L) - TW6	2016/01/11	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (µg/L) - TW7	2016/04/06	<MDL 0.36	5.00	No	No
1,4-Dichlorobenzene (µg/L) - TW8	2016/04/06	<MDL 0.36	5.00	No	No
1,2-Dichloroethane (µg/L) - TW1	2018/01/15	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (µg/L) - TW3	2016/01/11	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (µg/L) - TW5	2016/01/11	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (µg/L) - TW6	2016/01/11	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (µg/L) - TW7	2016/04/06	<MDL 0.35	5.00	No	No
1,2-Dichloroethane (µg/L) - TW8	2016/04/06	<MDL 0.35	5.00	No	No
1,1-Dichloroethylene (µg/L) - TW1	2018/01/15	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (µg/L) - TW3	2016/01/11	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (µg/L) - TW5	2016/01/11	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (µg/L) - TW6	2016/01/11	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (µg/L) - TW7	2016/04/06	<MDL 0.33	14.00	No	No
1,1-Dichloroethylene (µg/L) - TW8	2016/04/06	<MDL 0.33	14.00	No	No
Dichloromethane (Methylene Chloride) (µg/L) - TW1	2018/01/15	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (µg/L) - TW3	2016/01/11	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (µg/L) - TW5	2016/01/11	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (µg/L) - TW6	2016/01/11	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (µg/L) - TW7	2016/04/06	<MDL 0.35	50.00	No	No
Dichloromethane (Methylene Chloride) (µg/L) - TW8	2016/04/06	<MDL 0.35	50.00	No	No
2,4-Dichlorophenol (µg/L) - TW1	2018/01/15	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (µg/L) - TW3	2016/01/11	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (µg/L) - TW5	2016/01/11	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (µg/L) - TW6	2016/01/11	<MDL 0.15	900.00	No	No
2,4-Dichlorophenol (µg/L) - TW7	2016/04/06	<MDL 0.15	900.00	No	No

2,4-Dichlorophenol (µg/L) - TW8	2016/04/06	<MDL 0.15	900.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW1	2018/01/15	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW3	2016/01/11	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW5	2016/01/11	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW6	2016/01/11	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW7	2016/04/06	<MDL 0.19	100.00	No	No
2,4-Dichlorophenoxy acetic acid (2,4-D) (µg/L) - TW8	2016/04/06	<MDL 0.19	100.00	No	No
Diclofop-methyl (µg/L) - TW1	2018/01/15	<MDL 0.4	9.00	No	No
Diclofop-methyl (µg/L) - TW3	2016/01/11	<MDL 0.4	9.00	No	No
Diclofop-methyl (µg/L) - TW5	2016/01/11	<MDL 0.4	9.00	No	No
Diclofop-methyl (µg/L) - TW6	2016/01/11	<MDL 0.4	9.00	No	No
Diclofop-methyl (µg/L) - TW7	2016/04/06	<MDL 0.4	9.00	No	No
Diclofop-methyl (µg/L) - TW8	2016/04/06	<MDL 0.4	9.00	No	No
Dimethoate (µg/L) - TW1	2018/01/15	<MDL 0.03	20.00	No	No
Dimethoate (µg/L) - TW3	2016/01/11	<MDL 0.03	20.00	No	No
Dimethoate (µg/L) - TW5	2016/01/11	<MDL 0.03	20	No	No
Dimethoate (µg/L) - TW6	2016/01/11	<MDL 0.03	20	No	No
Dimethoate (µg/L) - TW7	2016/04/06	<MDL 0.03	20	No	No
Dimethoate (µg/L) - TW8	2016/04/06	<MDL 0.03	20	No	No
Diquat (µg/L) - TW1	2018/01/15	<MDL 1.0	70	No	No
Diquat (µg/L) - TW3	2016/01/11	<MDL 1.0	70	No	No
Diquat (µg/L) - TW5	2016/01/11	<MDL 1.0	70	No	No
Diquat (µg/L) - TW6	2016/01/11	<MDL 1.0	70	No	No
Diquat (µg/L) - TW7	2016/04/06	<MDL 1.0	70	No	No
Diquat (µg/L) - TW8	2016/04/06	<MDL 1.0	70	No	No
Diuron (µg/L) - TW1	2018/01/15	<MDL 0.03	150	No	No
Diuron (µg/L) - TW3	2016/01/11	<MDL 0.03	150	No	No
Diuron (µg/L) - TW5	2016/01/11	<MDL 0.03	150	No	No
Diuron (µg/L) - TW6	2016/01/11	<MDL 0.03	150	No	No
Diuron (µg/L) - TW7	2016/04/06	<MDL 0.03	150	No	No
Diuron (µg/L) - TW8	2016/04/06	<MDL 0.03	150	No	No
Glyphosate (µg/L) - TW1	2018/01/15	<MDL 1.0	280	No	No
Glyphosate (µg/L) - TW3	2016/01/11	<MDL 1.0	280	No	No
Glyphosate (µg/L) - TW5	2016/01/11	<MDL 1.0	280	No	No
Glyphosate (µg/L) - TW6	2016/01/11	<MDL 1.0	280	No	No
Glyphosate (µg/L) - TW7	2016/04/06	<MDL 1.0	280	No	No
Glyphosate (µg/L) - TW8	2016/04/06	<MDL 1.0	280	No	No
Malathion (µg/L) - TW1	2018/01/15	<MDL 0.02	190	No	No
Malathion (µg/L) - TW3	2016/01/11	<MDL 0.02	190	No	No
Malathion (µg/L) - TW5	2016/01/11	<MDL 0.02	190	No	No
Malathion (µg/L) - TW6	2016/01/11	<MDL 0.02	190	No	No

Malathion (µg/L) - TW7	2016/04/06	<MDL 0.02	190	No	No
Malathion (µg/L) - TW8	2016/04/06	<MDL 0.02	190	No	No
Metolachlor (µg/L) - TW1	2018/01/15	<MDL 0.01	50	No	No
Metolachlor (µg/L) - TW3	2016/01/11	<MDL 0.01	50	No	No
Metolachlor (µg/L) - TW5	2016/01/11	<MDL 0.01	50	No	No
Metolachlor (µg/L) - TW6	2016/01/11	<MDL 0.01	50	No	No
Metolachlor (µg/L) - TW7	2016/04/06	<MDL 0.01	50	No	No
Metolachlor (µg/L) - TW8	2016/04/06	<MDL 0.01	50	No	No
Metribuzin (µg/L) - TW1	2018/01/15	<MDL 0.02	80	No	No
Metribuzin (µg/L) - TW3	2016/01/11	<MDL 0.02	80	No	No
Metribuzin (µg/L) - TW5	2016/01/11	<MDL 0.02	80	No	No
Metribuzin (µg/L) - TW6	2016/01/11	<MDL 0.02	80	No	No
Metribuzin (µg/L) - TW7	2016/04/06	<MDL 0.02	80	No	No
Metribuzin (µg/L) - TW8	2016/04/06	<MDL 0.02	80	No	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW1	2018/01/15	<MDL 0.3	80	No	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW3	2016/01/11	<MDL 0.3	80	No	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW5	2016/01/11	<MDL 0.3	80	No	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW6	2016/01/11	<MDL 0.3	80	No	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW7	2016/04/06	<MDL 0.3	80	No	No
Monochlorobenzene (Chlorobenzene) (µg/L) - TW8	2016/04/06	<MDL 0.3	80	No	No
Paraquat (µg/L) - TW1	2018/01/15	<MDL 2.0	10	No	No
Paraquat (µg/L) - TW3	2016/01/11	<MDL 1.0	10	No	No
Paraquat (µg/L) - TW5	2016/01/11	<MDL 1.0	10	No	No
Paraquat (µg/L) - TW6	2016/01/11	<MDL 1.0	10	No	No
Paraquat (µg/L) - TW7	2016/04/06	<MDL 1.0	10	No	No
Paraquat (µg/L) - TW8	2016/04/06	<MDL 1.0	10	No	No
PCB (µg/L) - TW1	2018/01/15	<MDL 0.04	3	No	No
PCB (µg/L) - TW3	2016/01/11	<MDL 0.04	3	No	No
PCB (µg/L) - TW5	2016/01/11	<MDL 0.04	3	No	No
PCB (µg/L) - TW6	2016/01/11	<MDL 0.04	3	No	No
PCB (µg/L) - TW7	2016/04/06	<MDL 0.04	3	No	No
PCB (µg/L) - TW8	2016/04/06	<MDL 0.04	3	No	No
Pentachlorophenol (µg/L) - TW1	2018/01/15	<MDL 0.15	60	No	No
Pentachlorophenol (µg/L) - TW3	2016/01/11	<MDL 0.15	60	No	No
Pentachlorophenol (µg/L) - TW5	2016/01/11	<MDL 0.15	60	No	No
Pentachlorophenol (µg/L) - TW6	2016/01/11	<MDL 0.15	60	No	No
Pentachlorophenol (µg/L) - TW7	2016/04/06	<MDL 0.15	60	No	No
Pentachlorophenol (µg/L) - TW8	2016/04/06	<MDL 0.15	60	No	No
Phorate (µg/L) - TW1	2018/01/15	<MDL 0.01	2	No	No
Phorate (µg/L) - TW3	2016/01/11	<MDL 0.01	2	No	No
Phorate (µg/L) - TW5	2016/01/11	<MDL 0.01	2	No	No

Phorate (µg/L) - TW6	2016/01/11	<MDL 0.01	2	No	No
Phorate (µg/L) - TW7	2016/04/06	<MDL 0.01	2	No	No
Phorate (µg/L) - TW8	2016/04/06	<MDL 0.01	2	No	No
Picloram (µg/L) - TW1	2018/01/15	<MDL 1.0	190	No	No
Picloram (µg/L) - TW3	2016/01/11	<MDL 1.0	190	No	No
Picloram (µg/L) - TW5	2016/01/11	<MDL 1.0	190	No	No
Picloram (µg/L) - TW6	2016/01/11	<MDL 1.0	190	No	No
Picloram (µg/L) - TW7	2016/04/06	<MDL 1.0	190	No	No
Picloram (µg/L) - TW8	2016/04/06	<MDL 1.0	190	No	No
Prometryne (µg/L) - TW1	2018/01/15	<MDL 0.03	1	No	No
Prometryne (µg/L) - TW3	2016/01/11	<MDL 0.03	1	No	No
Prometryne (µg/L) - TW5	2016/01/11	<MDL 0.03	1	No	No
Prometryne (µg/L) - TW6	2016/01/11	<MDL 0.03	1	No	No
Prometryne (µg/L) - TW7	2016/04/06	<MDL 0.03	1	No	No
Prometryne (µg/L) - TW8	2016/04/06	<MDL 0.03	1	No	No
Simazine (µg/L) - TW1	2018/01/15	<MDL 0.01	10	No	No
Simazine (µg/L) - TW3	2016/01/11	<MDL 0.01	10	No	No
Simazine (µg/L) - TW5	2016/01/11	<MDL 0.01	10	No	No
Simazine (µg/L) - TW6	2016/01/11	<MDL 0.01	10	No	No
Simazine (µg/L) - TW7	2016/04/06	<MDL 0.01	10	No	No
Simazine (µg/L) - TW8	2016/04/06	<MDL 0.01	10	No	No
Terbufos (µg/L) - TW1	2018/01/15	<MDL 0.01	1	No	No
Terbufos (µg/L) - TW3	2016/01/11	<MDL 0.01	1	No	No
Terbufos (µg/L) - TW5	2016/01/11	<MDL 0.01	1	No	No
Terbufos (µg/L) - TW6	2016/01/11	<MDL 0.01	1	No	No
Terbufos (µg/L) - TW7	2016/04/06	<MDL 0.01	1	No	No
Terbufos (µg/L) - TW8	2016/04/06	<MDL 0.01	1	No	No
Tetrachloroethylene (µg/L) - TW1	2018/01/15	<MDL 0.35	10	No	No
Tetrachloroethylene (µg/L) - TW3	2016/01/11	<MDL 0.35	10	No	No
Tetrachloroethylene (µg/L) - TW5	2016/01/11	<MDL 0.35	10	No	No
Tetrachloroethylene (µg/L) - TW6	2016/01/11	<MDL 0.35	10	No	No
Tetrachloroethylene (µg/L) - TW7	2016/04/06	<MDL 0.35	10	No	No
Tetrachloroethylene (µg/L) - TW8	2016/04/06	<MDL 0.35	10	No	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW1	2018/01/15	<MDL 0.2	100	No	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW3	2016/01/11	<MDL 0.2	100	No	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW5	2016/01/11	<MDL 0.2	100	No	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW6	2016/01/11	<MDL 0.2	100	No	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW7	2016/04/06	<MDL 0.2	100	No	No
2,3,4,6-Tetrachlorophenol (µg/L) - TW8	2016/04/06	<MDL 0.2	100	No	No
Triallate (µg/L) - TW1	2018/01/15	<MDL 0.01	230	No	No
Triallate (µg/L) - TW3	2016/01/11	<MDL 0.01	230	No	No

Triallate (µg/L) - TW5	2016/01/11	<MDL 0.01	230	No	No
Triallate (µg/L) - TW6	2016/01/11	<MDL 0.01	230	No	No
Triallate (µg/L) - TW7	2016/04/06	<MDL 0.01	230	No	No
Triallate (µg/L) - TW8	2016/04/06	<MDL 0.01	230	No	No
Trichloroethylene (µg/L) - TW1	2018/01/15	<MDL 0.44	5	No	No
Trichloroethylene (µg/L) - TW3	2016/01/11	<MDL 0.44	5	No	No
Trichloroethylene (µg/L) - TW5	2016/01/11	<MDL 0.44	5	No	No
Trichloroethylene (µg/L) - TW6	2016/01/11	<MDL 0.44	5	No	No
Trichloroethylene (µg/L) - TW7	2016/04/06	<MDL 0.44	5	No	No
Trichloroethylene (µg/L) - TW8	2016/04/06	<MDL 0.44	5	No	No
2,4,6-Trichlorophenol (µg/L) - TW1	2018/01/15	<MDL 0.25	5	No	No
2,4,6-Trichlorophenol (µg/L) - TW3	2016/01/11	<MDL 0.25	5	No	No
2,4,6-Trichlorophenol (µg/L) - TW5	2016/01/11	<MDL 0.25	5	No	No
2,4,6-Trichlorophenol (µg/L) - TW6	2016/01/11	<MDL 0.25	5	No	No
2,4,6-Trichlorophenol (µg/L) - TW7	2016/04/06	<MDL 0.25	5	No	No
2,4,6-Trichlorophenol (µg/L) - TW8	2016/04/06	<MDL 0.25	5	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW1	2018/01/15	<MDL 0.12	100	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW3	2016/01/11	<MDL 0.12	100	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW5	2016/01/11	<MDL 0.12	100	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW6	2016/01/11	<MDL 0.12	100	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW7	2016/04/06	<MDL 0.12	100	No	No
2-methyl-4-chlorophenoxyacetic acid (MCPA) (µg/L) - TW8	2016/04/06	<MDL 0.12	100	No	No
Trifluralin (µg/L) - TW1	2018/01/15	<MDL 0.02	45	No	No
Trifluralin (µg/L) - TW3	2016/01/11	<MDL 0.02	45	No	No
Trifluralin (µg/L) - TW5	2016/01/11	<MDL 0.02	45	No	No
Trifluralin (µg/L) - TW6	2016/01/11	<MDL 0.02	45	No	No
Trifluralin (µg/L) - TW7	2016/04/06	<MDL 0.02	45	No	No
Trifluralin (µg/L) - TW8	2016/04/06	<MDL 0.02	45	No	No
Vinyl Chloride (µg/L) - TW1	2018/01/15	<MDL 0.17	1	No	No
Vinyl Chloride (µg/L) - TW3	2016/01/11	<MDL 0.17	1	No	No
Vinyl Chloride (µg/L) - TW5	2016/01/11	<MDL 0.17	1	No	No
Vinyl Chloride (µg/L) - TW6	2016/01/11	<MDL 0.17	1	No	No
Vinyl Chloride (µg/L) - TW7	2016/04/06	<MDL 0.17	1	No	No
Vinyl Chloride (µg/L) - TW8	2016/04/06	<MDL 0.17	1	No	No
<b>DISTRIBUTION WATER</b>					
Trihalomethane: Total (µg/L) Annual Average - DW1	2018/01/01	4.55	100	No	No
Trihalomethane: Total (µg/L) Annual Average - DW2	2018/01/01	2.15	100	No	No
HAA Total (µg/L) Annual Average - DW1	2018/01/01	5.3	N/A	N/A	N/A
HAA Total (µg/L) Annual Average - DW2	2018/01/01	5.3	N/A	N/A	N/A

**Table 7. List any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards. (Only if DWS category is large municipal residential, small municipal residential, large municipal non-residential, non-municipal year round residential, large non municipal non-residential)**

Refer to Table 4 and Table 5 for any Inorganic or Organic parameter(s) that exceeded half the standard prescribed in Schedule 2 of Ontario Drinking Water Quality Standards.