

ANNUAL REPORT

SHELBURNE WASTEWATER TREATMENT SYSTEM

FOR THE PERIOD:
JANUARY 1, 2020 – DECEMBER 31, 2020

*Prepared for the Town of Shelburne
by the Ontario Clean Water Agency*



A People Place, A Change of Pace
SHELBURNE
ONTARIO, CANADA



ONTARIO CLEAN WATER AGENCY
AGENCE ONTARIENNE DES EAUX

Table of Contents

| | |
|--|----|
| 1. System Description..... | 2 |
| 2. Monitoring Data and Comparison to Effluent Limits | 3 |
| 2.1 Sampling Frequency | 3 |
| 2.2 Effluent Objectives and Effluent Limits | 4 |
| 2.3 Comparison of Data to Effluent Objectives and Effluent Limits..... | 4 |
| 2.4 Additional Monitoring Parameters | 7 |
| 2.5 Overview of Success and Adequacy of the Works; | 8 |
| 3. Operating Problems and Corrective Actions | 8 |
| 4. Major Maintenance Activities | 8 |
| 5. Effluent Quality Assurance and Control | 9 |
| 6. Calibration and Maintenance Procedures..... | 10 |
| 7. Efforts and Results Achieved in Meeting Effluent Objectives..... | 10 |
| 8. Sludge Generation | 11 |
| 9. Complaints..... | 12 |
| 10. By-pass, Spill or Abnormal Discharge Events | 12 |
| 11. Notice of Modifications | 12 |
| 12. Summary of Completed Modifications..... | 12 |
| 13. Additional Information | 12 |

Appendix A: Performance Assessment Report

Appendix B: Sludge Haulage Summary, Sludge Quality Analysis, & Septage Receiving

Appendix C: Calibration Reports

Appendix D: Process Flow Schematic

1. System Description

The Town of Shelburne is a community of approximately 9,265 people located approximately 100 kilometers northwest of Toronto. The community first obtained a waste disposal system in 1968 with the construction of a 5.5 ha lagoon and associated gravity collection and pumping system. The Town grew consistently over the years and eventually overloaded the lagoon system. In July 1981 construction was completed on a wastewater treatment system located at the present location. This expansion consisted of a new trunk sewer, pumping facilities, secondary and tertiary treatment and modifications to the existing lagoons which now provide storm and effluent holding during excess storm flows and plant upsets and maintenance.

The facility consisted of a wet well, a manual screen, grit channels, an oxidation ditch, one secondary clarifier, four effluent sand filters and a chlorine contact chamber. The oxidation ditch used two brush rotors. The facility operated as an extended aeration plant in this configuration from 1981 until December 1999.

A major expansion (Phase 1) took place at the Shelburne WWTP in 1999, changing the configuration of the plant and the method of treating wastewater. The plant went under construction starting in April 1999 with the start-up of the new process in December of 1999. The Shelburne WWTP is still an extended aeration plant. As an extended aeration plant it is designed to remove suspended solids, CBOD₅ and phosphorus from the wastewater. Major improvements were two aeration tanks constructed with fine bubble diffusers. The sludge treatment system consists of a two stage aerobic sludge digestion system with a total storage volume of 580m³, equipped with coarse bubble aeration system and supernatant decanting. The former oxidation ditch was converted to a sludge storage facility with approximately six months storage.

Sludge loading facilities provide for transfer of digested aerobic sludge to trucks. Digested sludge is land-applied as farm fertilizer.

Two ultra-violet radiation banks replaced the sodium hypochlorite disinfection system.

In March 2006 the Ministry of the Environment issued an amended Certificate of Approval # 9046-6GAJUM for the Phase 2 extension and upgrading including;

- Construction of a hauled sewage receiving station;
- Replacement of the raw sewage pumping station - two submersible pumps;
- Replacement of the inlet works;
- Construction of a secondary clarifier ;
- Replacement of the clarifier effluent pump system; and
- Reconfiguration of the stormwater and effluent holding ponds.

In 2017 the Ministry of the Environment and Climate Change issued an amended Environmental Compliance Approval #6413-ABLQQS for upgrading of the filtration and standby power which included;

- Two cloth-filter treatment units with a design capacity of 4,400 m³ each
- One 650 kW standby power diesel generator and 9000L diesel tank with double-walled containment

This facility receives residential, commercial, institutional and industrial wastewater and provides a level of treatment to meet the amended "Environmental Compliance Approval - # 6413-ABLQQS" for discharging into the Beasley Drain a minor tributary of the Boyne River. The Boyne Creek empties into the Nottawasaga River, ultimately meeting Georgian Bay.

A "Process Flow Schematic" is included in Appendix D of this report.

An overview of Shelburne Wastewater Treatment Plant can be found in Table 1:

Table 1. Shelburne Wastewater Treatment Plant Overview

| | |
|--------------------------------|--|
| Facility Name | Shelburne Wastewater Treatment Plant |
| Facility Type | Extended Air STP with Tertiary Treatment |
| Plant Classification | WWT III |
| Works Number | 110000659 |
| Design Capacity | 3,420 m ³ /day |
| Receiving Water | Besley Drain to Boyne Creek to Nottawasaga River |
| Certificate of Approval | 6413-ABLQQS |

2. Monitoring Data and Comparison to Effluent Limits

As per Section 6a of ECA 6413-ABLQQS, a summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Effluent Limits of Condition 7, including an overview of the success and adequacy of the Works is required.

2.1 Sampling Frequency

Hauled sewage, raw sewage, and final effluent are sampled on a regular basis. The sampling types and frequencies are summarized in Tables 2, 3 and Table 4. The sampling frequencies meet the requirements set out in Section 9 of ECA 6413-ABLQQS.

Table 2. Hauled Sewage Monitoring – Sampling Frequencies

| Parameter | Sample Type | Frequency |
|-------------------------|-------------|-----------|
| BOD ₅ | Grab | Monthly |
| Total Suspended Solids | Grab | Monthly |
| Total Phosphorus | Grab | Monthly |
| Total Kjeldahl Nitrogen | Grab | Monthly |

Table 3. Raw Sewage Monitoring – Sampling Frequencies

| Parameter | Sample Type | Frequency |
|--------------------------|-------------|-----------|
| BOD ₅ * | Composite | Monthly |
| Total Suspended Solids* | Composite | Monthly |
| Total Phosphorous* | Composite | Monthly |
| Total Kjeldahl Nitrogen* | Composite | Monthly |

*Refer to Appendix A for monthly sample results.

Table 4. Effluent Sampling Monitoring – Sampling Frequencies

| Parameters | Sample Type | Frequency |
|-------------------------|-------------|-----------|
| CBOD ₅ * | Composite | Weekly |
| Total Suspended Solids* | Composite | Weekly |
| Total Phosphorous* | Composite | Weekly |
| Total Ammonia Nitrogen* | Composite | Weekly |
| E. Coli* | Grab | Weekly |
| pH | Grab/Probe | Weekly |
| Temperature | Grab/Probe | Weekly |

*Refer to Appendix A for monthly sample results.

2.2 Effluent Objectives and Effluent Limits

The effluent objectives as per Section 6 of ECA 6413-ABLQQS for the Shelburne Wastewater Treatment Plant are:

Table 5. Effluent Objectives as per Section 6 of ECA 6413-ABLQQS

| Effluent Parameter | Concentration Objective (mg/L) |
|---|--|
| CBOD ₅ | 4.0 |
| Total Suspended Solids | 4.0 |
| Total Phosphorous | 0.12 |
| Total Ammonia Nitrogen | |
| June 01 to Sept 30 | 0.5 |
| Oct 01 to May 31 | 2.0 |
| E-coli | 150 CFU /100 mL (monthly Geometric Mean Density) |
| pH of the effluent to be maintained between 6.5 to 8.5, inclusive, at all times | |

The effluent limits that are to be met as per Section 7 of ECA 6413-ABLQQS for the Shelburne Wastewater Treatment Plant are found in Table 5. Any exceedance with the limits found in Table 5 constitutes a non-compliance with ECA 6413-ABLQQS.

Table 6. Effluent Limits as per Section 7 of ECA 6413-ABLQQS

| Effluent Parameter | Average Concentration Limit (mg/L) | Average Waste Loading Limit (kg/day) |
|---|--|--------------------------------------|
| CBOD ₅ | 5.0 | 17.1 |
| Total Suspended Solids | 5.0 | 17.1 |
| Total Phosphorous | 0.25 | 0.86 |
| Total Ammonia Nitrogen | | |
| Jun 01 to Sep 30 | 0.8 | 2.7 |
| Oct 01 to May 31 | 2.4 | 8.2 |
| E-coli | 200 CFU /100 mL (monthly Geometric Mean Density) | n/a |
| pH of the effluent to be maintained between 6.0 to 9.5, inclusive, at all times | | |

2.3 Comparison of Data to Effluent Objectives and Effluent Limits

Analytical and monitoring data for the Shelburne Wastewater Treatment Facility is stored in OCWAs data management system (WISKI). Annual and monthly averages for flows, CBOD₅, BOD₅, Suspended Solids, Total Phosphorous, Nitrogen-series and E.coli can be found in Appendix A. A comparison of analytical data from effluent samples to the effluent objectives and effluent limits shown in the below Tables 7-11:

Table 7.

| | CBOD ₅ | | | | | |
|-----------|--------------------------------------|-------------------------------|---------------------------|--------------------------------|---------------------------|----------------------------|
| | Monthly Average Concentration (mg/L) | Within Objectives (4.00 mg/L) | Within Limits (5.00 mg/L) | Monthly Average Loading (kg/d) | Within Objectives (kg/d) | Within Limits (17.10 kg/d) |
| January | 2.50 | Yes | Yes | 6.04 | n/a | Yes |
| February | 3.25 | Yes | Yes | 7.15 | n/a | Yes |
| March | 2.25 | Yes | Yes | 6.25 | n/a | Yes |
| April | 2.00 | Yes | Yes | 5.15 | n/a | Yes |
| May | 2.00 | Yes | Yes | 4.35 | n/a | Yes |
| June | 2.00 | Yes | Yes | 4.11 | n/a | Yes |
| July | 2.25 | Yes | Yes | 4.98 | n/a | Yes |
| August | 2.00 | Yes | Yes | 4.61 | n/a | Yes |
| September | 2.00 | Yes | Yes | 4.15 | n/a | Yes |
| October | 2.00 | Yes | Yes | 4.28 | n/a | Yes |
| November | 2.75 | Yes | Yes | 5.91 | n/a | Yes |
| December | 2.60 | Yes | Yes | 6.32 | n/a | Yes |

Table 8.

| | Total Suspended Solids | | | | | |
|-----------|--------------------------------------|-------------------------------|---------------------------|--------------------------------|---------------------------|----------------------------|
| | Monthly Average Concentration (mg/L) | Within Objectives (4.00 mg/L) | Within Limits (5.00 mg/L) | Monthly Average Loading (kg/d) | Within Objectives (kg/d) | Within Limits (17.10 kg/d) |
| January | 3.50 | Yes | Yes | 8.45 | n/a | Yes |
| February | 5.00 | No | Yes | 11.00 | n/a | Yes |
| March | 3.00 | Yes | Yes | 8.33 | n/a | Yes |
| April | 2.20 | Yes | Yes | 5.66 | n/a | Yes |
| May | 3.00 | Yes | Yes | 6.53 | n/a | Yes |
| June | 2.00 | Yes | Yes | 4.11 | n/a | Yes |
| July | 3.00 | Yes | Yes | 6.64 | n/a | Yes |
| August | 3.00 | Yes | Yes | 6.91 | n/a | Yes |
| September | 2.80 | Yes | Yes | 5.80 | n/a | Yes |
| October | 2.50 | Yes | Yes | 5.35 | n/a | Yes |
| November | 2.50 | Yes | Yes | 5.37 | n/a | Yes |
| December | 2.80 | Yes | Yes | 6.80 | n/a | Yes |

Table 9.

| | Total Phosphorus | | | | | |
|-----------|--------------------------------------|--------------------------------|----------------------------|--------------------------------|---------------------------|----------------------------|
| | Monthly Average Concentration (mg/L) | Within Objectives (0.120 mg/L) | Within Limits (0.250 mg/L) | Monthly Average Loading (kg/d) | Within Objectives (kg/d) | Within Limits (0.860 kg/d) |
| January | 0.085 | Yes | Yes | 0.206 | n/a | Yes |
| February | 0.101 | Yes | Yes | 0.222 | n/a | Yes |
| March | 0.062 | Yes | Yes | 0.173 | n/a | Yes |
| April | 0.030 | Yes | Yes | 0.078 | n/a | Yes |
| May | 0.055 | Yes | Yes | 0.119 | n/a | Yes |
| June | 0.049 | Yes | Yes | 0.100 | n/a | Yes |
| July | 0.051 | Yes | Yes | 0.113 | n/a | Yes |
| August | 0.049 | Yes | Yes | 0.112 | n/a | Yes |
| September | 0.047 | Yes | Yes | 0.097 | n/a | Yes |
| October | 0.037 | Yes | Yes | 0.079 | n/a | Yes |
| November | 0.043 | Yes | Yes | 0.092 | n/a | Yes |
| December | 0.034 | Yes | Yes | 0.084 | n/a | Yes |

Table 10.

| | Total Ammonia Nitrogen (Ammonia Nitrogen + Ammonium Nitrogen) | | | | | | | | | |
|-----------|--|--|---|--|--|--------------------------------|--|--|---|---|
| | Monthly Average Concentration (mg/L) | Within Objectives (Jun 01-Sept 30 0.50 mg/L) | Within Objectives (Oct 01-May 31 2.00 mg/L) | Within Limits (Jun 01-Sept 30 0.80 mg/L) | Within Limits (Oct 01-May 31 2.4 mg/L) | Monthly Average Loading (kg/d) | Within Objectives (Dec 01-Apr 30 kg/d) | Within Objectives (May 01-Nov 30 kg/d) | Within Limits (June 01-Sept 30 2.70 kg/d) | Within Limits (Oct 01-May 31 8.20 kg/d) |
| January | 0.10 | n/a | Yes | n/a | Yes | 0.242 | n/a | n/a | n/a | Yes |
| February | 0.10 | n/a | Yes | n/a | Yes | 0.220 | n/a | n/a | n/a | Yes |
| March | 0.13 | n/a | Yes | n/a | Yes | 0.347 | n/a | n/a | n/a | Yes |
| April | 0.14 | n/a | Yes | n/a | Yes | 0.360 | n/a | n/a | n/a | Yes |
| May | 0.10 | n/a | Yes | n/a | Yes | 0.218 | n/a | n/a | n/a | Yes |
| June | 0.10 | Yes | n/a | Yes | n/a | 0.206 | n/a | n/a | Yes | n/a |
| July | 0.10 | Yes | n/a | Yes | n/a | 0.221 | n/a | n/a | Yes | n/a |
| August | 0.10 | Yes | n/a | Yes | n/a | 0.230 | n/a | n/a | Yes | n/a |
| September | 0.10 | Yes | n/a | Yes | n/a | 0.207 | n/a | n/a | Yes | n/a |
| October | 0.20 | n/a | Yes | n/a | Yes | 0.428 | n/a | n/a | n/a | Yes |
| November | 0.10 | n/a | Yes | n/a | Yes | 0.215 | n/a | n/a | n/a | Yes |
| December | 0.12 | n/a | Yes | n/a | Yes | 0.292 | n/a | n/a | n/a | Yes |

Table 11.

| | E.coli | | |
|-----------|--|-----------------------------------|-------------------------------|
| | Monthly Geometric Mean Density (CFU/100mL) | Within Objectives (100 CFU/100mL) | Within Limits (200 CFU/100mL) |
| January | 2.00 | Yes | Yes |
| February | 2.00 | Yes | Yes |
| March | 1.68 | Yes | Yes |
| April | 1.74 | Yes | Yes |
| May | 2.00 | Yes | Yes |
| June | 1.74 | Yes | Yes |
| July | 1.68 | Yes | Yes |
| August | 2.00 | Yes | Yes |
| September | 2.00 | Yes | Yes |
| October | 2.00 | Yes | Yes |
| November | 2.00 | Yes | Yes |
| December | 1.74 | Yes | Yes |

Table 12. Effluent Monitoring Parameter Summary as required by ECA 6413-ABLQQS for Shelburne Treatment Plant, 2020

| Parameters | Average | Minimum | Maximum | Average Annual Loading |
|------------------------|---------|---------|---------|------------------------|
| CBOD ₅ | 2.30 | 2.00 | 3.25 | 5.27 |
| Total Suspended Solids | 2.94 | 2.20 | 5.00 | 6.75 |
| Total Phosphorus | 0.054 | 0.030 | 0.101 | 0.123 |
| Total Ammonia Nitrogen | 0.115 | 0.10 | 0.20 | 0.265 |
| E.Coli | 1.88 | 1.68 | 2.00 | n/a |
| pH | 8.20 | 8.06 | 8.55 | n/a |
| Temperature | 16.11 | 10.90 | 24.80 | n/a |

2.4 Additional Monitoring Parameters

The following parameters in Table 13 do not have limits or objectives but are monitored on a regular basis (see Section 2.1 for sampling frequency) as required by ECA 6413-ABLQQS. Table 13 summarizes the monitoring data for the reporting period.

Raw Sewage Quality:

Table 13. Raw Sewage Monitoring Parameters as required by ECA 6413-ABLQQS for Shelburne Wastewater Treatment Plant, 2020

| Parameter | Average | Minimum | Maximum |
|---------------------------------|---------|---------|---------|
| BOD ₅ * (mg/L) | 281.08 | 108.00 | 418.00 |
| Total Suspended Solids* (mg/L) | 556.00 | 118.00 | 2150.00 |
| Total Phosphorous* (mg/L) | 5.82 | 3.32 | 9.05 |
| Total Kjeldahl Nitrogen* (mg/L) | 39.88 | 18.90 | 79.40 |

*Refer to Appendix A for monthly sample results.

The following parameters in Table 14 do not have limits or objectives but are monitored as needed when septage is received at the facility. Table 14 summarizes the monitoring data for the reporting period.

Table 14. Hauled Sewage Monitoring

| Parameter | Average | Minimum | Maximum |
|--------------------------------|----------|---------|----------|
| BOD ₅ (mg/L) | 4251.33 | 1210.00 | 6760.00 |
| Total Suspended Solids (mg/L) | 12838.57 | 2450.00 | 23200.00 |
| Total Phosphorous (mg/L) | 78.20 | 26.90 | 130.00 |
| Total Kjeldahl Nitrogen (mg/L) | 399.07 | 114.00 | 848.00 |

2.5 Overview of Success and Adequacy of the Works;

The annual average effluent CBOD₅ concentration was 2.30 mg/L with a removal efficiency of >97.77%. The annual average effluent TSS concentration was 2.94 mg/L with a removal efficiency of >97.63%. The annual average effluent Total Phosphorus concentration was 0.054 mg/L with a removal efficiency of >98.49%.

The bacteriological quality of the effluent complied with the certificate of approval requirement of <200 Colony Forming Units (CFU) per 100 mL sample. The annual geometric mean density for 2020 was 1.88 CFU per 100 mL, indicating adequate effluent disinfection for the majority of the year.

The total raw sewage volume of wastewater treated in 2020 was 1,010,182.80 m³. The annual average daily flow of raw sewage was 2,758.02 m³/day was 80.64 % of the design flow (3,420 m³/day). The maximum peak flow of 3,823.10 m³/day occurred in March due to higher precipitation and snow melt. This represents a peak flow of 1.1 times the rated capacity. The wastewater treatment plant operated within the rated capacity 92% of the time (335 out of 365 days of the year)

3. Operating Problems and Corrective Actions

As per Section 6b of ECA 6413-ABLQQS, *a description of any operating problems encountered and corrective actions taken* is required.

There were no operating problems encountered or corrective actions required at the Shelburne Wastewater Pollution Control Plant during 2020 that affected the quality of the effluent leaving the plant.

All repairs/maintenance can be found in Section 4 of this report.

4. Major Maintenance Activities

As per 6c of ECA 6413-ABLQQS, *a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanisms or thing forming part of the works* is required.

Plant maintenance, including non-scheduled maintenance is monitored using Maximo Workplace Management System. All routine and preventative maintenance was conducted as scheduled in 2020.

For 2020, major maintenance activities that occurred include:

- Foam filter on splitter box gates replaced
- Filter #1 drained and cleaned
- Pump #3 removal and motor repair
- Clarifier sweeper arm repair
- Mechanical bar screen repair

- Blower air filter replacements
- Auger repair, installed new relay
- Heater inspection, maintenance and repairs
- North clarifier inspection/cleaning
- Mixing pump 1 repairs
- Digester decant valve repair
- Filter 1 and 2 drained and cleaned
- Clarifier scrapper arm repair
- RAS pit float replacement
- Grit vortex system repair/maintenance
- Annual Backflow Prevention inspection
- Blower hour meter replacement
- UV Lamp and Sleeve replacements
- Annual Gas Sensor calibrations
- North Clarifier Sweeper Arm repair
- Annual Flow Meter calibrations
- South Clarifier Sweeper Arm repair
- Headworks Wet Well cleanout

5. Effluent Quality Assurance and Control

As per 6d of ECA 6413-ABLQQS, *a summary of any effluent quality assurance or control measures undertaken in the reporting period* is required:

All laboratory analyzed raw sewage and effluent samples (Section 2.1) are analyzed by SGS Canada Inc., which is an ISO 17025 accredited laboratory. In-house tests are conducted for monitoring purposes by licensed operators using standardized methods. The results from in-house tests are used to determine treatment efficiency and to effectively maintain process control. Calibrations and preventative maintenance are performed on facility equipment and monitoring equipment, see Section 4 for more details. In addition to sample analysis, preventative maintenance is scheduled for equipment at the sewage treatment plant and pumping stations at regular frequency (frequency depends on the equipment and type of maintenance). Maintenance activities are scheduled in the work management system Maximo.

Operation by Licensed Operators: This sewage system is operated and maintained by the OCWA's licensed staff. The mandatory licensing program for operators of sewage treatment facilities in Ontario is regulated under the Ontario Water Resources Act (OWRA) Ontario Regulation 129/04. A licensed individual meets the education and experience requirements and has successfully passed the licensing exam.

The following are certified operators who operated this facility during 2020 with current certified classification, certificate numbers and certificate expiry dates.

Table 15.

| Operator | Level | Certificate # | Expiry Date |
|------------------|-------|---------------|--------------|
| Alex Solomonov | WWT 2 | 49144 | Jul 31, 2021 |
| | WWC 2 | 16652 | Jan 31, 2024 |
| Curtis Parker | WWT 4 | 79166 | Mar 31, 2022 |
| | WWC 3 | 79167 | Jul 31, 2021 |
| Emanuel Castro | WWT 1 | 95067 | Oct 31, 2022 |
| | WWC 1 | 102934 | Nov 30, 2021 |
| Monika Kowalska | WWT 1 | 109143 | Dec 31, 2023 |
| | WWC 1 | 109134 | Oct 31, 2023 |
| Juliet Ouellette | OIT | OT61203 | Nov 30, 2022 |
| | | OT61212 | Nov 30, 2022 |
| Jenna Porter | WWT 4 | 61948 | Mar 31, 2023 |
| | WWC 2 | 108856 | Jan 31, 2023 |

6. Calibration and Maintenance Procedures

As per 6e of ECA 6413-ABLQQS, a summary of the calibration and maintenance carried out on all effluent monitoring equipment is required.

All in-house monitoring equipment is calibrated/verified as per manufacturer’s recommendations. Monitoring and metering equipment is also calibrated by a third party on an annual basis. Preventative maintenance is scheduled for all equipment at the sewage treatment plant and pumping stations at regular frequency (frequency depends on the equipment and type of maintenance). Maintenance activities are scheduled within the work management system Maximo, upon completion, Operators set the work order to complete. On a monthly basis, preventative work orders are reviewed for completion.

Indus Controls was contracted to calibrate flow measuring equipment on September 2, 2020. Copies of these calibration reports can be found in Appendix C of this report.

7. Efforts and Results Achieved in Meeting Effluent Objectives

As per 6f of ECA 6413-ABLQQS, a description of efforts made and results achieved in meeting the Effluent Objectives of Condition 6 is required.

Condition 6 is imposed “to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs and before the compliances limits of Condition 7 are exceeded.”

OCWA as the Operating Authority (on behalf of the Owner) has made best efforts to stay within the Effluent Objectives in the ECA. These efforts are supported through:

- Continuous monitoring equipment
- Regular plant inspections/checks
- In-house sampling and testing
- Laboratory (3rd party) analysis of influent and effluent samples
- Data review
- Process optimization and adjustments (as required)
- Scheduled/preventative maintenance

- Repairs as necessary

A summary of the effluent quality in comparison to the effluent objectives can be found in Tables 7-11 of section 2.3 of this report. These results show that sewage treatment operations for 2020 provided effluent quality that was within all effluent objectives outlined in the ECA and minimized environmental impairment.

8. Sludge Generation

As per 6g of ECA 6413-ABLQQS, a tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed is required.

Digested sludge produced at the Shelburne WWTP is land-applied in accordance with the Nutrient Management Act 2002 and Ontario Regulation 267/03.

Grab samples of digested (aerobic) sludge are collected and tested as per these requirements. In 2020, sludge sample analysis was carried out by SGS Lakefield Research Limited. A summary of sludge sample results is provided in Appendix B of this report, along with septage data for the reporting period.

Wessuc Environmental Services Inc. was contracted to haul and spread sludge from the Shelburne plant in 2020. (Certificate of Approval - Waste Management System # 1603-4LGJBN)

The following certified sites were utilized in 2020:

Table 16. Volume of Sludge Generated from Shelburne Wastewater Treatment Plant in 2020

| Site | Site Location | Volume of Biosolids (m ³) | Hauler |
|---------------------------|---------------|---------------------------------------|--------|
| NASM Submission ID: 23166 | D2001 | 2473.00 | Wessuc |
| NASM Submission ID: 24208 | D2007 | 2899.00 | Wessuc |
| NASM Submission ID: 23344 | D2003 | 2983.00 | Wessuc |
| NASM Submission ID: 24382 | W2002 | 571.00 | Wessuc |
| NASM Submission ID: 24433 | W1004 | 134.00 | Wessuc |

A total volume of 9,060.00 m³ of sludge was applied to the above fields from the Shelburne WWTP in 2020.

Based on the design flow, average wastewater quantity and a linear regression with an R² value of 94.27%, the anticipated volume of sludge generated for 2021 will be approximately 9,800 m³.




Figure 1. Shelburne Wastewater Treatment Plant Haulage Volumes (2013 to 2020)

9. Complaints

As per 6h of ECA 6413-ABLQQS, *a summary of any complaints received during the reporting period and any steps taken to address the complaints* is required.

A standard operating procedure (SOP) is in place for addressing complaints received from the community. All complaints are addressed and documented in the facility logbook. Community complaint information is entered in OCWA's electronic database system "WMS Maximo". This system contains all the required information and history of all complaints.

There were no complaint registered in 2020 for the reporting period.

10. By-pass, Spill or Abnormal Discharge Events

As per 6i of ECA 6413-ABLQQS, *a summary of all By-pass, spill or abnormal discharge events* is required.

There were no by-passes, spills, abnormal discharge events, over flows or other situations outside Normal Operating Conditions that occurred during this reporting period with regard to the Shelburne Wastewater Treatment Plant.

11. Notice of Modifications

As per 6j of ECA 6413-ABLQQS, *a copy of all Notice of Modifications submitted to the Water Supervisor as a result of Schedule B, Section 1, with a status report on the implementation of each modification* is required.

There were no modifications at the Shelburne Wastewater Treatment Plant during the reporting period.

12. Summary of Completed Modifications

As per 6k of ECA 6413-ABLQQS, *a report summarizing all modifications completed as a result of Schedule B, Section 3* is required.

There were no modifications at the Shelburne Wastewater Treatment Plant during the reporting period.

13. Additional Information

As per 6l of ECA 6413-ABLQQS, *any other information the Water Supervisor requires from time to time* is required.

There were no requests from the Water Supervisor for any other information during the reporting period.

**2020 Annual Performance Report
Shelburne Wastewater Treatment Plant
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix A

Performance Assessment Report

2020

Ontario Clean Water Agency
Performance Assessment Report Wastewater/Lagoon

Report extracted 02/05/2021 14:44

From: 01/01/2020 to 31/12/2020

Facility: [5773] SHELBURNE WASTEWATER TREATMENT FACILITY

Works: [11000659]

| | 01/2020 | 02/2020 | 03/2020 | 04/2020 | 05/2020 | 06/2020 | 07/2020 | 08/2020 | 09/2020 | 10/2020 | 11/2020 | 12/2020 | <-Total--> | <-Avg--> | <-Max--> | <-Criteria--> |
|---|----------|----------|-----------|----------|----------|----------|----------|----------|----------|----------|----------|----------|------------|----------|----------|-------------------------------------|
| Flows: | | | | | | | | | | | | | | | | |
| Raw Flow: Total - Raw Sewage (m³) | 8846.60 | 74252.10 | 101284.60 | 89360.50 | 84568.80 | 75613.90 | 81055.50 | 87755.30 | 76541.70 | 80886.00 | 78924.70 | 91093.10 | 1010182.80 | | | |
| Raw Flow: Avg - Raw Sewage (m³/d) | 2866.02 | 2560.42 | 3267.25 | 2978.68 | 2728.03 | 2520.46 | 2614.69 | 2830.82 | 2551.39 | 2609.23 | 2630.82 | 2938.49 | | 2758.02 | | 3420.0 |
| Raw Flow: Max - Raw Sewage (m³/d) | 3241.10 | 3019.30 | 3823.10 | 3695.90 | 3132.10 | 2829.60 | 3297.00 | 3480.40 | 2914.20 | 2849.20 | 2904.80 | 3397.70 | | | 3823.10 | |
| Eff. Flow: Total - Final Effluent (m³) | 74870.10 | 63790.10 | 86053.40 | 77216.50 | 67433.80 | 61684.70 | 68646.00 | 71422.70 | 62176.50 | 66306.90 | 64459.10 | 75328.50 | 839388.30 | | | |
| Eff. Flow: Avg - Final Effluent (m³/d) | 2415.16 | 2199.66 | 2775.92 | 2573.88 | 2175.28 | 2056.16 | 2214.39 | 2303.96 | 2072.55 | 2138.93 | 2148.64 | 2429.95 | | 2292.04 | | |
| Eff. Flow: Max - Final Effluent (m³/d) | 2910.90 | 2584.60 | 3455.90 | 3336.50 | 2807.30 | 2420.50 | 2846.20 | 2907.90 | 2412.90 | 2402.70 | 2429.80 | 2848.10 | | | 3455.90 | |
| Carbonaceous Biochemical Oxygen Demand: CBOD: | | | | | | | | | | | | | | | | |
| Raw: Avg cBOD5 - Raw Sewage (mg/L) | 374.000 | 269.000 | 101.000 | 150.000 | 325.000 | 339.000 | 241.000 | 276.000 | 323.000 | 285.000 | 338.000 | 119.000 | | 261.667 | 374.000 | |
| Raw: # of samples of cBOD5 - Raw Sewage (mg/L) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 12 | | | |
| Eff: Avg cBOD5 - Final Effluent (mg/L) | < 2.500 | < 3.250 | < 2.250 | < 2.000 | < 2.000 | < 2.000 | < 2.250 | < 2.000 | < 2.000 | < 2.000 | < 2.750 | < 2.600 | | < 2.300 | < 3.250 | 5.0 |
| Eff: # of samples of cBOD5 - Final Effluent (mg/L) | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 | 5 | 52 | | | |
| Loading: cBOD5 - Final Effluent (kg/d) | < 6.038 | < 7.149 | < 6.246 | < 5.148 | < 4.351 | < 4.112 | < 4.982 | < 4.608 | < 4.145 | < 4.278 | < 5.909 | < 6.318 | | < 5.274 | < 7.149 | |
| Percent Removal: cBOD5 - Final Effluent (mg/L) | 99.332 | 98.792 | 97.772 | 98.667 | 99.385 | 99.410 | 99.066 | 99.275 | 99.381 | 99.298 | 99.186 | 97.815 | | | 99.410 | |
| Biochemical Oxygen Demand: BOD5: | | | | | | | | | | | | | | | | |
| Raw: Avg BOD5 - Raw Sewage (mg/L) | 319.000 | 349.000 | 108.000 | 147.000 | 418.000 | 347.000 | 289.000 | 223.000 | 293.000 | 382.000 | 332.000 | 166.000 | | 281.083 | 418.000 | |
| Raw: # of samples of BOD5 - Raw Sewage (mg/L) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 12 | | | |
| Eff: Avg BOD5 - Final Effluent (mg/L) | < 2.000 | 3.000 | 2.000 | < 2.000 | < 2.000 | < 2.000 | < 2.000 | < 2.000 | < 2.000 | 3.000 | < 2.000 | < 2.000 | | < 2.167 | 3.000 | |
| Loading: BOD5 - Final Effluent (kg/d) | < 4.830 | 6.599 | 5.552 | < 5.148 | < 4.351 | < 4.112 | < 4.429 | < 4.608 | < 4.145 | 6.417 | < 4.297 | < 4.860 | | < 4.946 | 6.599 | |
| Percent Removal: BOD5 - Final Effluent (mg/L) | 99.373 | 99.140 | 98.148 | 98.639 | 99.522 | 99.424 | 99.308 | 99.103 | 99.317 | 99.215 | 99.398 | 98.795 | | | 99.522 | |
| Total Suspended Solids: TSS: | | | | | | | | | | | | | | | | |
| Raw: Avg TSS - Raw Sewage (mg/L) | 304.000 | 459.000 | 140.000 | 140.000 | 452.000 | 587.000 | 777.000 | 430.000 | 504.000 | 2150.000 | 611.000 | 118.000 | | 556.000 | 2150.000 | |
| Raw: # of samples of TSS - Raw Sewage (mg/L) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 12 | | | |
| Eff: Avg TSS - Final Effluent (mg/L) | 3.500 | 5.000 | 3.000 | < 2.200 | 3.000 | < 2.000 | 3.000 | < 3.000 | < 2.800 | < 2.500 | < 2.500 | 2.800 | | < 2.942 | 5.000 | 5.0 |
| Eff: # of samples of TSS - Final Effluent (mg/L) | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 | 5 | 52 | | | |
| Loading: TSS - Final Effluent (kg/d) | 8.453 | 10.998 | 8.328 | < 5.663 | 6.526 | < 4.112 | 6.643 | < 6.912 | < 5.803 | < 5.347 | < 5.372 | 6.804 | | < 6.747 | 10.998 | |
| Percent Removal: TSS - Final Effluent (mg/L) | 98.849 | 98.911 | 97.857 | 98.429 | 99.336 | 99.659 | 99.614 | 99.302 | 99.444 | 99.884 | 99.591 | 97.627 | | | 99.884 | |
| Total Phosphorus: TP: | | | | | | | | | | | | | | | | |
| Raw: Avg TP - Raw Sewage (mg/L) | 8.410 | 9.050 | 4.110 | 3.380 | 7.730 | 4.920 | 5.250 | 3.580 | 5.470 | 8.580 | 6.020 | 3.320 | | 5.818 | 9.050 | |
| Raw: # of samples of TP - Raw Sewage (mg/L) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 12 | | | |
| Eff: Avg TP - Final Effluent (mg/L) | 0.085 | 0.101 | 0.062 | 0.030 | 0.055 | 0.049 | 0.051 | 0.049 | 0.047 | 0.037 | 0.043 | < 0.034 | | < 0.054 | 0.101 | 0.25 |
| Eff: # of samples of TP - Final Effluent (mg/L) | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 | 5 | 52 | | | |
| Loading: TP - Final Effluent (kg/d) | 0.206 | 0.222 | 0.173 | 0.078 | 0.119 | 0.100 | 0.113 | 0.112 | 0.097 | 0.079 | 0.092 | < 0.084 | | < 0.123 | 0.222 | |
| Percent Removal: TP - Final Effluent (mg/L) | 98.986 | 98.884 | 98.485 | 99.107 | 99.292 | 99.008 | 99.029 | 98.638 | 99.141 | 99.572 | 99.286 | 98.964 | | | 99.572 | |
| Nitrogen Series: | | | | | | | | | | | | | | | | |
| Raw: Avg TKN - Raw Sewage (mg/L) | 79.400 | 37.600 | 32.400 | 27.000 | 57.800 | 34.400 | 51.400 | 18.900 | 38.800 | 36.800 | 39.600 | 24.500 | | 39.883 | 79.400 | |
| Raw: # of samples of TKN - Raw Sewage (mg/L) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 12 | | | |
| Eff: Avg TAN - Final Effluent (mg/L) | < 0.100 | < 0.100 | < 0.125 | < 0.140 | < 0.100 | < 0.100 | < 0.100 | < 0.100 | < 0.100 | < 0.200 | < 0.100 | < 0.120 | | < 0.115 | < 0.200 | - 2.4 - 0.8 - 0.8 - 0.8 - 0.8 - 2.4 |
| Eff: # of samples of TAN - Final Effluent (mg/L) | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 | 5 | 52 | | | |
| Loading: TAN - Final Effluent (kg/d) | < 0.242 | < 0.220 | < 0.347 | < 0.360 | < 0.216 | < 0.206 | < 0.221 | < 0.230 | < 0.207 | < 0.428 | < 0.215 | < 0.292 | | < 0.265 | < 0.428 | |
| Eff: Avg NO3-N - Final Effluent (mg/L) | 18.900 | 12.785 | 15.075 | 13.536 | 20.975 | 21.980 | 16.748 | 12.070 | 15.760 | 14.238 | 17.160 | 12.368 | | 15.966 | 21.980 | |
| Eff: # of samples of NO3-N - Final Effluent (mg/L) | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 | 5 | 52 | | | |
| Eff: Avg NO2-N - Final Effluent (mg/L) | < 0.030 | 0.080 | < 0.035 | < 0.044 | < 0.030 | < 0.036 | < 0.030 | < 0.030 | < 0.030 | < 0.053 | < 0.042 | < 0.042 | | < 0.039 | 0.080 | |
| Eff: # of samples of NO2-N - Final Effluent (mg/L) | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 | 5 | 52 | | | |
| Disinfection: | | | | | | | | | | | | | | | | |
| Eff: GMD E. Coli - Final Effluent (cfu/100mL) | 2.000 | 2.000 | 1.682 | 1.741 | 2.000 | 1.741 | 1.682 | 2.000 | 2.000 | 2.000 | 2.000 | 1.741 | | 1.882 | 2.000 | 200.0 |
| Eff: # of samples of E. Coli - Final Effluent (cfu/100mL) | 4 | 4 | 4 | 5 | 4 | 5 | 4 | 4 | 5 | 4 | 4 | 5 | 52 | | | |

**2020 Annual Performance Report
Shelburne Wastewater Treatment Plant
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix B

Sludge Haulage Summary, Sludge Quality, and
Septage Receiving

2020

| Shelburne WWTP - Daily Haulage Summary | | | |
|--|-------|--------|---------------------------------|
| Date | Site | NASM # | Sludge Hauled (m ³) |
| May | | | |
| 13-May-20 | D2007 | 24208 | 1044.00 |
| 14-May-20 | D2007 | 24208 | 1247.00 |
| 21-May-20 | D2007 | 24208 | 608.00 |
| June | | | |
| 29-Jun-20 | D2003 | 23344 | 848.00 |
| 30-Jun-20 | D2003 | 23344 | 944.00 |
| July | | | |
| 2-Jul-20 | D2003 | 23344 | 1191.00 |
| August | | | |
| 31-Aug-20 | W2002 | 24382 | 89.00 |
| September | | | |
| 1-Sep-20 | W2002 | 24382 | 482.00 |
| 4-Sep-20 | D2001 | 23166 | 919.00 |
| 11-Sep-20 | D2001 | 23166 | 1052.00 |
| 15-Sep-20 | D2001 | 23166 | 502.00 |
| October | | | |
| 15-Oct-20 | W1004 | 24433 | 134.00 |
| Total | | | 9060.00 |

**SHELBURNE WASTEWATER TREATMENT PLANT
SLUDGE QUALITY DATA**

2020

Nutrients

| | | JAN | FEB | MAR | APR | MAY | JUN | JUL | AUG | SEP | OCT | NOV | DEC | AVERAGE |
|-------------------|--------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|-------|---------|
| TS | (mg/L) | 20600 | 20900 | 34800 | 34400 | 29300 | 27200 | 38000 | 27700 | 21500 | 30900 | 23000 | 23600 | 27658 |
| Ammonia+Ammonium | (mg/L) | 155.0 | 182.0 | 180.0 | 217.0 | 262.0 | 297.0 | 143.0 | 399.0 | 378.0 | 86.1 | 187.0 | 220.0 | 225.5 |
| Nitrate | (mg/L) | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 | 0.30 |
| Ammonia + Nitrate | (mg/L) | 155.3 | 182.3 | 180.3 | 217.3 | 262.3 | 297.3 | 143.3 | 399.3 | 378.3 | 86.4 | 187.3 | 220.3 | 225.8 |
| TKN | (mg/L) | 1240 | 1090 | 1990 | 1880 | 1890 | 1640 | 1970 | 1580 | 1350 | 1330 | 1190 | 1190 | 1528 |
| Phosphorus | (mg/L) | 350 | 350 | 670 | 680 | 570 | 410 | 660 | 440 | 360 | 270 | 310 | 340 | 451 |

Metal Concentrations

| | | | | | | | | | | | | | | |
|------------|--------|-------|-------|-------|-------|--------|--------|-------|-------|--------|-------|-------|-------|-------|
| Arsenic | (mg/L) | 0.30 | 0.30 | 0.50 | 0.50 | 0.50 | 0.30 | 0.50 | 0.30 | 0.20 | 0.20 | 0.30 | 0.20 | 0.34 |
| Cadmium | (mg/L) | 0.012 | 0.011 | 0.024 | 0.022 | 0.020 | 0.016 | 0.032 | 0.021 | 0.017 | 0.013 | 0.017 | 0.014 | 0.02 |
| Cobalt | (mg/L) | 0.06 | 0.06 | 0.11 | 0.11 | 0.100 | 0.07 | 0.12 | 0.10 | 0.08 | 0.07 | 0.09 | 0.09 | 0.09 |
| Chromium | (mg/L) | 0.67 | 0.67 | 1.30 | 1.30 | 1.10 | 0.81 | 1.60 | 1.20 | 0.87 | 0.82 | 0.89 | 0.98 | 1.02 |
| Copper | (mg/L) | 5.40 | 5.90 | 11.00 | 9.90 | 9.30 | 5.70 | 11.00 | 8.30 | 5.70 | 4.80 | 5.70 | 5.50 | 7.35 |
| Mercury | (mg/L) | 0.011 | 0.013 | 0.018 | 0.023 | 0.0160 | 0.0110 | 0.018 | 0.022 | 0.0110 | 0.006 | 0.010 | 0.011 | 0.014 |
| Potassium | (mg/L) | 62 | 60.0 | 83.0 | 78.0 | 270.0 | 60.0 | 75.0 | 55.0 | 56.0 | 86.0 | 56.0 | 61.0 | 84 |
| Molybdenum | (mg/L) | 0.19 | 0.19 | 0.38 | 0.32 | 0.34 | 0.21 | 0.35 | 0.27 | 0.20 | 0.17 | 0.22 | 0.23 | 0.26 |
| Nickel | (mg/L) | 0.38 | 0.39 | 0.68 | 0.68 | 0.61 | 0.42 | 0.84 | 0.58 | 0.44 | 0.41 | 0.46 | 0.48 | 0.53 |
| Lead | (mg/L) | 0.40 | 0.30 | 0.60 | 0.50 | 0.60 | 0.40 | 0.70 | 0.60 | 0.50 | 0.50 | 0.60 | 0.70 | 0.53 |
| Selenium | (mg/L) | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 | 0.10 |
| Zinc | (mg/L) | 8.00 | 8.00 | 13.00 | 13.00 | 12.00 | 7.00 | 18.00 | 13.00 | 9.00 | 7.00 | 9.00 | 9.00 | 10.50 |

Bacti

| | | | | | | | | | | | | | |
|----------------------------|---------|---------|---------|---------|---------|---------|-----------|---------|---------|---------|---------|---------|---------|
| E. coli (cfu/1g dried wgt) | 169,903 | 148,325 | 97,701 | 72,674 | 102,389 | 106,618 | 789,474 | 39,711 | 65,116 | 87,379 | 91,304 | 72,034 | 153,552 |
| E. coli (cfu/100mL) | 350,000 | 310,000 | 340,000 | 250,000 | 300,000 | 290,000 | 3,000,000 | 110,000 | 140,000 | 270,000 | 210,000 | 170,000 | 478,333 |

Metal/Solids Concentration

| | | | | | | | | | | | | | | |
|-----------------|---------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| Arsenic [170] | (mg/kg) | 15 | 14 | 14 | 15 | 17 | 11 | 13 | 11 | 9 | 6 | 13 | 8 | 12 |
| Cadmium [34] | (mg/kg) | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 0 | 1 | 1 | 1 |
| Cobalt [340] | (mg/kg) | 3 | 3 | 3 | 3 | 3 | 3 | 3 | 4 | 4 | 2 | 4 | 4 | 3 |
| Chromium [2800] | (mg/kg) | 33 | 32 | 37 | 38 | 38 | 30 | 42 | 43 | 40 | 27 | 39 | 42 | 37 |
| Copper [1700] | (mg/kg) | 262 | 282 | 316 | 288 | 317 | 210 | 289 | 300 | 265 | 155 | 248 | 233 | 264 |
| Mercury [11] | (mg/kg) | 1 | 1 | 1 | 1 | 1 | 0 | 0 | 1 | 1 | 0 | 0 | 0 | 1 |
| Molybdenum [94] | (mg/kg) | 9 | 9 | 11 | 9 | 12 | 8 | 9 | 10 | 9 | 6 | 10 | 10 | 9 |
| Nickel [420] | (mg/kg) | 18 | 19 | 20 | 20 | 21 | 15 | 22 | 21 | 20 | 13 | 20 | 20 | 19 |
| Lead [1100] | (mg/kg) | 19 | 14 | 17 | 15 | 20 | 15 | 18 | 22 | 23 | 16 | 26 | 30 | 20 |
| Selenium [34] | (mg/kg) | 5 | 5 | 3 | 3 | 3 | 4 | 3 | 4 | 5 | 3 | 4 | 4 | 4 |
| Zinc [4200] | (mg/kg) | 388 | 383 | 374 | 378 | 410 | 257 | 474 | 469 | 419 | 227 | 391 | 381 | 379 |

Ontario Clean Water Agency
Time Series Info Report

Report extracted 02/05/2021 14:49

From: 01/01/2020 to 31/12/2020

Facility Org Number: 5773
 Facility Works Number: 110000659
 Facility Name: SHELBURNE WASTEWATER TREATMENT FACILITY
 Facility Owner: Corporation/Company: The Corporation of the Town of Shelburne
 Facility Classification: Class 3 Wastewater Treatment
 Receiver: Besley Drain to Boyne Creek
 Service Population: 7900.0
 Total Design Capacity: 3420.0 m3/day

| | 01/2020 | 02/2020 | 03/2020 | 04/2020 | 05/2020 | 06/2020 | 07/2020 | 08/2020 | 09/2020 | 10/2020 | 11/2020 | 12/2020 | Total | Avg | Max | Min |
|---|---------|---------|---------|---------|----------|---------|---------|---------|---------|---------|---------|---------|--------|----------|-------|-------|
| Septage / Biochemical Oxygen Demand: BOD5 - mg/L | | | | | | | | | | | | | | | | |
| Count Lab | 0 | 0 | 2 | 2 | 4 | 2 | 0 | 0 | 2 | 1 | 1 | 1 | 15 | | | |
| Max Lab | | | 5920 | 5120 | 6760 | 4930 | | | 6180 | 3200 | 1210 | 2010 | | | 6760 | |
| Mean Lab | | | 4210 | 4995 | 5012.5 | 4380 | | | 5065 | 3200 | 1210 | 2010 | | 4251.333 | | |
| Min Lab | | | 2500 | 4870 | 2840 | 3830 | | | 3950 | 3200 | 1210 | 2010 | | | | 1210 |
| Septage / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L | | | | | | | | | | | | | | | | |
| Count Lab | 0 | 0 | 2 | 2 | 4 | 2 | 0 | 0 | 2 | 1 | 1 | 1 | 15 | | | |
| Max Lab | | | 6110 | 5800 | 4680 | 4430 | | | 5560 | 2170 | 1300 | 1510 | | | 6110 | |
| Mean Lab | | | 4160 | 5650 | 3382.5 | 4340 | | | 4790 | 2170 | 1300 | 1510 | | 3759.333 | | |
| Min Lab | | | 2210 | 5500 | 2340 | 4250 | | | 4020 | 2170 | 1300 | 1510 | | | | 1300 |
| Septage / Septage Received - m³ | | | | | | | | | | | | | | | | |
| Count IH | 0 | 0 | 2 | 3 | 4 | 2 | 0 | 0 | 2 | 1 | 1 | 1 | 16 | | | |
| Total IH | | | 12.683 | 19.54 | 22.728 | 9.092 | | | 9.092 | 4.546 | 4.546 | 4.546 | 86.773 | | | |
| Max IH | | | 6.819 | 7.27 | 9.09 | 4.546 | | | 4.546 | 4.546 | 4.546 | 4.546 | | | 9.09 | |
| Mean IH | | | 6.342 | 6.513 | 5.682 | 4.546 | | | 4.546 | 4.546 | 4.546 | 4.546 | | 5.423 | | |
| Min IH | | | 5.864 | 5.45 | 4.546 | 4.546 | | | 4.546 | 4.546 | 4.546 | 4.546 | | | | 4.546 |
| Septage / Total Kjeldahl Nitrogen: TKN - mg/L | | | | | | | | | | | | | | | | |
| Count Lab | 0 | 0 | 2 | 2 | 4 | 2 | 0 | 0 | 2 | 1 | 1 | 1 | 15 | | | |
| Max Lab | | | 422 | 352 | 514 | 490 | | | 573 | 848 | 352 | 114 | | | 848 | |
| Mean Lab | | | 271 | 337 | 413.25 | 394 | | | 507.5 | 848 | 352 | 114 | | 399.067 | | |
| Min Lab | | | 120 | 322 | 301 | 298 | | | 442 | 848 | 352 | 114 | | | | 114 |
| Septage / Total Phosphorus: TP - mg/L | | | | | | | | | | | | | | | | |
| Count Lab | 0 | 0 | 2 | 2 | 4 | 2 | 0 | 0 | 2 | 1 | 1 | 1 | 15 | | | |
| Max Lab | | | 82 | 93 | 105 | 101 | | | 130 | 112 | 71.5 | 54 | | | 130 | |
| Mean Lab | | | 54.45 | 68.8 | 74.65 | 92.6 | | | 102.6 | 112 | 71.5 | 54 | | 78.2 | | |
| Min Lab | | | 26.9 | 44.6 | 49 | 84.2 | | | 75.2 | 112 | 71.5 | 54 | | | | 26.9 |
| Septage / Total Suspended Solids: TSS - mg/L | | | | | | | | | | | | | | | | |
| Count Lab | 0 | 0 | 2 | 2 | 3 | 2 | 0 | 0 | 2 | 1 | 1 | 1 | 14 | | | |
| Max Lab | | | 12200 | 15400 | 20000 | 23200 | | | 13100 | 16700 | 8530 | 8160 | | | 23200 | |
| Mean Lab | | | 7325 | 13750 | 14266.67 | 19050 | | | 11650 | 16700 | 8530 | 8160 | | 12838.57 | | |
| Min Lab | | | 2450 | 12100 | 10800 | 14900 | | | 10200 | 16700 | 8530 | 8160 | | | | 2450 |

**2020 Annual Performance Report
Shelburne Wastewater Treatment Plant
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix C

Calibration Reports

2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT PRESSURE MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information
Make: Magnehelic
Model: 2000 Series
Order No: NA
Serial No: NA
Tag: NA
Job Location: To digester
Asset ID: 0000062546

Service Information
Date: September 2nd,2020
Report No: CO1150-2009-51
Job No: CO1150-2009

| Inst. Reading | AS FOUND | AS LEFT |
|---------------|----------|---------|
| Pressure(psi) | 0 | 0 |

Details
Unit: psi
Range: 0-15
Current Output: NA
4 mA Set Point: 0
20 mA Set Point: 15


| Maintenance Checklist | | | Remarks |
|---------------------------|--|---------------------------------|---------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |

| Instrument Test Information and Results | | | | | |
|---|---------------------------|------------------------|------------------------|---------------------|-----------------|
| Input (%) | Calculated Pressure (psi) | Calculated Flow(l/sec) | Measure Pressure (psi) | Display flow(l/sec) | Deviation (psi) |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 100.00 | 15.00 | 1,000.00 | 14.80 | 1000.00 | 0.20 |

| Information of Tools used for Verification of the Instruments | | | |
|---|------------|------------------------|------------|
| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 2 |
| Device Description: | | Digital Pressure Gauge | |
| Manufacturer: | | Martel Electronics | |
| Model No: | | BG-PI-PRO-500G | |

Overall Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel Stamp/Signature 
Printed Date: September 2nd,2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT PRESSURE MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information
Make: Magnehelic
Model: 2000 Series
Order No: NA
Serial No: NA
Tag: NA
Job Location: Aeration flow
Asset ID: 0000062546

Service Information
Date: September 2nd, 2020
Report No: CO1150-2009-52
Job No: CO1150-2009

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| Pressure (psi) | 0 | 0 |

Details
Unit: psi
Range: 0-15
Current Output: NA
4 mA Set Point: 0
20 mA Set Point: 15


| Maintenance Checklist | | | Remarks |
|---------------------------|--|---------------------------------|---------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |

| Instrument Test Information and Results | | | | | |
|---|---------------------------|-------------------------|------------------------|----------------------|-----------------|
| Input (%) | Calculated Pressure (psi) | Calculated Flow (l/sec) | Measure Pressure (psi) | Display flow (l/sec) | Deviation (psi) |
| 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 |
| 100.00 | 15.00 | 1,000.00 | 14.80 | 1000.00 | 0.20 |

| Information of Tools used for Verification of the Instruments | | | |
|---|------------|------------------------|------------|
| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 2 |
| Device Description: | | Digital Pressure Gauge | |
| Manufacturer: | | Martel Electronics | |
| Model No: | | BG-PI-PRO-500G | |

Overall Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel Stamp/Signature 
Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: Khrono
Model: IFC 010D
Order Code: NA
Serial No.: A9915693
Tag: FIT01
Job Location: WAS Flow
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-53
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-27.8
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 27.8

Sensor Details

Line size: 3"
GKL: 5.167
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| TOTALIZER (m3) | 531608 | 531609 |
| FLOW (l/sec) | 0 | 0 |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

Instrument Test Information and Results

| Set-Point as Per Calibration KIT | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
|----------------------------------|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| 0 | 0.00 | 4.00 | 0.00 | 3.99 | 0.00 |
| A | 1.98 | 5.14 | 1.92 | 5.12 | 0.06 |
| B | 3.96 | 6.28 | 3.92 | 6.25 | 0.04 |
| C | 7.92 | 8.56 | 7.69 | 8.51 | 0.23 |
| D | 19.79 | 15.39 | 19.56 | 15.23 | 0.23 |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|------------|-----------------------|------------|
| Device Description: | Calibrator | Electrical Multimeter | N/A |
| Manufacturer: | Khrono | Fluke | N/A |
| Model No: | GS8B | 179 | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature

Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: Khrono
Model: IFC 010D
Order Code: NA
Serial No.: A9915978
Tag: FIT02
Job Location: Tank 1 RAS Flow
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-54
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-66.7
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 66.7

Sensor Details

Line size: 4"
GKL: 5.243
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| TOTALIZER (m3) | 8614487 | 8614490 |
| FLOW (l/sec) | 17.75 | 17.56 |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

Instrument Test Information and Results

| Set-Point as Per Calibration KIT | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
|----------------------------------|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| 0 | 0.00 | 4.00 | 0.23 | 3.99 | -0.23 |
| A | 3.14 | 4.75 | 3.11 | 4.56 | 0.03 |
| B | 6.28 | 5.51 | 6.25 | 5.26 | 0.03 |
| C | 12.55 | 7.01 | 15.25 | 6.98 | -2.70 |
| D | 31.38 | 11.53 | 31.35 | 11.53 | 0.03 |
| E | 62.76 | 19.05 | 61.89 | 19.04 | 0.87 |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|------------|-----------------------|------------|
| Device Description: | Calibrator | Electrical Multimeter | N/A |
| Manufacturer: | Khrono | Fluke | N/A |
| Model No: | GS8B | 179 | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature



Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: Khrono
Model: IFC 010D
Order Code: NA
Serial No.: A9915977
Tag: FIT03
Job Location: Tank 2 RAS Flow
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-55
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-66.7
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 66.7

Sensor Details

Line size: 4"
GKL: 5.318
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| TOTALIZER (m3) | 9023137 | 9023141 |
| FLOW (l/sec) | 17.75 | 17.56 |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

Instrument Test Information and Results

| Set-Point as Per Calibration KIT | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
|----------------------------------|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| 0 | 0.00 | 4.00 | 0.32 | 3.99 | -0.32 |
| A | 3.18 | 4.76 | 3.11 | 4.52 | 0.07 |
| B | 6.37 | 5.53 | 6.32 | 5.45 | 0.05 |
| C | 12.73 | 7.05 | 12.85 | 6.95 | -0.12 |
| D | 31.83 | 11.63 | 31.78 | 11.52 | 0.05 |
| E | 63.65 | 19.27 | 63.58 | 19.02 | 0.07 |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|------------|-----------------------|------------|
| Device Description: | Calibrator | Electrical Multimeter | N/A |
| Manufacturer: | Khrono | Fluke | N/A |
| Model No: | GS8B | 179 | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature



Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: Khrone
Model: IFC 010D
Order Code: NA
Serial No.: A9915979
Tag: FIT04
Job Location: Truck Fill Flow
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-56
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-75
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 75

Sensor Details

Line size: 4"
GKL: 5.045
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| TOTALIZER (m3) | 64510 | 64511 |
| FLOW (l/sec) | 0 | 0 |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

Instrument Test Information and Results

| Set-Point as Per Calibration KIT | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
|----------------------------------|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| 0 | 0.00 | 4.00 | 0.03 | 3.99 | -0.03 |
| A | 3.02 | 4.64 | 3.25 | 4.65 | -0.23 |
| B | 6.04 | 5.29 | 6.12 | 5.27 | -0.08 |
| C | 12.08 | 6.58 | 12.01 | 6.52 | 0.07 |
| D | 30.19 | 10.44 | 29.96 | 10.41 | 0.23 |
| E | 60.39 | 16.88 | 60.25 | 16.69 | 0.14 |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|------------|-----------------------|------------|
| Device Description: | Calibrator | Electrical Multimeter | N/A |
| Manufacturer: | Khrone | Fluke | N/A |
| Model No: | GS8B | 179 | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature



Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - OCM III
OPEN CHANNEL FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information
Make: Milltronics
Model: OCM III
Tag: FIT05
Job Location: Effluent Flow

Service Information
Date: September 2nd,2020
Report No: CO1150-2009-57
Job No: CO1150-2009

Flow Details
Unit: l/sec
Flow Range: 0-105
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 105

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|----------|
| TOTALIZER (m3) | 17074454 | 17074463 |
| FLOW (l/sec) | 40 | 56 |

| Maintenance Checklist | | | Remarks |
|------------------------|--|---------------------------------|---------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |

| Programming Parameter of Instrument | | | | | |
|-------------------------------------|--------------------------|-----------|-----------|----------------------|------------|
| Parameter | Discription | Value | Parameter | Discription | Value |
| F0 | Access Code | 2.71828 | P7 | Height of Max. Head | 34.48 |
| P1 | Dimension Unit (cm) | 0 | P32 | Totalizer Multiplier | 6*1000 |
| P3 | Exponential Device | 0 | P42 | Head by OCM III | 0 |
| P4 | Cal. Method -Ratiometric | 1 | P45 | Low Flow Cut-off | 0 |
| P5 | Flow Unit - l/sec | 0 | P46 | Range at Zero Head | 85.6672 cm |
| P6 | Max Flow rate | 105 l/sec | P47 | Blanking Distance | 30.4864 cm |

| Test Point Report | | | | | | |
|-------------------------|------------------------|-------------------------|--------------------------|-----------------|---------------|-----------------------------|
| Reference Distance (cm) | Measured Distance (cm) | Calculated Flow (l/sec) | UUT Flow Display (l/sec) | Calculated (mA) | Measured (mA) | Devaiton Full Scale (l/sec) |
| 17.00 | 17.52 | 37.26 | 37.26 | 9.60 | 9.67 | 0.00 |

Calculations

Flow Calculations
 $Q = q_{cal} (h/h_{cal})^{Exp}$ Where, Q= Discharge Flow, qcal = max flow, h = head, hcal = max head
 Exp = 1.53 , Hence,
 $Q = 105 (17.52/34.48)^{1.53}$
 $Q = 5631.47$

| Instrument Test Information and Results | | | | | |
|---|------------------------|-----------------------|---------------------|--------------------------|-------------------|
| Input (%) | Calculated Flow(l/sec) | Calculated Input (mA) | Flow on UUT (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
| 0 | 0.00 | 4.00 | 0.02 | 3.99 | -0.02 |
| 25 | 26.25 | 8.00 | 26.25 | 7.99 | 0.00 |
| 50 | 52.50 | 12.00 | 52.00 | 11.99 | 0.50 |
| 75 | 78.75 | 16.00 | 78.00 | 15.99 | 0.75 |
| 100 | 105.00 | 20.00 | 104.50 | 19.99 | 0.50 |

| Information of Tools used for Verification of the Instruments | | | |
|---|--------------|-------|--|
| Device Description: | Manufacturer | Model | |
| Electrical Multimeter | Fluke | 179 | |

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Program parameters verified. Single point verification done

Service Technician : Sagar Patel
Printed Date: September 2nd,2020

Stamp/Signature



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - ROSEMOUNT ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: Rosemount
Model: 8712
Order Code: NA
Serial No.: 860188157
Tag: FIT06
Job Location: Raw sewage flow
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-58
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-150
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 150

Sensor Details

Line size: 8"
Flow Cal Tube No.: 1025505911000010
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|-----------|-----------|
| TOTALIZER (m3) | 887116288 | 887116291 |
| FLOW (L/SEC) | 0 | |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

| |
|--|
| |
| |
| |
| |

Instrument Test Information and Results

| Test-Point as Per Calibration KIT | Calculated Flow (FPS) | Calculated O/P (mA) | UUT Display (FPS) | UUT Measured Output (mA) | Deviation (FPS) |
|-----------------------------------|-----------------------|---------------------|-------------------|--------------------------|-----------------|
| 0.00 | 0.00 | 4.00 | 0.00 | 3.99 | 0.00 |
| 3.00 | 3.00 | 5.60 | 3.00 | 5.59 | 0.00 |
| 10.00 | 10.00 | 9.33 | 10.00 | 9.32 | 0.00 |
| 30.00 | 30.00 | 20.00 | 30.00 | 20.00 | 0.00 |
| | | | | | |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|------------|-----------------------|------------|
| Device Description: | Calibrator | Electrical Multimeter | N/A |
| Manufacturer: | Rosemount | Fluke | N/A |
| Model No: | 8714D | 179 | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature

Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information
Make: Khrone
Model: IFC 100W
Order Code: NA
Serial No.: C16501184
Tag: FIT014(UPPER)
Job Location: upper filter
Asset ID: NA

Service Information
Date: September 2nd, 2020
Report No: CO1150-2009-59
Job No: CO1150-2009

Sensor Details
Line size: 10"
GKL: 8.6872
Mounting: Remote

Flow Details
Unit: l/sec
Flow Range: 0-200
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 200

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|------------|------------|
| TOTALIZER (m3) | 2037378.46 | 2037380.12 |
| FLOW (l/sec) | 0 | 0 |

| Maintenance Checklist | | | Remarks |
|---------------------------|--|---------------------------------|---------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |

| Instrument Test Information and Results | | | | | |
|---|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| Set-Point as Per Calibration KIT | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
| 0 | 0.00 | 4.00 | 0.00 | 3.99 | 0.00 |
| A | 32.49 | 6.60 | 32.56 | 6.59 | -0.07 |
| B | 64.99 | 9.20 | 64.25 | 9.21 | 0.74 |
| C | 129.98 | 14.40 | 129.59 | 14.26 | 0.39 |

| Information of Tools used for Verification of the Instruments | | | |
|---|------------|-----------------------|------------|
| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
| Device Description: | Calibrator | Electrical Multimeter | N/A |
| Manufacturer: | Khrone | Fluke | N/A |
| Model No: | GS8B | 179 | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature 

Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: Khrono
Model: IFC 100W
Order Code: NA
Serial No.: C16501544
Tag: FIT014(LOWER)
Job Location: Lower filter
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-60
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-200
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 200

Sensor Details

Line size: 10"
GKL: 8.2852
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|------------|------------|
| TOTALIZER (m3) | 1955599.24 | 1955602.36 |
| FLOW (l/sec) | 0 | 0 |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

Instrument Test Information and Results

| Set-Point as Per Calibration KIT | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
|----------------------------------|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| 0 | 0.00 | 4.00 | 0.00 | 3.99 | 0.00 |
| A | 30.99 | 6.48 | 30.56 | 6.12 | 0.43 |
| B | 61.98 | 8.96 | 60.52 | 8.92 | 1.46 |
| C | 123.96 | 13.92 | 123.56 | 12.89 | 0.40 |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|------------|-----------------------|------------|
| Device Description: | Calibrator | Electrical Multimeter | N/A |
| Manufacturer: | Khrono | Fluke | N/A |
| Model No: | GS8B | 179 | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature

Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - ABB ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information
Make: ABB
Model: MagMaster
Order Code: NA
Serial No.: 3K620000015306
Tag: FIT07
Job Location: Storm Flow
Asset ID: NA

Service Information
Date: September 2nd, 2020
Report No: CO1150-2009-61
Job No: CO1150-2009

Sensor Details
Line size: 10"
Mounting: Remote

Flow Details
Unit: l/sec
Flow Range: 0-200
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 200

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| TOTALIZER (m3) | 668750 | 668753 |
| FLOW (l/sec) | 0 | 0 |

| Maintenance Checklist | | | Remarks |
|---------------------------|--|---------------------------------|---------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK | |

| Instrument Test Information and Results | | | | | |
|---|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| Flow Input (%) | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
| 0.00 | 0.00 | 4.00 | 0.00 | 3.99 | 0.00 |
| 25.00 | 50.00 | 8.00 | 50.00 | 7.99 | 0.00 |
| 50.00 | 100.00 | 12.00 | 100.00 | 11.99 | 0.00 |
| 75.00 | 150.00 | 16.00 | 150.00 | 15.99 | 0.00 |
| 100.00 | 200.00 | 20.00 | 200.00 | 19.99 | 0.00 |


| Information of Tools used for Verification of the Instruments | | | |
|---|-----------------------|------------|------------|
| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
| Device Description: | Electrical Multimeter | N/A | N/A |
| Manufacturer: | Fluke | N/A | N/A |
| Model No: | 179 | N/A | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature 

Printed Date: September 2nd, 2020



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - ABB ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: ABB
Model: MagMaster
Order Code: NA
Serial No.: 3K620000015305
Tag: FIT08
Job Location: Storm return Flow
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-62
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-100
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 100

Sensor Details

Line size: 8"
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| TOTALIZER (m3) | 697870 | 697883 |
| FLOW (l/sec) | 0 | 0 |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

Instrument Test Information and Results

| Flow Input (%) | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
|----------------|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| 0.00 | 0.00 | 0.25 | 0.25 | 3.99 | -0.25 |
| 25.00 | 25.00 | 24.56 | 24.56 | 7.99 | 0.44 |
| 50.00 | 50.00 | 49.89 | 49.89 | 11.99 | 0.11 |
| 75.00 | 75.00 | 75.00 | 75.00 | 15.99 | 0.00 |
| 100.00 | 100.00 | 100.00 | 100.00 | 19.99 | 0.00 |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|-----------------------|------------|------------|
| Device Description: | Electrical Multimeter | N/A | N/A |
| Manufacturer: | Fluke | N/A | N/A |
| Model No: | 179 | N/A | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature

Printed Date: September 2nd, 2020

End of Report

Version: 19-12



151 Superior Blvd, Unit #13
Mississauga, ON, L5T 2L1.
www.Indus-Control.com

VERIFICATION REPORT - ABB ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: Town of Shelburne
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial rd,
Shelburne, ON L0N1S4

Device Information

Make: ABB
Model: MagMaster
Order Code: NA
Serial No.: 3K620000015302
Tag: FIT09
Job Location: Sludge transfer Flow
Asset ID: NA

Service Information

Date: September 2nd, 2020
Report No: CO1150-2009-63
Job No: CO1150-2009

Flow Details

Unit: l/sec
Flow Range: 0-80
Current Output: 4-20 mA
4 mA Set Point: 0
20 mA Set Point: 80

Sensor Details

Line size: 8"
Mounting: Remote

| Inst. Reading | AS FOUND | AS LEFT |
|----------------|----------|---------|
| TOTALIZER (m3) | 97590 | 97593 |
| FLOW (l/sec) | 0 | 0 |

Maintenance Checklist

| | | |
|---------------------------|--|---------------------------------|
| Visual Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Electrical Inspection: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Sensor Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |
| Transmitter Installation: | <input checked="" type="checkbox"/> OK | <input type="checkbox"/> NOT OK |

Remarks

Instrument Test Information and Results

| Flow Input (%) | Calculated Flow (l/sec) | Calculated O/P (mA) | UUT Display (l/sec) | UUT Measured Output (mA) | Deviation (l/sec) |
|----------------|-------------------------|---------------------|---------------------|--------------------------|-------------------|
| 0.00 | 0.00 | 4.00 | 0.00 | 3.99 | 0.00 |
| 25.00 | 20.00 | 8.00 | 20.00 | 7.99 | 0.00 |
| 50.00 | 40.00 | 12.00 | 40.00 | 11.99 | 0.00 |
| 75.00 | 60.00 | 16.00 | 59.90 | 15.99 | 0.10 |
| 100.00 | 80.00 | 20.00 | 80.00 | 19.99 | 0.00 |

Information of Tools used for Verification of the Instruments

| Details | Tool/Kit 1 | Tool/Kit 2 | Tool/Kit 3 |
|---------------------|-----------------------|------------|------------|
| Device Description: | Electrical Multimeter | N/A | N/A |
| Manufacturer: | Fluke | N/A | N/A |
| Model No: | 179 | N/A | N/A |

* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: **Passed** **Fail** **Not Verified**

Overall Remarks: Measurement Works within Specification.

Service Technician : Sagar Patel

Stamp/Signature



Printed Date: September 2nd, 2020

End of Report

Version: 19-12


**2020 Annual Performance Report
Shelburne Wastewater Treatment Plant
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix D

Process Flow Schematic

2020

- LEGEND**
- Existing lines
 - Proposed lines
 - Proposed lines to be installed in 2003
 - Proposed lines to be installed in 2004
 - Proposed lines to be installed in 2005
 - Proposed lines to be installed in 2006
 - Proposed lines to be installed in 2007
 - Proposed lines to be installed in 2008
 - Proposed lines to be installed in 2009
 - Proposed lines to be installed in 2010
 - Proposed lines to be installed in 2011
 - Proposed lines to be installed in 2012
 - Proposed lines to be installed in 2013
 - Proposed lines to be installed in 2014
 - Proposed lines to be installed in 2015
 - Proposed lines to be installed in 2016
 - Proposed lines to be installed in 2017
 - Proposed lines to be installed in 2018
 - Proposed lines to be installed in 2019
 - Proposed lines to be installed in 2020
 - Proposed lines to be installed in 2021
 - Proposed lines to be installed in 2022
 - Proposed lines to be installed in 2023
 - Proposed lines to be installed in 2024
 - Proposed lines to be installed in 2025
 - Proposed lines to be installed in 2026
 - Proposed lines to be installed in 2027
 - Proposed lines to be installed in 2028
 - Proposed lines to be installed in 2029
 - Proposed lines to be installed in 2030



| | |
|---|----------------------|
| <p>EXPANSION OF WATER POLLUTION CONTROL FACILITIES PHASE 2</p> | |
| <p>TOWN OF SHELburne</p> | |
| <p>GENERAL PLANS</p> | |
| <p>PROCESS FLOW SCHEMATIC</p> | |
| <p>DATE: JANUARY 2003</p> | <p>SCALE: N.T.S.</p> |
| <p>PROJECT NO: MO-01-0284-C3</p> | <p>DATE: N.T.S.</p> |
| <p>BERNSTEIN</p> <p>Engineering & Construction Services, Inc.</p> <p>1000 North Main Street, Suite 1000</p> <p>Westborough, MA 01581</p> <p>TEL: 508-853-1100</p> <p>FAX: 508-853-1101</p> <p>WWW: www.bernstein.com</p> | |

Must Be Updated To Incorporate Phase 2 As Constructed Improvements