

# 2022 ANNUAL SEWAGE REPORT Version 2

SHELBURNE WASTEWATER  
TREATMENT PLANT

For the period of  
January 1<sup>st</sup>, 2022 to December 31<sup>st</sup>, 2022

Prepared for the Corporation of the Town of Shelburne by the Ontario Clean Water Agency



*A People Place, A Change of Pace*  
**SHELBURNE**  
ONTARIO, CANADA



**ONTARIO CLEAN WATER AGENCY**  
**AGENCE ONTARIENNE DES EAUX**

## Table of Contents

1. System Description.....	2
2. Monitoring Data and Comparison to Effluent Limits .....	5
2.1 Sampling Frequency.....	5
2.2 Effluent Objectives and Effluent Limits.....	6
2.3 Comparison of Data to Effluent Objectives and Effluent Limits .....	7
2.4 Additional Monitoring Parameters.....	10
2.5 Overview of Success and Adequacy of the Works;.....	11
3. Operating Problems and Corrective Actions .....	11
4. Major Maintenance Activities .....	11
5. Effluent Quality Assurance and Control .....	12
5.1 Adherence to Provincial Regulations .....	12
5.2 Use of Accredited Laboratories.....	12
5.3 Operation by Licensed Operators .....	12
5.4 Sampling and Analysis .....	13
5.5 In-House Analysis.....	13
6. Calibration and Maintenance Procedures .....	13
7. Efforts and Results Achieved in Meeting Effluent Objectives .....	13
8. Sludge Generation.....	14
9. Complaints.....	15
10. By-pass, Spill or Abnormal Discharge Events .....	15
11. Notice of Modifications .....	16
12. Summary of Completed Modifications .....	16
13. Additional Information.....	16

Appendix A: Performance Assessment Report

Appendix B: Sludge Haulage Summary, Sludge Quality Analysis, & Septage Receiving

Appendix C: Calibration Reports

Appendix D: Process Flow Schematic

Appendix E: Notice of Modification to the Sewage Works

Appendix F: ECA Limit Exceedance Email/Written Notifications

## 1. System Description

The Town of Shelburne is a community of approximately 8,994 people located approximately 100 kilometers northwest of Toronto. The community first obtained a waste disposal system in 1968 with the construction of a 5.5 ha lagoon and associated gravity collection and pumping system. The Town grew consistently over the years and eventually overloaded the lagoon system. In July 1981 construction was completed on a wastewater treatment system located at the present location. This expansion consisted of a new trunk sewer, pumping facilities, secondary and tertiary treatment and modifications to the existing lagoons which now provide storm and effluent holding during excess storm flows and plant upsets and maintenance.

The facility consisted of a wet well, a manual screen, grit channels, an oxidation ditch, one secondary clarifier, four effluent sand filters and a chlorine contact chamber. The oxidation ditch used two brush rotors. The facility operated as an extended aeration plant in this configuration from 1981 until December 1999.

A major expansion (Phase 1) took place at the Shelburne WWTP in 1999, changing the configuration of the plant and the method of treating wastewater. The plant went under construction starting in April 1999 with the start-up of the new process in December of 1999. The Shelburne WWTP is still an extended aeration plant. As an extended aeration plant it is designed to remove suspended solids, CBOD<sub>5</sub> and phosphorus from the wastewater. Major improvements were two aeration tanks constructed with fine bubble diffusers. The sludge treatment system consists of a two stage aerobic sludge digestion system with a total storage volume of 580m<sup>3</sup>, equipped with coarse bubble aeration system and supernatant decanting. The former oxidation ditch was converted to a sludge storage facility with approximately six months storage.

Sludge loading facilities provide for transfer of digested aerobic sludge to trucks. Digested sludge is land-applied as farm fertilizer.

### Works:

#### Trunk Sanitary Sewers

- 82 m of 750 mm diameter, 594 m of 600 mm diameter and 14.5 m of 300 mm diameter trunk

sanitary sewers complete with emergency overflow to adjacent creek and all necessary manholes, appurtenances and inter-connections to the sanitary collection system, commencing at a point approximately 100 m south and 13 m west of the intersection of Ella Street and Highway Nos. 10 and 89 following an easement 60 m east and then north across Highway Nos. 10 and 89 and then generally along the creek bank to a point approximately 40 m south, 15 m west of the pumping station then due north to the centre of Centennial Street (unopened extension) and then north and west 82 m to the Inlet Works at the sewage treatment plant;

#### Hauled Sewage Receiving Station

- one (1) hauled sewage transfer tank with a capacity of 24,000 L, located adjacent to the inlet works building;

## Inlet Works

- one (1) automatic mechanical bar screen having a Peak Flow Rate of 13,000 m<sup>3</sup>/d, one (1) manually cleaned bar racks for emergency or maintenance bypass and one (1) bypass channel overflow weir; – one (1) 7.50 m x 2.93 m x 5.40 m benched wet well equipped with two (2) submersible pumps, each with VFD and rated at 34.4 to 103.3 L/s at 10.2 to 12.0 m TDH; – one (1) wet weather flow pump rated at 81.0 Vs, 8.53 m TDH, discharging to the wet weather flow holding ponds; – one (1) additional wet weather flow pump rated at 152 Vs, 1.6 m TDH., discharging through the storm force main to the wet weather flow holding ponds; – one (1) 2.1 m diameter vortex grit separator having a Peak Flow Rate of 9,504 m<sup>3</sup>/d and a grit classifier; – three (3) 5.7 m x 0.6 m x 1.0 m SWD grit channels having a Peak Flow Rate of 9,130 m<sup>3</sup>/d for back up to the vortex grit separator;

## Wet Weather Flow Holding Ponds

- one (1) 19,900 m<sup>3</sup> Wet Weather Flow Holding Pond A and one (1) 16,800 m<sup>3</sup> Wet Weather Flow Holding Pond B, to be used under emergency situations for temporary storage of wet weather flow to be returned later to the Inlet Works for further treatment;

## Aeration Tanks

- two (2) 40 m x 10 m x 4.6 m SWD aeration tanks, each with two longitudinal cells with the inlet pipes to distribute flows into each cell of each tank, equipped with fine bubble diffused aeration system and two (2) centrifugal air blowers (one duty and one standby), rated at 500 Vs and 250 L/S respectively;

## Secondary Clarifiers

- one (1) 14.0 m diameter x 2.8 m SWD secondary clarifiers equipped with sludge and scum removal mechanisms and cold weather cover;
- – one (1) 14.0 m diameter x 3.65 m SWD secondary clarifiers equipped with sludge and scum removal mechanisms and cold weather cover;

## Clarifier Effluent Pump System

- two (2) 2.9 m x 2.1 m x 2.0 m SWD clarified effluent tanks; – three (3) VFD controlled dry pit filter feed pumps each rated at 17.2 to 51.7 L/S at 9.9 to 11.3 m T.D.H. discharging to either the filters or to the wet weather flow holding ponds;

## Filtration

- two (2) cloth-filter treatment units (one standby) each having a Peak Flow Rate of 558 m<sup>3</sup>/h via one (1) 450 mm diameter inlet piping to a splitter box, 250 mm process pipings to the units and overflow over a weir;

### Ultraviolet (UV) Disinfection

- a 8.0 m x 0.61 m x 1.067 m deep channel equipped with a low pressure mercury vapour ultraviolet irradiation lamp system having a Peak Flow Rate of 8,921 m<sup>3</sup>/d and with a weighted lever gate on the outlet to the Parshall flume to maintain the liquid level in the channel at a depth of 460 mm;

### Outfall Sewer

- approximately 60 m of 450 mm x 740 mm effluent outfall pipe discharging from the Parshall flume to a minor tributary of Boyne River;

### Activated Sludge Pumping System

- three (3) VFD controlled sludge pumps, each rated at 8.6 to 34.4 Vs at 3.2 to 7.6 m T.D.H., complete with valving and piping to permit withdrawal from either the secondary clarifier sludge sump or the scum hopper and returning to either the aeration tanks or to wasting to the sludge digesters;

### Phosphorus Removal

- one (1) 24.1 m capacity chemical storage tank and four (4) chemical metering pumps (two with capacity of 23 U/h to the secondary clarifiers and two with capacity of 108 LAI to the tertiary filters) for phosphorus removal;

### Sludge Digestion

- a two stage aerobic sludge digestion system with one (1) 450 m stage 1 digester and one (1) 170 m stage 2 digester, both equipped with coarse bubble aeration system and supernatant decanting facility;
- two (2) air blowers (one standby shared with the aeration tanks) rated at 1,800m<sup>3</sup>/h supplying air to the digesters;
- two (2) replacement digested sludge transfer pumps (one standby) each rated at 20 L/s at 19 m TDH;

### Biosolids Storage Tank

- one (1) 4,300 m biosolids storage tank with mixing nozzles and two (2) mixing pumps;

### Effluent Flow Measurement

- one (1) 305 mm Parshall flume measuring quantity of effluent discharged from the plant located downstream of the UV disinfection system;

### Standby Power

- one (1) 650 kW standby power diesel generator and 9000 L diesel tank with double-walled containment

This facility receives residential, commercial, institutional and industrial wastewater and provides a level of treatment to meet the amended "Environmental Compliance Approval - # 6413-ABLQQS" for discharging into the Beasley Drain a minor tributary of the Boyne River. The Boyne Creek empties into the Nottawasaga River, ultimately meeting Georgian Bay.

A "Process Flow Schematic" is included in **Appendix D** of this report.

An overview of Shelburne Wastewater Treatment Plant can be found in Table 1:

**Table 1.** Shelburne Wastewater Treatment Plant Overview

<b>Facility Name</b>	Shelburne Wastewater Treatment Plant
<b>Facility Type</b>	Extended Air STP with Tertiary Treatment
<b>Plant Classification</b>	WWT III
<b>Works Number</b>	110000659
<b>Design Capacity</b>	3,420 m <sup>3</sup> /day
<b>Receiving Water</b>	Besley Drain to Boyne Creek to Nottawasaga River
<b>Environmental Compliance Approval</b>	6413-ABLQQS , issued July 19, 2016

## 2. Monitoring Data and Comparison to Effluent Limits

As per Section 10(6)(a) of ECA 6413-ABLQQS, a summary and interpretation of all monitoring data and a comparison to the effluent limits outlined in Effluent Limits of Condition 7, including an overview of the success and adequacy of the Works is required.

### 2.1 Sampling Frequency

Hauled sewage, raw sewage, and final effluent are sampled on a regular basis. The sampling types and frequencies are summarized in Tables 2, 3 and Table 4. The sampling frequencies meet the requirements set out in Section 9 of ECA 6413-ABLQQS.

**Table 2.** Hauled Sewage Monitoring (Hauled Sewage receiving Station) – Sampling Frequencies

Parameter	Sample Type	Frequency
BOD <sub>5</sub> <sup>2A</sup>	Grab	Monthly
Total Suspended Solids <sup>2A</sup>	Grab	Monthly
Total Phosphorus <sup>2A</sup>	Grab	Monthly
Total Kjeldahl Nitrogen <sup>2A</sup>	Grab	Monthly

<sup>2A</sup>Refer to Appendix A for monthly sample results.

**Table 3.** Raw Sewage Monitoring – Sampling Frequencies

Parameter	Sample Type	Frequency
BOD <sub>5</sub> <sup>3A</sup>	Composite	Monthly
Total Suspended Solids <sup>3A</sup>	Composite	Monthly
Total Phosphorous <sup>3A</sup>	Composite	Monthly
Total Kjeldahl Nitrogen <sup>3A</sup>	Composite	Monthly

<sup>3A</sup>Refer to Appendix A for monthly sample results.

**Table 4.** Effluent Sampling Monitoring – Sampling Frequencies

Parameters	Sample Type	Frequency
CBOD <sub>5</sub> <sup>4A</sup>	Composite	Weekly
Total Suspended Solids <sup>4A</sup>	Composite	Weekly
Total Phosphorous <sup>4A</sup>	Composite	Weekly
Total Ammonia Nitrogen <sup>4A</sup>	Composite	Weekly
E. Coli <sup>4A</sup>	Grab	Weekly
pH	Grab/Probe	Weekly
Temperature	Grab/Probe	Weekly

<sup>4A</sup>Refer to Appendix A for monthly sample results.

## 2.2 Effluent Objectives and Effluent Limits

The effluent objectives as per Section 6 of ECA 6413-ABLQQS for the Shelburne Wastewater Treatment Plant are found in Table 5.

**Table 5.** Effluent Objectives as per Section 6 of ECA 6413-ABLQQS

Effluent Parameter	Concentration Objective (mg/L)
CBOD <sub>5</sub>	4.0
Total Suspended Solids	4.0
Total Phosphorous	0.12
Total Ammonia Nitrogen June 01 to Sept 30	0.5
Oct 01 to May 31	2.0
E-coli	150 CFU /100 mL (monthly Geometric Mean Density)
pH	maintained between 6.5 to 8.5, inclusive, at all times

The effluent limits that are to be met as per Section 7 of ECA 6413-ABLQQS for the Shelburne Wastewater Treatment Plant are found in Table 6. Any exceedance with the limits found in Table 6 constitutes a non-compliance with ECA 6413-ABLQQS.

**Table 6.** Effluent Limits as per Section 7 of ECA 6413-ABLQQS

Effluent Parameter	Average Concentration Limit (mg/L)	Average Waste Loading Limit (kg/day)
CBOD <sub>5</sub>	5.0	17.1
Total Suspended Solids	5.0	17.1
Total Phosphorous	0.25	0.86
Total Ammonia Nitrogen Jun 01 to Sep 30	0.8	2.7
Oct 01 to May 31	2.4	8.2
E-coli	200 CFU /100 mL (monthly Geometric Mean Density)	n/a
pH	maintained between 6.0 to 9.5, inclusive, at all times	

## 2.3 Comparison of Data to Effluent Objectives and Effluent Limits

Analytical and monitoring data for the Shelburne Wastewater Treatment Facility is stored in OCWAs data management system (WISKI). Annual and monthly averages for flows, CBOD<sub>5</sub>, BOD<sub>5</sub>, Suspended Solids, Total Phosphorous, Nitrogen-series and E.coli can be found in Appendix A. A comparison of analytical data from effluent samples to the effluent objectives and effluent limits shown in the below Tables 7-13:

**Table 7.** 2022 Monthly Average Concentration and Loading of CBOD<sub>5</sub> in Comparison to ECA Objectives and Limits

	CBOD <sub>5</sub>					
	Monthly Average Concentration (mg/L)	Within Objectives (4.00 mg/L)	Within Limits (5.00 mg/L)	Monthly Average Loading (kg/d)	Within Objectives ( kg/d)	Within Limits (17.10 kg/d)
<b>January</b>	3.25	Yes	Yes	7.57	n/a	Yes
<b>February</b>	<3.83	Yes	Yes	<8.90	n/a	Yes
<b>March</b>	3.40	Yes	Yes	9.08	n/a	Yes
<b>April</b>	2.75	Yes	Yes	7.10	n/a	Yes
<b>May</b>	<5.40	<b>No</b>	<b>No</b> <sup>7A</sup>	<11.18	n/a	Yes
<b>June</b>	<3.50	Yes	Yes	<8.08	n/a	Yes
<b>July</b>	<3.00	Yes	Yes	<6.51	n/a	Yes
<b>August</b>	<4.00	Yes	Yes	<7.42	n/a	Yes
<b>September</b>	4.50	<b>No</b>	Yes	8.40	n/a	Yes
<b>October</b>	<3.25	Yes	Yes	<6.16	n/a	Yes
<b>November</b>	<3.00	Yes	Yes	<5.84	n/a	Yes
<b>December</b>	<3.25	Yes	Yes	<6.74	n/a	Yes

<sup>7A</sup>Required notification of non-compliances were made for the limit exceedance in May 2022 and full details are provided in appendix F

**Table 8.** 2022 Monthly Average Concentration and Loading of TSS in Comparison to ECA Objectives and Limits

	Total Suspended Solids					
	Monthly Average Concentration (mg/L)	Within Objectives (4.00 mg/L)	Within Limits (5.00 mg/L)	Monthly Average Loading (kg/d)	Within Objectives ( kg/d)	Within Limits (17.10 kg/d)
<b>January</b>	3.75	Yes	Yes	8.73	n/a	Yes
<b>February</b>	4.33	<b>No</b>	Yes	10.06	n/a	Yes
<b>March</b>	3.20	Yes	Yes	8.55	n/a	Yes
<b>April</b>	4.00	Yes	Yes	10.33	n/a	Yes
<b>May</b>	<2.40	Yes	Yes	<4.97	n/a	Yes
<b>June</b>	3.00	Yes	Yes	6.93	n/a	Yes
<b>July</b>	3.75	Yes	Yes	8.14	n/a	Yes
<b>August</b>	3.60	Yes	Yes	6.68	n/a	Yes
<b>September</b>	3.50	Yes	Yes	6.53	n/a	Yes
<b>October</b>	<2.00	Yes	Yes	<3.79	n/a	Yes
<b>November</b>	2.80	Yes	Yes	5.45	n/a	Yes
<b>December</b>	5.50	<b>No</b>	<b>No</b> <sup>8A</sup>	11.40	n/a	Yes



<sup>8A</sup>Required notification of non-compliances were made for the limit exceedance in December 2022 and full details are provided in appendix F

**Table 9. 2022 Monthly Average Concentration and Loading of Total Phosphorus in Comparison to ECA Objectives and Limits**

	Total Phosphorus					
	Monthly Average Concentration (mg/L)	Within Objectives (0.12 mg/L)	Within Limits (0.25 mg/L)	Monthly Average Loading (kg/d)	Within Objectives ( kg/d)	Within Limits (0.86 kg/d)
<b>January</b>	0.08	Yes	Yes	0.18	n/a	Yes
<b>February</b>	0.10	Yes	Yes	0.23	n/a	Yes
<b>March</b>	0.10	Yes	Yes	0.25	n/a	Yes
<b>April</b>	0.11	Yes	Yes	0.29	n/a	Yes
<b>May</b>	0.05	Yes	Yes	0.10	n/a	Yes
<b>June</b>	0.09	Yes	Yes	0.21	n/a	Yes
<b>July</b>	0.10	Yes	Yes	0.21	n/a	Yes
<b>August</b>	0.09	Yes	Yes	0.17	n/a	Yes
<b>September</b>	0.17	<b>No</b>	Yes	0.31	n/a	Yes
<b>October</b>	0.13	<b>No</b>	Yes	0.25	n/a	Yes
<b>November</b>	0.09	Yes	Yes	0.17	n/a	Yes
<b>December</b>	0.08	Yes	Yes	0.17	n/a	Yes

**Table 10. 2022 Monthly Average Concentration and Loading of Total Ammonia Nitrogen in Comparison to ECA Objectives and Limits**

	Total Ammonia Nitrogen (Ammonia Nitrogen + Ammonium Nitrogen)									
	Monthly Average Concentration (mg/L)	Within Objectives (Jun 01-Sept 30 0.50 mg/L)	Within Objectives (Oct 01-May 31 2.00 mg/L)	Within Limits (Jun 01-Sept 30 0.80 mg/L)	Within Limits (Oct 01-May 31 2.4 mg/L)	Monthly Average Loading (kg/d)	Within Objectives (Dec 01-Apr 30 kg/d)	Within Objectives (May 01-Nov 30 kg/d)	Within Limits (June 01-Sept 30 2.70 kg/d)	Within Limits (Oct 01-May 31 8.20 kg/d)
<b>January</b>	<0.10	n/a	Yes	n/a	Yes	<0.23	n/a	n/a	n/a	Yes
<b>February</b>	<0.10	n/a	Yes	n/a	Yes	<0.23	n/a	n/a	n/a	Yes
<b>March</b>	<0.10	n/a	Yes	n/a	Yes	<0.27	n/a	n/a	n/a	Yes
<b>April</b>	<0.10	n/a	Yes	n/a	Yes	<0.26	n/a	n/a	n/a	Yes
<b>May</b>	<0.10	n/a	Yes	n/a	Yes	<0.21	n/a	n/a	n/a	Yes
<b>June</b>	<0.18	Yes	n/a	Yes	n/a	<0.40	n/a	n/a	Yes	n/a
<b>July</b>	<0.10	Yes	n/a	Yes	n/a	<0.22	n/a	n/a	Yes	n/a
<b>August</b>	<0.10	Yes	n/a	Yes	n/a	<0.19	n/a	n/a	Yes	n/a
<b>September</b>	<0.10	Yes	n/a	Yes	n/a	<0.19	n/a	n/a	Yes	n/a
<b>October</b>	<0.10	n/a	Yes	n/a	Yes	<0.19	n/a	n/a	n/a	Yes
<b>November</b>	<0.10	n/a	Yes	n/a	Yes	<0.20	n/a	n/a	n/a	Yes
<b>December</b>	<0.13	n/a	Yes	n/a	Yes	<0.26	n/a	n/a	n/a	Yes

**Table 11.** 2022 Monthly Average Concentration of E.Coli in Comparison to ECA Objectives and Limits

	<b>E.coli</b>		
	Monthly Geometric Mean Density (CFU/100mL)	Within Objectives (150 CFU/100mL)	Within Limits (200 CFU/100mL)
<b>January</b>	2.38	Yes	Yes
<b>February</b>	1.68	Yes	Yes
<b>March</b>	2.00	Yes	Yes
<b>April</b>	1.68	Yes	Yes
<b>May</b>	2.00	Yes	Yes
<b>June</b>	2.00	Yes	Yes
<b>July</b>	2.00	Yes	Yes
<b>August</b>	1.74	Yes	Yes
<b>September</b>	2.00	Yes	Yes
<b>October</b>	1.68	Yes	Yes
<b>November</b>	2.00	Yes	Yes
<b>December</b>	2.00	Yes	Yes

**Table 12.** 2022 Monthly Minimum and Maximum pH in Comparison to ECA Objectives and Limits

	<b>pH</b>			
	pH Monthly Minimum	pH Monthly Maximum	Within Objectives (6.5-8.5)	Within Limits (6.0-9.5)
<b>January</b>	7.6	7.7	Yes	Yes
<b>February</b>	7.6	7.6	Yes	Yes
<b>March</b>	7.5	7.7	Yes	Yes
<b>April</b>	7.6	7.8	Yes	Yes
<b>May</b>	7.6	7.7	Yes	Yes
<b>June</b>	7.7	7.7	Yes	Yes
<b>July</b>	7.3	7.8	Yes	Yes
<b>August</b>	7.7	7.8	Yes	Yes
<b>September</b>	7.3	7.7	Yes	Yes
<b>October</b>	7.5	7.7	Yes	Yes
<b>November</b>	7.4	7.6	Yes	Yes
<b>December</b>	7.4	8.0	Yes	Yes

**Table 13.** 2022 Monthly Minimum and Maximum Temperature

	Temperature	
	Monthly Minimum (°C)	Monthly Maximum (°C)
<b>January</b>	11.2	14.2
<b>February</b>	12.6	14.2
<b>March</b>	12.5	14.9
<b>April</b>	12.9	15.5
<b>May</b>	15.1	19.1
<b>June</b>	18.4	20.1
<b>July</b>	20.8	21.7
<b>August</b>	21.7	23.0
<b>September</b>	19.0	22.9
<b>October</b>	17.2	19.3
<b>November</b>	14.8	17.8
<b>December</b>	12.7	15.5

**Table 14.** Effluent Monitoring Parameter Summary as required by ECA 6413-ABLQQS for Shelburne Treatment Plant, 2022

Parameters	Average (mg/L)	Minimum (mg/L)	Maximum (mg/L)	Average Annual Loading (kg/d)
CBOD <sub>5</sub>	3.63	2.75	5.40	7.75
Total Suspended Solids	3.48	<2.00	5.50	7.63
Total Phosphorus	0.10	0.05	0.17	0.21
Total Ammonia Nitrogen	<0.11	<0.10	<0.18	<0.24
E.Coli (cfu/100ml)	-	1.68	2.38	n/a
pH	7.6	7.3	8.0	n/a
Temperature	16.9	11.2	21.7	n/a

## 2.4 Additional Monitoring Parameters

The following parameters in Table 15 do not have limits or objectives but are monitored on a regular basis (see Section 2.1 for sampling frequency) as required by ECA 6413-ABLQQS. Table 15 summarizes the monitoring data for the reporting period.

Raw sewage quality in 2022 overall in all parameters were lower than compared to raw sewage quality in 2021. BOD<sub>5</sub> annual average was 478.54 mg/L in 2021 and was lower this year at 455.58 mg/L. TSS annual average was 1349.08 mg/L in 2021 and was significantly lower this year at 645.00 mg/L. TP annual average was 9.24 mg/L in 2021 and lower this year at 6.63 mg/L. TKN annual average was 56.28 mg/L in 2021 and was lower this year at 45.11 mg/L.

**Table 15.** Raw Sewage Monitoring Parameters as required by ECA 6413-ABLQQS for Shelburne Wastewater Treatment Plant, 2022

Parameter	Average (mg/L)	Minimum (mg/L)	Maximum (mg/L)
BOD <sub>5</sub> <sup>15A</sup>	455.58	262.00	703.00
Total Suspended Solids <sup>15A</sup>	645.00	194.00	1300.00
Total Phosphorous <sup>15A</sup>	6.63	3.59	11.60

Total Kjeldahl Nitrogen <sup>15A</sup>	45.11	26.60	59.00
--	-------	-------	-------

<sup>15A</sup>Refer to Appendix A for monthly sample results.

The following parameters in Table 16 do not have limits or objectives but are monitored as needed when septage is received at the facility. Table 16 summarizes the monitoring data for the reporting period.

**Table 16.** Hauled Sewage Monitoring

Parameter	Average (mg/L)	Minimum (mg/L)	Maximum (mg/L)
BOD <sub>5</sub>	5467.86	1660.00	8200.00
Total Suspended Solids	17575.71	8360.00	28200.00
Total Phosphorous	122.41	35.70	200.00
Total Kjeldahl Nitrogen	759.50	305.00	1110.00

## 2.5 Overview of Success and Adequacy of the Works;

The annual average effluent CBOD<sub>5</sub> concentration was 3.63 mg/L with a removal efficiency of >98.34%. The annual average effluent TSS concentration was 3.48 mg/L with a removal efficiency of >98.07%. The annual average effluent Total Phosphorus concentration was 0.10 mg/L with a removal efficiency of >97.33%.

The bacteriological quality of the effluent complied with the certificate of approval requirement of <200 Colony Forming Units (CFU) per 100 mL sample. The maximum geometric mean density for 2022 was 2.38 CFU per 100 mL, indicating adequate effluent disinfection for the majority of the year.

The total raw sewage volume of wastewater treated in 2022 was 957,440.20 m<sup>3</sup>. The annual average daily flow of raw sewage was 2,623.12 m<sup>3</sup>/day was 76.70 % of the design flow (3,420 m<sup>3</sup>/day). The maximum peak flow of 3,830.40 m<sup>3</sup>/day occurred in February due to higher precipitation and snow melt. This represents a peak flow of 1.1 times the rated capacity. The wastewater treatment plant operated within the rated capacity 99.18% of the time (362 out of 365 days of the year). The average daily flow is approaching 80% of the rated capacity and the Town of Shelburne is well aware of this. With future upgrades proposed for the Works this will increase design capacity to accommodate the growth of the Town.

## 3. Operating Problems and Corrective Actions

As per Section 10(6)(b) of ECA 6413-ABLQQS, *a description of any operating problems encountered and corrective actions taken* is required.

During the reporting period there were two (2) operating problems/situations encountered and corrective actions taken at the Shelburne Wastewater Plant during 2022 that affected the quality of the effluent leaving the plant. One situation occurred in May 2022 where the CBOD<sub>5</sub> monthly average concentration limit was exceeded due to the North Clarifier being taken out of service on April 28, 2022 for repairs of the return activated sludge pumps 1 and 3 while the plant may have taken a shock load of BOD from possible industrial section of town. It was observed in the lab analysis between weekly samples of CBOD<sub>5</sub> from May 3, 2022 to May 10, 2022. The North Clarifier was returned to service June 6, 2022. Another situation occurred December 2022 where the Total Suspended Solids monthly average concentration limit was exceeded due to high concentration of solids entering the plant after hours, the observation of black raw sewage coming into the plant, snow storm causing equipment failures and electrical cable issues to the equipment. During this situation corrective actions were taken throughout the month to remediate by cleaning UV channel, auto sampler/discharge lines, increase aeration and contractor/electrician onsite to solve electrical issues. The ECA limit exceedance written/email

notification which include full details of these occurrences are included in Appendix F. All major repairs/maintenance can be found in Section 4 of this report.

#### **4. Major Maintenance Activities**

As per Section 10(6)(c) of ECA 6413-ABLQQS, *a summary of all maintenance carried out on any major structure, equipment, apparatus, mechanisms or thing forming part of the works* is required.

Plant maintenance, including non-scheduled maintenance is monitored using Maximo Work Management System. All routine and preventative maintenance was conducted as scheduled in 2022.

For 2022, major maintenance activities that occurred include:

- Septage tank clean out
- Sludge transfer pump repair
- North Clarifier visual inspection while out of service
- Sump pump replacement
- Yard hydrant repair
- Return activated sludge pump #1 repairs
- Return activated sludge pump #3 repairs
- Clarifier sweeper arm repair
- Mechanical bar screen repair
- Blower air filter replacements
- Grit vortex system cleanout
- Annual Backflow Prevention inspection
- UV Lamp and Sleeve replacements
- Annual Gas Sensor calibrations
- Annual Flow Meter calibrations
- Headworks Wet Well cleanout

#### **5. Effluent Quality Assurance and Control**

As per Section 10(6)(d) of ECA 6413-ABLQQS, *a summary of any effluent quality assurance or control measures undertaken in the reporting period* is required:

Quality assurance and control measures undertaken during the reporting period include adherence to provincial regulations, use of accredited laboratories, operation of the system by licensed Operators, scheduled sampling and analysis, in-house laboratory analysis, and calibration and preventative maintenance of equipment. The sections below provide further details of these measures.

##### **5.1 Adherence to Provincial Regulations**

The Ontario Clean Water Agency operates the WWTP in accordance with provincial regulations and the Environmental Compliance Approval.

## 5.2 Use of Accredited Laboratories

Analytical tests to monitor the effluent quality are conducted by a laboratory audited by the Canadian Association for Laboratory Accreditation Inc. (CALA) and accredited by the Standards Council of Canada (SCC). Accreditation ensures that the laboratory has acceptable laboratory protocols and test methods in place. It also requires the laboratory to provide evidence and assurances of the proficiency of the analysts performing the test methods. During the reporting period, all chemical sample analyses were conducted by SGS (Lakefield) Canada Inc.

## 5.3 Operation by Licensed Operators

The WWTP was operated and maintained by licensed Operators. The mandatory licensing program for operators of sewage treatment facilities in Ontario is regulated under the Ontario Water Resources Act (OWRA) Regulation 435/93 and Ontario Regulation 129/04. A Licensed individual has successfully passed the licensing exam and meets the education and experience requirements set out in the regulation.

## 5.4 Sampling and Analysis

The Ontario Clean Water Agency followed a sampling and analysis schedule that meets the requirements of the ECA.

## 5.5 In-house Analysis

In-house analysis were conducted by Licensed Operators for monitoring purposes using standard methods. The data generated from these tests is used to determine the treatment efficiency while effectively maintaining process control. All in-house monitoring equipment is calibrated based on the manufacturer's recommendations. Using their expertise, Operators of the facility make best efforts to stay within the ECA Effluent Objectives and Limits.

## 6. Calibration and Maintenance Procedures

As per Section 10(6)(e) of ECA 6413-ABLQQS, *a summary of the calibration and maintenance carried out on all effluent monitoring equipment* is required.

All in-house monitoring equipment is calibrated/verified as per manufacturer's recommendations. Monitoring and metering equipment is also calibrated by a third party on an annual basis. Preventative maintenance is scheduled for all equipment at the sewage treatment plant and pumping stations at regular frequency (frequency depends on the equipment and type of maintenance). Maintenance activities are scheduled within the work management system Maximo, upon completion, Operators set the work order to complete. On a monthly basis, preventative work orders are reviewed for completion.

Indus Controls was contracted to calibrate flow measuring equipment on August 23, 2022. Copies of these calibration reports can be found in **Appendix C** of this report.

## 7. Efforts and Results Achieved in Meeting Effluent Objectives

As per Section 10(6)(f) of ECA 6413-ABLQQS, *a description of efforts made and results achieved in meeting the Effluent Objectives of Condition 6* is required.

Condition 6 is imposed "to establish non-enforceable effluent quality objectives which the Owner is obligated to use best efforts to strive towards on an ongoing basis. These objectives are to be used as a mechanism to trigger corrective action proactively and voluntarily before environmental impairment occurs and before the compliances limits of Condition 7 are exceeded."

OCWA as the Operating Authority (on behalf of the Owner) has made best efforts to stay within the Effluent Objectives in the ECA. These efforts are supported through:

- Continuous monitoring equipment
- Regular plant inspections/checks
- In-house sampling and testing
- Laboratory (3<sup>rd</sup> party) analysis of influent and effluent samples
- Data review
- Process optimization and adjustments (as required)
- Scheduled/preventative maintenance
- Repairs as necessary

A summary of the effluent quality in comparison to the effluent objectives can be found in Tables 7-13 of section 2.3 of this report. These results show that sewage treatment operations for 2022 provided effluent quality that was within all effluent objectives outlined in the ECA and minimized environmental impairment with the exception of CBOD<sub>5</sub> (February and September 2022), Total Suspended Solids (February and December 2022) and Total Phosphorous (September and October 2022). Higher Mixed Liquor Suspended Solids concentrations in aeration basin and temperature fluctuations could account for some effluent objective exceedances. Minor operational changes were implemented to provide higher effluent quality in order to achieve the effluent objectives outlined in the ECA.

## 8. Sludge Generation

As per Section 10(6)(g) of ECA 6413-ABLQQS, *a tabulation of the volume of sludge generated in the reporting period, an outline of anticipated volumes to be generated in the next reporting period and a summary of the locations to where the sludge was disposed* is required.

Digested sludge produced at the Shelburne WWTP is land-applied in accordance with the Nutrient Management Act 2002 and Ontario Regulation 267/03.

Grab samples of digested (aerobic) sludge are collected and tested as per these requirements. In 2022, sludge sample analysis was carried out by SGS Lakefield Research Limited. Sludge analysis showed that the sludge met the quality criteria specified in the Ontario Guidelines for the Utilization of Biosolids and Other Wastes on Agricultural Land (Guidelines). A summary of sludge sample results is provided in **Appendix B** of this report, along with septage data for the reporting period.

Saugeen Agri. Service was contracted to haul and spread sludge from the Shelburne Wastewater plant in 2022. (Certificate of Approval - Waste Management System #9566-6HYKC3)

The Town of Shelburne has an arrangement/agreement for the hauling, acceptance and processing of liquid biosolids material from the Shelburne Wastewater Treatment Plant with Lystek International Corp. Volumes of biosolids hauled from the Shelburne Wastewater Treatment Plant to Lystek are noted in below table 17.


The following certified sites were utilized in 2022:

**Table 17.** Volume of Sludge Generated from Shelburne Wastewater Treatment Plant in 2022

Site	Site Location	Volume of Biosolids (m <sup>3</sup> )	Hauler
NASM Submission ID: 24387	Harvey Martin Field	2691.00	Saugeen Agri.
NASM Submission ID: 25079	Leroy May	2934.00	Saugeen Agri.
NASM Submission ID: 25247	Gary Horst	3538.00	Saugeen Agri.
Lystek International Corp.	Dundalk, On	1090.00	Saugeen Agri.

A total volume of 9,163 m<sup>3</sup> of sludge was applied to the above fields from the Shelburne WWTP in 2022. Based on the design flow, average wastewater quantity and a linear regression with an R<sup>2</sup> value of 93.91%, the anticipated volume of sludge generated for 2023 will be approximately 10,200 m<sup>3</sup>.

**Figure 1.** Shelburne Wastewater Treatment Plant Haulage Volumes (2013 to 2021)



## 9. Complaints

As per Section 10(6)(h) of ECA 6413-ABLQQS, a summary of any complaints received during the reporting period and any steps taken to address the complaints is required.

A standard operating procedure (SOP) is in place for addressing complaints received from the community. All complaints are addressed and documented in the facility logbook. Community complaint information is entered in OCWA's electronic database system "WMS Maximo". This system contains all the required information and history of all complaints.

There were no complaint registered in 2022 for the reporting period.

## 10. By-pass, Spill or Abnormal Discharge Events

As per Section 10(6)(i) of ECA 6413-ABLQQS, a summary of all By-pass, spill or abnormal discharge events (additionally events outside of Normal Operating Conditions) is required.

There were no by-passes, spills, abnormal discharge events or over flows. However, there were situations outside of Normal Operating Conditions that occurred during this reporting period with regard to the Shelburne Wastewater Treatment Plant. One situation occurred in May 2022 where the CBOD5 monthly average concentration limit was exceeded due to the North Clarifier being taken out of service on April 28, 2022 for repairs of the return activated sludge pumps 1 and 3 while the plant may have taken a shock load of BOD from possible industrial section of town. It was observed in the lab analysis between weekly samples of CBOD5 from May 3, 2022 to May 10, 2022. The North Clarifier was returned to service June 6, 2022. Another situation occurred December 2022 where the Total Suspended Solids monthly average concentration limit was exceeded due to high concentration of solids entering the plant



after hours, the observation of black raw sewage coming into the plant, snow storm causing equipment failures and electrical cable issues to equipment. During this situation corrective actions were taken throughout the month to remediate by cleaning UV channel, auto sampler/discharge lines, increase aeration and contractor/electrician onsite to solve electrical issues. The ECA limit exceedance written/email notification which include full details of these occurrences are included in Appendix F

ECA 6413-ABLQQS requires that Quarterly bypass/overflow reports are to be submitted to the Water Supervisor. All 2022 quarterly reports were submitted to the Water Supervisor by the deadlines specified in the ECA.

## **11. Notice of Modifications**

As per Section 10(6)(j) of ECA 6413-ABLQQS, *a copy of all Notice of Modifications submitted to the Water Supervisor as a result of Schedule B, Section 1, with a status report on the implementation of each modification* is required.

There was one (1) modification at the Shelburne Wastewater Treatment Plant during the reporting period. Please see Appendix E for the completed Notice of Modification to the Sewage Works.

The Notice of Modification was signed March 29, 2022

Description of the Modifications as part of the Limited Operational Flexibility;

AQUABACxt is a highly effective, US EPA-registered biological larvicide. It contains a species of bacteria called bacillus thuringiensis, an approved pesticide for controlling red worms and midge flies in wastewater treatment plants. On a weekly basis from spring to fall operations will dose the incoming raw sewage and aeration tank to eliminate midge flies at the plant during the summer months.

The addition of AQUABACxt was started April 11, 2022 and was greatly beneficial, there was a major reduction of midge flies in the clarifiers and filter/UV rooms when this product was used compared to previous years when no product was used. This product will continue to be used on a weekly basis from spring to fall.

## **12. Summary of Completed Modifications**

As per Section 10(6)(k) of ECA 6413-ABLQQS, *a report summarizing all modifications completed as a result of Schedule B, Section 3* is required.

Normal or emergency operational modifications, such as repairs, reconstructions, or other improvements that are part of maintenance activities, including cleaning, renovations to existing approved sewage works equipment are included in Section 4 of this report.

## **13. Additional Information**

As per Section 10(6)(l) of ECA 6413-ABLQQS, *any other information the Water Supervisor requires from time to time* is required.

There were no requests from the Water Supervisor for any other information during the reporting period.

**2022 Annual Performance Report  
Shelburne Wastewater Treatment Plant  
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix A  
Performance Assessment Report  
2022

5773 SHELBURNE WASTEWATER TREATMENT FACILITY 110000659

	1 / 2022	2/ 2022	3/ 2022	4/ 2022	5/ 2022	6/ 2022	7/ 2022	8/ 2022	9/ 2022	10/ 2022	11/ 2022	12/ 2022	<--Total-->	<--Avg-->	<--Max-->	<-Criteria-->
--	----------	---------	---------	---------	---------	---------	---------	---------	---------	----------	----------	----------	-------------	-----------	-----------	---------------

Flows

Raw Flow: Total - Raw Sewage m³/d	85,300.60	76,627.30	95,175.70	90,656.90	77,851.90	86,788.30	77,938.50	70,091.80	69,555.90	74,333.70	74,313.70	78,805.90	957,440.20			0.00
Raw Flow: Avg - Raw Sewage m³/d	2,751.63	2,736.69	3,070.18	3,021.90	2,511.35	2,892.94	2,514.15	2,261.03	2,318.53	2,397.86	2,477.12	2,542.13		2,623.12		3,420.00
Raw Flow: Max - Raw Sewage m³/d	3,220.80	3,830.40	3,361.90	3,260.80	2,751.90	3,068.10	2,974.10	2,409.70	2,433.30	2,556.10	2,676.80	2,897.00			3,830.40	0.00
Raw Flow: Count - Raw Sewage m³/d	31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00			0.00
Eff. Flow: Total - Final Effluent m³/d	72,174.60	65,012.60	82,796.80	77,456.80	64,172.10	69,281.40	67,290.60	57,491.60	55,973.90	58,755.90	58,357.80	64,249.00	793,013.10			0.00
Eff. Flow: Avg - Final Effluent m³/d	2,328.21	2,321.88	2,670.86	2,581.89	2,070.07	2,309.38	2,170.66	1,854.57	1,865.80	1,895.35	1,945.26	2,072.55		2,172.64		
Eff. Flow: Max - Final Effluent m³/d	2,832.70	3,449.00	2,990.20	2,848.80	2,306.60	2,597.90	2,620.80	2,118.80	2,002.70	2,146.40	2,234.80	2,367.30			3,449.00	0.00
Eff Flow: Count - Final Effluent m³/d	31.00	28.00	31.00	30.00	31.00	30.00	31.00	31.00	30.00	31.00	30.00	31.00	365.00			0.00

Carbonaceous Biochemical Oxygen Demand: CBOD

Raw: Avg cBOD5 - Raw Sewage mg/L	312.00	546.00	377.00	341.00	797.00	357.00	181.00	575.00	541.00	369.00	392.00	331.00		426.58	797.00	0.00
Raw: # of samples of cBOD5 - Raw Sewage	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			0.00
Eff: Avg cBOD5 - Final Effluent mg/L	3.25	3.83	3.40	2.75	5.40	3.50	3.00	4.00	4.50	3.25	3.00	3.25		3.63	5.40	5.00
Eff: # of samples of cBOD5 - Final Effluent	4.00	6.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	54.00			0.00
Loading: cBOD5 - Final Effluent kg/d	7.567	8.901	9.081	7.100	11.178	8.083	6.512	7.418	8.396	6.160	5.836	6.736		7.75	11.18	0.000
Percent Removal: cBOD5 - Final Effluent %	98.96	99.30	99.10	99.19	99.32	99.02	98.34	99.30	99.17	99.12	99.23	99.02			99.32	0.00

Biochemical Oxygen Demand: BOD5

Raw: Avg BOD5 - Raw Sewage mg/L	417.00	640.00	315.00	313.00	638.00	310.00	262.00	703.00	525.00	359.00	666.00	319.00		455.58	703.00	0.00
Raw: # of samples of BOD5 - Raw Sewage	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			0.00
Eff: Avg BOD5 - Final Effluent mg/L	3.00	3.00	3.00	4.00	4.00	4.00	3.00	4.00	5.00	5.00	4.00	2.00		3.67		
Loading: BOD5 - Final Effluent kg/d	6.985	6.966	8.013	10.328	8.280	9.238	6.512	7.418	9.329	9.477	7.781	4.145		7.87	10.33	0.000
Percent Removal: BOD5 - Final Effluent %	99.28	99.53	99.05	98.72	99.37	98.71	98.85	99.43	99.05	98.61	99.40	99.37			99.53	0.00

Total Suspended Solids: TSS

Raw: Avg TSS - Raw Sewage mg/L	542.00	661.00	483.00	350.00	915.00	408.00	194.00	1,160.00	719.00	669.00	1,330.00	309.00		645.00	1,330.00	0.00
Raw: # of samples of TSS - Raw Sewage	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	1.00	12.00			0.00
Eff: Avg TSS - Final Effluent mg/L	3.75	4.33	3.20	4.00	2.40	3.00	3.75	3.60	3.50	2.00	2.80	5.50		3.48	5.50	5.00
Eff: # of samples of TSS - Final Effluent	4.00	6.00	5.00	4.00	5.00	4.00	4.00	5.00	4.00	4.00	5.00	4.00	54.00			0.00
Loading: TSS - Final Effluent kg/d	8.731	10.061	8.547	10.328	4.968	6.928	8.140	6.676	6.530	3.791	5.447	11.399		7.63	11.40	0.000
Percent Removal: TSS - Final Effluent %	99.31	99.34	99.34	98.86	99.74	99.26	98.07	99.69	99.51	99.70	99.79	98.22			99.79	0.00

Total Phosphorus: TP

Raw: Avg TP - Raw Sewage mg/L			5.46			8.05			4.33			4.86			9.49			4.68			3.59			7.57			7.26			5.39			11.60			7.25			6.63			11.60			0.00
Raw: # of samples of TP - Raw Sewage			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			12.00						0.00
Eff: Avg TP - Final Effluent mg/L			0.08			0.10			0.10			0.11			0.05			0.09			0.10			0.09			0.17			0.13			0.09			0.08			0.10			0.17			0.25
Eff: # of samples of TP - Final Effluent			4.00			4.00			5.00			4.00			5.00			4.00			4.00			5.00			4.00			4.00			6.00			4.00			53.00						0.00
Loading: TP - Final Effluent kg/d			0.175			0.232			0.254			0.289			0.099			0.206			0.208			0.170			0.311			0.246			0.169			0.170			0.21			0.31			0.000
Percent Removal: TP - Final Effluent %			98.63			98.76			97.80			97.70			99.50			98.09			97.33			98.79			97.71			97.59			99.25			98.87						99.50			0.00

Nitrogen Series

Raw: Avg TKN - Raw Sewage mg/L			44.10			59.00			37.00			26.60			42.50			44.20			31.20			56.30			58.00			47.00			58.60			36.80				45.11			59.00			0.00	
Raw: # of samples of TKN - Raw Sewage			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			1.00			12.00						0.00		
Eff: Avg TAN - Final Effluent mg/L	<		0.10	<		0.10	<		0.10	<		0.10	<		0.10	<		0.18	<		0.10	<		0.10	<		0.10	<		0.10	<		0.10	<		0.13			<		0.11	<		0.18			2.40
Eff: # of samples of TAN - Final Effluent			4.00			4.00			5.00			4.00			5.00			4.00			4.00			5.00			4.00			4.00			5.00			4.00			52.00						0.00		
Loading: TAN - Final Effluent kg/d	<		0.233	<		0.232	<		0.267	<		0.258	<		0.207	<		0.404	<		0.217	<		0.185	<		0.187	<		0.190	<		0.195	<		0.259			<		0.24	<		0.40			0.000
Eff: Avg NO3-N - Final Effluent mg/L			25.25			26.75			20.12			22.03			27.10			29.63			27.25			26.70			29.63			30.58			27.66			25.20				26.49			30.58			0.00	
Eff: # of samples of NO3-N - Final Effluent			4.00			4.00			5.00			4.00			5.00			4.00			4.00			5.00			4.00			4.00			5.00			4.00			52.00						0.00		
Eff: Avg NO2-N - Final Effluent mg/L			0.12			0.11			0.08			0.12			0.18			0.17			0.16			0.11			0.12	<		0.10	<		0.09			0.39				0.14			0.39			0.00	
Eff: # of samples of NO2-N - Final Effluent			4.00			4.00			5.00			4.00			5.00			4.00			4.00			5.00			4.00			4.00			5.00			4.00			52.00						0.00		

Disinfection

Eff: GMD E. Coli - Final Effluent cfu/100mL			2.38			1.68			2.00			1.68			2.00			2.00			2.00			1.74			2.00			1.68			2.00			2.00																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																																															
---	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	------	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--

**2022 Annual Performance Report  
Shelburne Wastewater Treatment Plant  
Amended Environmental Compliance Approval No. 6413-ABLQQS**

**Appendix B**

**Sludge Haulage Summary, Sludge Quality, and  
Septage Receiving**

**2022**

Shelburne WWTP - Daily Haulage Summary			
Date	Site	NASM #	Sludge Hauled (m³)
May			
13-May-22	Harvey Martin	24387	799.00
17-May-22	Harvey Martin	24387	306.00
18-May-22	Harvey Martin	24387	815.00
20-May-22	Harvey Martin	24387	771.00
June			
20-Jun-22	Leroy May	25079	1138.00
21-Jun-22	Leroy May	25079	953.00
22-Jun-22	Leroy May	25079	843.00
November			
14-Nov-22	Gary Horst	25247	594.00
15-Nov-22	Gary Horst	25247	739.00
16-Nov-22	Gary Horst	25247	893.00
17-Nov-22	Gary Horst	25247	954.00
18-Nov-22	Gary Horst	25247	358.00
Total			9163.00

Note: all parameters in this report will be derived from the Bslq Station

Note: all parameters in this report will be derived from the Bslq Station

Note: all parameters in this report will be derived from the Bslq Station

Ontario Clean Water Agency  
Biosolids Quality Report - Liquid  
Digester Type: AEROBIC  
**Metals and Criteria**

Facility: SHELBURNE WASTEWATER TREATMENT FACILITY  
Works: 5773  
Period: 01/01/2022 to 12/01/2022

Note: all parameters in this report will be derived from the Bslq Station

Month	Arsenic (mg/L)	Cadmium (mg/L)	Cobalt (mg/L)	Chromium (mg/L)	Copper (mg/L)	Mercury (mg/L)	Molybdenum (mg/L)	Nickel (mg/L)	Lead (mg/L)	Selenium (mg/L)	Zinc (mg/L)
Site	SHELBURNE WASTEWATER TREATMENT FACILITY										
Station	Bslq Station only										
Parameter Short Name	As	Cd	Co	Cr	Cu	Hg	Mo	Ni	Pb	Se	Zn
T/s	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean	Lab Published Month Mean
Jan	0.300	0.014	0.060	0.690	6.700	0.008	0.220	0.380	0.400	0.100	8.000
Feb	0.100	0.005	0.010	0.060	0.200	0.001	0.050	0.050	0.100	0.100	1.000
Mar	0.200	0.008	0.040	0.410	4.700	0.006	0.160	0.230	0.300	0.100	5.000
Apr	0.200	0.005	0.030	0.260	3.300	0.004	0.100	0.160	0.200	0.100	3.000
May	0.300	0.010	0.050	0.550	6.600	0.011	0.210	0.310	0.400	0.100	7.000
Jun	0.200	0.009	0.050	0.550	6.300	0.007	0.190	0.290	0.300	0.100	6.000
Jul	0.200	0.012	0.070	0.810	6.200	0.008	0.230	0.370	0.400	0.100	8.000
Aug	0.200	0.011	0.070	0.820	5.600	0.007	0.110	0.400	0.500	0.100	9.000
Sep	0.300	0.018	0.100	1.200	8.600	0.016	0.290	0.570	0.600	0.100	12.000
Oct	0.300	0.018	0.110	1.200	8.500	0.014	0.280	0.580	0.600	0.100	13.000
Nov	0.300	0.013	0.080	0.920	7.100	0.010	0.230	0.460	0.500	0.100	10.000
Dec	0.400	0.017	0.080	0.860	9.000	0.021	0.330	0.470	0.600	0.100	9.000
Average	0.250	0.012	0.063	0.694	6.067	0.009	0.200	0.356	0.408	0.100	7.583
Max. Permissible Metal Concentrations (mg/kg of	170.000	34.000	340.000	2,800.000	1,700.000	11.000	94.000	420.000	1,100.000	34.000	4,200.000
Metal Concentrations in Sludge (mg/kg)	11.291	0.527	2.823	31.351	273.993	0.425	9.033	16.071	18.442	4.516	342.492



Ontario Clean Water Agency  
Time Series Info Report

Report extracted 03/17/2023 14:24

From: 01/01/2022 to 31/12/2022

Facility Org Number: 5773  
Facility Works Number: 110000659  
Facility Name: SHELBURNE WASTEWATER TREATMENT FACILITY  
Facility Owner: Corporation/Company: The Corporation of the Town of Shelburne  
Facility Classification: Class 3 Wastewater Treatment  
Receiver: Besley Drain to Boyne Creek  
Service Population: 8994.0  
Total Design Capacity: 3420.0 m3/day

	01/2022	02/2022	03/2022	04/2022	05/2022	06/2022	07/2022	08/2022	09/2022	10/2022	11/2022	12/2022	Total	Avg	Max	Min
Septage / Biochemical Oxygen Demand: BOD5 - mg/L																
Count Lab	1	0	2	1	2	0	2	2	0	1	1	2	14			
Max Lab	7000		6610	5470	5890		7620	6200		1760	1660	8200			8200	
Mean Lab	7000		5975	5470	5470		6475	5150		1760	1660	7260		5467.857		
Min Lab	7000		5340	5470	5050		5330	4100		1760	1660	6320				1660
Septage / Carbonaceous Biochemical Oxygen Demand: CBOD5 - mg/L																
Count Lab	1	0	2	1	2	0	2	2	0	1	1	2	14			
Max Lab	5660		5110	5900	4570		7150	6250		1410	1460	6350			7150	
Mean Lab	5660		4835	5900	4515		5910	5485		1410	1460	6115		4867.857		
Min Lab	5660		4560	5900	4460		4670	4720		1410	1460	5880				1410
Septage / Septage Received - m³																
Count IH	1	0	2	1	2	0	2	2	0	1	1	2	14			
Total IH	4.546		9.092	4.546	10.001		10.91	10.91		4.546	13.64	9.092	77.283			
Max IH	4.546		4.546	4.546	5.455		5.455	5.455		4.546	13.64	4.546			13.64	
Mean IH	4.546		4.546	4.546	5.001		5.455	5.455		4.546	13.64	4.546		5.52		
Min IH	4.546		4.546	4.546	4.546		5.455	5.455		4.546	13.64	4.546				4.546
Septage / Total Kjeldahl Nitrogen: TKN - mg/L																
Count Lab	1	0	2	1	2	0	2	2	0	1	1	2	14			
Max Lab	840		821	589	1110		1020	956		788	305	580			1110	
Mean Lab	840		645.5	589	898		1020	955		788	305	537		759.5		
Min Lab	840		470	589	686		1020	954		788	305	494				305
Septage / Total Phosphorus: TP - mg/L																
Count Lab	1	0	2	1	2	0	2	2	0	1	1	2	14			
Max Lab	88.6		139	76.8	188		200	147		140	120	88.6			200	
Mean Lab	88.6		110	76.8	111.85		197.5	143.5		140	120	81.3		122.407		
Min Lab	88.6		81	76.8	35.7		195	140		140	120	74				35.7
Septage / Total Suspended Solids: TSS - mg/L																
Count Lab	1	0	2	1	2	0	2	2	0	1	1	2	14			
Max Lab	8360		15500	10700	23300		28200	19700		17600	12100	26200			28200	
Mean Lab	8360		13250	10700	20400		26500	18700		17600	12100	19800		17575.71		
Min Lab	8360		11000	10700	17500		24800	17700		17600	12100	13400				8360

**2022 Annual Performance Report  
Shelburne Wastewater Treatment Plant  
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix C  
Calibration Reports  
2022



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT PRESSURE MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Magnehelic  
Model: 2000 Series  
Order No: NA  
Serial No: NA  
Tag: NA  
Job Location: To digester  
Asset ID: 0000062546

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-52  
Job No: CO1360-2208

### Details

Unit: psi  
Range: 0-15  
Current Output: NA  
4 mA Set Point: 0  
20 mA Set Point: 15

Inst. Reading	AS FOUND	AS LEFT
Pressure(psi)	8.7	0

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Input (%)	Calculated Pressure (psi)	Calculated Flow(l/sec)	Measure Pressure (psi)	Display flow(l/sec)	Deviation (psi)
0.00	0.00	0.00	0.02	0.00	0.02
100.00	15.00	1,000.00	14.92	1000.00	-0.08

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 2
Device Description:	Digital Pressure Gauge	N/A	N/A
Manufacturer:	Martel Electronics	N/A	N/A
Model No:	BG-PI-PRO-500G	N/A	N/A

Overall Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification. Limited verification

Service Technician : Tushar Patel

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT PRESSURE MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Magnehelic  
Model: 2000 Series  
Order No: NA  
Serial No: NA  
Tag: NA  
Job Location: Aeration flow  
Asset ID: 0000062544

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-53  
Job No: CO1360-2208

### Details

Unit: psi  
Range: 0-15  
Current Output: NA  
4 mA Set Point: 0  
20 mA Set Point: 15

Inst. Reading	AS FOUND	AS LEFT
Pressure(psi)	9.6	9.69

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Input (%)	Calculated Pressure (psi)	Calculated Flow(l/sec)	Measure Pressure (psi)	Display flow(l/sec)	Deviation (psi)
0.00	0.00	0.00	0.10	0.00	0.10
100.00	15.00	1,000.00	14.88	1000.00	-0.12

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 2
Device Description:	Digital Pressure Gauge	N/A	N/A
Manufacturer:	Martel Electronics	N/A	N/A
Model No:	BG-PI-PRO-500G	N/A	N/A

Overall Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks:

Measurement Works within Specification. Limited verification

Service Technician : Tushar Patel

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Khrone  
Model: IFC 010D  
Order Code: NA  
Serial No.: A9915693  
Tag: FIT01  
Job Location: WAS Flow  
Asset ID: 0000062478

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-54  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-27.8  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 27.8

### Sensor Details

Line size: 3"  
GKL: 5.1670  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	606791	606792
FLOW (l/sec)	3.602	3.144

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Set-Point as Per Calibration KIT	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0	0.00	4.00	0.016	4.01	0.02
A	1.98	5.14	1.971	5.13	-0.01
B	3.96	6.28	3.942	6.26	-0.02
C	7.92	8.56	7.935	8.52	0.01
D	19.79	15.39	19.810	15.33	0.02

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Khrone	Fluke	N/A
Model No:	GS8B	179	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks:

Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Khrone  
Model: IFC 010D  
Order Code: NA  
Serial No.: A9915978  
Tag: FIT02  
Job Location: Tank 1 RAS Flow  
Asset ID: 0000062479

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-55  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-66.7  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 66.7

### Sensor Details

Line size: 4"  
GKL: 5.243  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	9537781	9537784
FLOW (l/sec)	15.99	14.43

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Set-Point as Per Calibration KIT	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0	0.00	4.00	0.15	4.00	0.15
A	3.14	4.75	3.17	4.77	0.03
B	6.28	5.51	6.44	5.53	0.16
C	12.55	7.01	12.58	7.03	0.03
D	31.38	11.53	31.40	11.39	0.02
E	62.76	19.05	62.73	19.01	-0.03

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Khrone	Fluke	N/A
Model No:	GS8B	179	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Khrone  
Model: IFC 010D  
Order Code: NA  
Serial No.: A9915977  
Tag: FIT03  
Job Location: Tank 2 RAS Flow  
Asset ID: 0000062480

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-56  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-66.7  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 66.7

### Sensor Details

Line size: 4"  
GKL: 5.318  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	9924547	9924551
FLOW (l/sec)	17.87	16.27

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Set-Point as Per Calibration KIT	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0	0.00	4.00	0.20	4.01	0.20
A	3.18	4.76	3.23	4.80	0.05
B	6.37	5.53	6.41	5.57	0.04
C	12.73	7.05	12.75	7.03	0.02
D	31.83	11.63	31.87	11.65	0.04
E	63.65	19.27	63.73	19.31	0.08

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Khrone	Fluke	N/A
Model No:	GS8B	179	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Khrone  
Model: IFC 010D  
Order Code: NA  
Serial No.: A9915979  
Tag: FIT04  
Job Location: Truck Fill Flow  
Asset ID: NA

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-57  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-75  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 75

### Sensor Details

Line size: 4"  
GKL: 5.045  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	84967	84968
FLOW (l/sec)	0	0

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Set-Point as Per Calibration KIT	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0	0.00	4.00	0.01	4.00	0.01
A	3.02	4.64	3.06	4.68	0.04
B	6.04	5.29	6.09	5.31	0.05
C	12.08	6.58	12.11	6.59	0.03
D	30.19	10.44	30.08	10.36	-0.11
E	60.39	16.88	60.27	16.83	-0.12

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Khrone	Fluke	N/A
Model No:	GS8B	179	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification.

Service Technician : Tushar Patel


Stamp/Signature

Printed Date: August 23, 2022


End of Report

Version: 19-12





VERIFICATION REPORT - **OCM III**  
OPEN CHANNEL FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region		Site/Plant Address: 300 Centennial Rd,				
Plant Name: Shelburne WWTP		Shelburne, ON L0N 1S4				
<b>Device Information</b>		<b>Service Information</b>				
Make: Milltronics	Date: August 23, 2022					
Model: OCM III	Report No: CO1360-2208-58					
Tag: FIT05	Job No: CO1360-2208					
Job Location: Effluent Flow						
Asset ID: 000052506						
		<b>Flow Details</b>				
		Unit: l/sec				
		Flow Range: 0-105				
		Current Output: 4-20 mA				
		4 mA Set Point: 0				
		20 mA Set Point: 105				
<b>Maintenance Checklist</b>		<b>Remarks</b>				
Visual Inspection: <input checked="" type="checkbox"/> OK <input type="checkbox"/> NOT OK						
Electrical Inspection: <input checked="" type="checkbox"/> OK <input type="checkbox"/> NOT OK						
<b>Programming Parameter of Instrument</b>						
Parameter	Discription	Value	Parameter	Discription	Value	
F0	Access Code	2.71828	P7	Height of Max. Head	34.4820	
P1	Dimension Unit (cm)	0	P32	Totalizer Multiplier	6*1000	
P3	Exponential Device	0	P42	Head by OCM III	0	
P4	Cal. Method -Ratiometric	1	P45	Low Flow Cut-off	0	
P5	Flow Unit - l/sec	0	P46	Range at Zero Head	85.66725 cm	
P6	Max Flow rate	105.0009	P47	Blanking Distance	30.48264 cm	
<b>Test Point Report</b>						
Reference Distance (cm)	Measured Distance (cm)	Calculated Flow (l/sec)	UUT Flow Display (l/sec)	Calculated (mA)	Measured (mA)	Devaiiton Full Scale (l/sec)
7.23	7.09	9.62	9.34	5.47	5.42	-0.28
6.58	6.44	8.33	8.06	5.27	5.23	-0.27
<b>Calculations</b>						
<b>Flow Calculations</b>						
$Q = q_{cal} (h/h_{cal})^{Exp}$ Where, $Q$ = Discharge Flow, $q_{cal}$ = max flow, $h$ = head, $h_{cal}$ = max head						
$Exp = 1.53$ , Hence,						
$Q = 105 (7.23/34.48)^{1.53}$						
$Q = 9.62$						
<b>Instrument Test Information and Results</b>						
Input (%)	Calculated Flow(l/sec)	Calculated Input (mA)	Flow on UUT (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)	
0	0.00	4.00	0.20	4.02	0.20	
25	26.25	8.00	26.22	7.98	-0.03	
50	52.50	12.00	52.34	11.94	-0.16	
75	78.75	16.00	78.62	15.96	-0.13	
100	105.00	20.00	104.82	19.98	-0.18	
<b>Information of Tools used for Verification of the Instruments</b>						
Device Description:	Manufacturer		Model			
Electrical Multimeter	Fluke		179			
* Refer Calibration Tools Certificates submittal for more Information						
Verification Test Result:	<input checked="" type="checkbox"/> Passed		<input type="checkbox"/> Fail		<input type="checkbox"/> Not Verified	
Overall Remarks:	Program parameters verified. Single point verification done					
Service Technician :	Sanket Trada		Stamp/Signature			
Printed Date:	August 23, 2022					
End of Report						



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - ROSEMOUNT ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

**Device Information**  
Make: Rosemount  
Model: 8712  
Order Code: NA  
Serial No.: 860188157  
Tag: FIT06  
Job Location: Raw sewage flow  
Asset ID: NA

**Service Information**  
Date: August 23, 2022  
Report No: CO1360-2208-59  
Job No: CO1360-2208

**Sensor Details**  
Line size: 8"  
Flow Cal Tube No.: 1025505911000011  
Mounting: Remote

**Flow Details**  
Unit: l/sec  
Flow Range: 0-150  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 150

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	882766016	882761472
FLOW (L/SEC)	0.0	30.2

Maintenance Checklist			Remarks
Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK	
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK	
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK	
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK	

Instrument Test Information and Results					
Test-Point as Per Calibration KIT	Calculated Flow (FPS)	Calculated O/P (mA)	UUT Display (FPS)	UUT Measured Output (mA)	Deviation (FPS)
0.00	0.00	4.00	0.00	4.00	0.00
3.00	3.00	5.60	3.00	5.60	0.00
10.00	10.00	9.33	9.99	9.34	-0.01
30.00	30.00	20.00	29.99	19.98	-0.01

Information of Tools used for Verification of the Instruments			
Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Rosemount	Fluke	N/A
Model No:	8714D	179	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification.

Service Technician : Tushar Patel  
Printed Date: August 23, 2022

Stamp/Signature

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Khrone  
Model: IFC 100W  
Order Code: NA  
Serial No.: C16501184  
Tag: FIT014(UPPER)  
Job Location: Upper filter  
Asset ID: NA

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-60  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-200  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 200

### Sensor Details

Line size: 10"  
GKL: 8.6872  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	2771955.455	2771960.260
FLOW (l/sec)	0.00	0.00

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Set-Point as Per Calibration KIT	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0	0.00	4.00	0.00	4.00	0.00
A	32.49	6.60	32.57	6.64	0.08
B	64.99	9.20	65.12	9.22	0.13
C	129.98	14.40	130.08	14.42	0.10

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Khrone	Fluke	N/A
Model No:	GS8B	179	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks:

Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - KHRONE ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: Khrone  
Model: IFC 100W  
Order Code: NA  
Serial No.: C16501544  
Tag: FIT014(LOWER)  
Job Location: Lower filter  
Asset ID: NA

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-61  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-200  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 200

### Sensor Details

Line size: 10"  
GKL: 8.2852  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	3287077.102	3287079.287
FLOW (l/sec)	0.00	0.00

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Set-Point as Per Calibration KIT	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0	0.00	4.00	0.00	4.00	0.00
A	30.99	6.48	31.13	6.52	0.14
B	61.98	8.96	62.16	9.01	0.18
C	123.96	13.92	124.16	13.95	0.20

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Calibrator	Electrical Multimeter	N/A
Manufacturer:	Khrone	Fluke	N/A
Model No:	GS8B	179	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - ABB ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: ABB  
Model: MagMaster  
Order Code: NA  
Serial No.: 3K620000015306  
Tag: FIT07  
Job Location: Storm Flow  
Asset ID: NA

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-62  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-200  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 200

### Sensor Details

Line size: 10"  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	818813	818814
FLOW (l/sec)	0.00	0.00

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Flow Input (%)	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0.00	0.00	4.00	0.00	4.00	0.00
25.00	50.00	8.00	49.98	7.98	-0.02
50.00	100.00	12.00	99.99	11.99	-0.01
75.00	150.00	16.00	150.01	16.01	0.01
100.00	200.00	20.00	200.00	20.01	0.00

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Electrical Multimeter	N/A	N/A
Manufacturer:	Fluke	N/A	N/A
Model No:	179	N/A	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - ABB ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: ABB  
Model: MagMaster  
Order Code: NA  
Serial No.: 3K620000015305  
Tag: FIT08  
Job Location: Storm return Flow  
Asset ID: NA

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-63  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-100  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 100

### Sensor Details

Line size: 8"  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	849697	849697
FLOW (l/sec)	1.77	1.39

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Flow Input (%)	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0.00	0.00	0.25	0.02	4.01	0.02
25.00	25.00	24.54	25.00	8.00	0.00
50.00	50.00	49.85	50.01	12.01	0.01
75.00	75.00	74.99	74.98	15.98	-0.02
100.00	100.00	100.00	100.00	20.01	0.00

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Electrical Multimeter	N/A	N/A
Manufacturer:	Fluke	N/A	N/A
Model No:	179	N/A	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks: Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12



Induscontrol Inc  
3170 Ridgeway Drive, Unit #11  
Mississauga, ON L5L 5R4

## VERIFICATION REPORT - ABB ELECTRO-MAGNETIC FLOW MEASUREMENT

Customer Name: OCWA-Georgian Highlands Region  
Plant Name: Shelburne WWTP

Site/Plant Address: 300 Centennial Rd,  
Shelburne, ON L0N 1S4

### Device Information

Make: ABB  
Model: MagMaster  
Order Code: NA  
Serial No.: 3K620000015302  
Tag: FIT09  
Job Location: Sludge transfer Flow  
Asset ID: NA

### Service Information

Date: August 23, 2022  
Report No: CO1360-2208-64  
Job No: CO1360-2208

### Flow Details

Unit: l/sec  
Flow Range: 0-80  
Current Output: 4-20 mA  
4 mA Set Point: 0  
20 mA Set Point: 80

### Sensor Details

Line size: 8"  
Mounting: Remote

Inst. Reading	AS FOUND	AS LEFT
TOTALIZER (m3)	36597	36597
FLOW (l/sec)	0.00	0.00

### Maintenance Checklist

Visual Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Electrical Inspection:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Sensor Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK
Transmitter Installation:	<input checked="" type="checkbox"/> OK	<input type="checkbox"/> NOT OK

### Remarks

### Instrument Test Information and Results

Flow Input (%)	Calculated Flow (l/sec)	Calculated O/P (mA)	UUT Display (l/sec)	UUT Measured Output (mA)	Deviation (l/sec)
0.00	0.00	4.00	0.00	4.00	0.00
25.00	20.00	8.00	19.99	7.99	0.01
50.00	40.00	12.00	40.00	12.00	0.00
75.00	60.00	16.00	60.00	16.00	0.00
100.00	80.00	20.00	80.01	20.01	-0.01

### Information of Tools used for Verification of the Instruments

Details	Tool/Kit 1	Tool/Kit 2	Tool/Kit 3
Device Description:	Electrical Multimeter	N/A	N/A
Manufacturer:	Fluke	N/A	N/A
Model No:	179	N/A	N/A

\* Refer Calibration Tools Certificates submittal for more Information

Verification Test Result: ☒ Passed ☐ Fail ☐ Not Verified

Overall Remarks:

Measurement Works within Specification.

Service Technician : Sanket Trada

Stamp/Signature

Printed Date: August 23, 2022

End of Report

Version: 19-12


**2022 Annual Performance Report  
Shelburne Wastewater Treatment Plant  
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix D

Process Flow Schematic




# Process Diagram



LEGEND

- EXISTING PIPING
- TO INLET WORKS DURING COMMISSIONING
- TEMPORARY BY-PASS
- FLOW DIRECTION
- SLUDGE/BLOWER AIR FLOW DIRECTION
- PROPOSED EQUIPMENT
- STOP GATE (N.C.)
- STOP GATE (N.O.)
- SHEAR GATE (N.C.)
- SHEAR GATE (N.O.)
- GATE VALVE (N.C.)
- GATE VALVE (N.O.)
- PLUG VALVE
- AUTOMATIC VALVE (N.C.)
- AUTOMATIC VALVE (N.O.)
- CHECK VALVE
- FLAPGATE
- BUTTERFLY VALVE
- WEIR
- VENTURI
- FLOW METER
- PUMP
- BLOWER
- SLIDEGATE (N.O.)



- THIS DRAWING IS THE EXCLUSIVE PROPERTY OF S. BURNETT & ASSOCIATES LIMITED AND THE REPRODUCTION OF ANY PART WITHOUT PRIOR WRITTEN CONSENT OF THIS OFFICE IS STRICTLY PROHIBITED.
- THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS, LEVELS, AND DATUMS ON SITE AND REPORT ANY DISCREPANCIES OR OMISSIONS TO THIS OFFICE PRIOR TO CONSTRUCTION.
- THIS DRAWING IS TO BE READ AND UNDERSTOOD IN CONJUNCTION WITH ALL OTHER PLANS AND DOCUMENTS APPLICABLE TO THIS PROJECT.
- DO NOT SCALE THE DRAWINGS.

PROF. STAMP

No.	DATE	ISSUE / REVISION	No.	DATE	ISSUE / REVISION
1.	05/04/2016	33% SUBMISSION	6.	14/06/2016	ISSUED REQUEST FOR PROPOSAL
2.	20/04/2016	66% SUBMISSION	7.	08/08/2016	ISSUED FOR CONSTRUCTION
3.	25/04/2016	ISSUED FOR MOC REVIEW	8.	26/01/2018	AS-BUILT
4.	26/04/2016	ISSUED FOR NVCA REVIEW			
5.	30/05/2016	REVISED AS PER NVCA COMMENTS			

CLIENT	TOWN OF SHELburnE
PROJECT	WATER POLLUTION CONTROL PLANT TERTIARY FILTER REPLACEMENT UPGRADES
TITLE	GENERAL PROCESS FLOW SCHEMATIC TEMPORARY BY-PASS & UPGRADES

DESIGNED BY	D.D.	DRAWN BY	B.U.	VERIFIED BY	S.B.	DRAWING No.	G4
SCALE	NTS	PROJECT No.	M15003				

**2022 Annual Performance Report  
Shelburne Wastewater Treatment Plant  
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix E

Notice of Modification to the Sewage Works

2022



Ontario

Ministry of the  
Environment,  
Conservation and  
Parks

## Notice of Modification to Sewage Works

RETAIN COPY OF COMPLETED FORM AS PART OF THE ECA ON-SITE PRIOR TO THE SCHEDULED IMPLEMENTATION DATE.

### Part 1 – Environmental Compliance Approval (ECA) with Limited Operational Flexibility

(Insert the ECA's owner, number and issuance date and notice number, which should start with "01" and consecutive numbers thereafter)

ECA Number  
6413-ABLQQS

Issuance Date (mm/dd/yy)  
07/19/16

Notice number (if applicable)  
01

ECA Owner  
Town of Shelburne

Municipality  
Town of Shelburne

### Part 2: Description of the modifications as part of the Limited Operational Flexibility

(Attach a detailed description of the sewage works)

AQUABACxt is a highly effective, US EPA-registered biological larvicide. It contains a species of bacteria called bacillus thuringiensis, an approved pesticide for controlling red worms and midge flies in wastewater treatment plants.

On a weekly basis from spring to fall operator will dose the incoming raw sewage and aeration tank to eliminate midge flies at the plant during the summer months.

Description shall include:

1. A detail description of the modifications and/or operations to the sewage works (e.g. sewage work component, location, size, equipment type/model, material, process name, etc.)
2. Confirmation that the anticipated environmental effects are negligible.
3. List of updated versions of, or amendments to, all relevant technical documents that are affected by the modifications as applicable, i.e. submission of documentation is not required, but the listing of updated documents is (design brief, drawings, emergency plan, etc.)

### Part 3 – Declaration by Professional Engineer

I hereby declare that I have verified the scope and technical aspects of this modification and confirm that the design:

1. Has been prepared or reviewed by a Professional Engineer who is licensed to practice in the Province of Ontario;
2. Has been designed in accordance with the Limited Operational Flexibility as described in the ECA;
3. Has been designed consistent with Ministry's Design Guidelines, adhering to engineering standards, industry's best management practices, and demonstrating ongoing compliance with s.53 of the Ontario Water Resources Act; and other appropriate regulations.

I hereby declare that to the best of my knowledge, information and belief the information contained in this form is complete and accurate

Name (Print)

Jose A. Casal, P.Eng. PMP

PEO License Number

100133268

Signature

Digitally signed by Jose Casal  
Date: 2022.03.29 10:46:11 -04'00'

Date (mm/dd/yy)

March 29, 2022

Name of Employer

Ontario Clean Water Agency (OCWA)

### Part 4 – Declaration by Owner

I hereby declare that:

1. I am authorized by the Owner to complete this Declaration;
2. The Owner consents to the modification; and
3. This modifications to the sewage works are proposed in accordance with the Limited Operational Flexibility as described in the ECA.

4. The Owner has fulfilled all applicable requirements of the *Environmental Assessment Act*.

I hereby declare that to the best of my knowledge, information and belief the information contained in this form is complete and accurate

Name of Owner Representative (Print)

Jim Moss

Owner representative's title (Print)

Director, Development and Operations

Owner Representative's Signature

Date (mm/dd/yy)

03/22/2022

# AQUABACxt & BugJuice

Eliminates Red Worms and Midge Flies In Wastewater



## AQUABACxt

AQUABACxt is a highly effective, US EPA-registered biological larvicide. It contains a species of bacteria called *bacillus thuringiensis* (BT), an approved larvicide for controlling red worms and midge flies in wastewater treatment plants.

Red worms find wastewater plants to be a perfect home. They survive by eating your MLSS, then hatch into midge flies, and the cycle repeats. The active ingredient in AQUABACxt kills the red worms and breaks the cycle.

Common symptoms of red worm infestations include: disappearing MLSS (the red worms are eating it), stringy or clumpy return activated sludge, and nuisance flies that attract pests. AQUABACxt is safe to use and will only kill a very narrow set of target species; larvae of the mosquito, midge flies, and black flies. It will not cause effluent toxicity issues.



## BugJuice

BugJuice degrades the cocoons red worms build around themselves, exposing more red worms to the AQUABACxt treatment. You can often find these cocoons on the walls of clarifier rings, or the sides of basins. This technique increases the effectiveness of AQUABACxt dramatically.

We recommend using BugJuice for the first 20 to 40 days of any treatment. After the initial treatment, an annual or biannual 20 day treatment is helpful for restoring the benefits.



## Figure 1:

Isolated midge fly and an isolated red worm



Red Worm



Midge Fly



P.O. Box 8682  
Madison, WI  
53708-8682

P: 888.757.9577  
F: 866.636.1864

info@teamaquafix.com  
www.teamaquafix.com



# Dose Rates

## AQUABACxt & BugJuice



### AQUABACxt: Wastewater Plant Dosing

Flow Rate Gallons per day	Super Dose Twice per week for 1-2 weeks	Initial Dose Twice per week for 2 weeks	Maintenance Dose Once per week
10,000 GPD	0.5 pt or 8 oz	4 oz	2 oz
50,000 GPD	1 qt or 2 pt	1 pt	8 oz
100,000 GPD	0.5 gal	1 qt	1 pt
200,000 GPD	1 gal	2 qt	2 pt
300,000 GPD	1.5 gal	3 qt	3 pt
400,000 GPD	2 gal	4 qt	4 pt
500,000 GPD	2.5 gal	5 qt	5 pt
600,000 GPD	3 gal	6 qt	6 pt
700,000 GPD	3.5 gal	7 qt	7 pt
800,000 GPD	4 gal	8 qt	8 pt
900,000 GPD	4.5 gal	9 qt	9 pt
1,000,000 GPD	5 gal	10 qt	10 pt

### AQUABACxt: Wastewater Lagoon Dosing

Lagoon Size	Initial Dose Once per week for 4 weeks	Maintenance Dose Once per week
1 Acres	2.5 gal	1 gal
4 Acres	10 gal	4 gal
8 Acres	20 gal	8 gal

### BugJuice Dose Rate

Flow Rate Gallons per day	Dose: Add Daily at the head of treatment plant
100,000 GPD	1 pt
200,000 GPD	2 pt
300,000 GPD	3 pt
400,000 GPD	4 pt
500,000 GPD	5 pt
600,000 GPD	6 pt
700,000 GPD	7 pt
800,000 GPD	8 pt
900,000 GPD	9 pt
1,000,000 GPD	10 pt

### AQUABACxt:

- Add directly to areas with red worms, often secondary clarifiers and tertiary processes
- Can be metered instead of weekly slug dose, if desired
- Continue to use throughout your climate's active midge fly season

### BugJuice:

- Add daily at headworks of plant
- Use for at least the first 20-40 days of any AQUABACxt treatment

### Available Sizes:

- 5 gal case
- 135 gal pallet
- 250 gal tote (AQUABACxt)
- 275 gal tote (BugJuice)

**From:** [Weber, Martha \(MECP\)](#)  
**To:** [Melissa Cortes](#)  
**Cc:** [Don Irvine](#); [Monika Kowalska](#); [Jenna Porter](#)  
**Subject:** RE: Shelburne WWTP - Midge Fly Control  
**Date:** March-21-22 7:57:13 AM

---

**CAUTION:** This email originated from outside of the organization. Do not click links or open attachments unless you recognize the sender and know the content is safe.

Good morning Melissa,

I double-checked with Approvals, and they agree this item would fall within the LOF provisions as proposed.

Thanks for reaching out!

**Martha Weber**

Water Inspector/Provincial Officer  
Ministry of the Environment, Conservation and Parks  
Guelph District Office  
Cell (519) 830-5977

**NOTE:** This message is confidential and may be privileged and exempt from disclosure under applicable law. If you are not the intended recipient or an agent of that individual or organization, any use, copying, or distribution of this message by you is strictly prohibited. If you received this communication in error, please contact me by return e-mail and delete this message.

- We want to hear from you. How was my service? You can provide feedback at 1-888-745-8888 or [ontario.ca/inspectionfeedback](https://ontario.ca/inspectionfeedback)
- Nous attendons vos commentaires. Qu'avez-vous pensé de mon service? Vous pouvez nous faire part de vos commentaires au 1-888-745-8888 ou à [ontario.ca/retroactioninspection](https://ontario.ca/retroactioninspection)

---

**From:** Melissa Cortes <MCortes@ocwa.com>  
**Sent:** Wednesday, March 16, 2022 12:01 PM  
**To:** Weber, Martha (MECP) <Martha.Weber@ontario.ca>  
**Cc:** Donald Irvine <dirvine@ocwa.com>; Monika Kowalska <MKowalska@ocwa.com>; Jenna Porter <JPorter2@ocwa.com>  
**Subject:** Shelburne WWTP - Midge Fly Control

**CAUTION -- EXTERNAL E-MAIL - Do not click links or open attachments unless you recognize the sender.**

Hi Martha,

I wanted to reach out to you to start a discussion on the use of a products called AQUABACxt and Bug Juice at the Shelburne WWTP to control midge flies. Our operator reached out and provided documentation/research on this product and how effective it is in controlling midge flies and wanted to try it at the Shelburne WWTP. Attached is some information on the product as well as dosing calculations that our operator has completed with a schedule of dosing.

If you could provide your feedback and directions we can take to start using these products I would greatly appreciate it. I believe it would fall under LOF and a notice of modification form will be

completed before using this product.

Thanks Melissa

*Melissa Cortes*

Process & Compliance Technician  
Highlands Hub, Georgian Highlands Region  
300 Centennial Road  
Shelburne ON, L9V 2Z4  
519-938-6909



---

**From:** Monika Kowalska <[MKowalska@ocwa.com](mailto:MKowalska@ocwa.com)>  
**Sent:** March-11-22 9:48 AM  
**To:** Don Irvine <[DIrvine@ocwa.com](mailto:DIrvine@ocwa.com)>  
**Cc:** Jose Casal <[JCasal@ocwa.com](mailto:JCasal@ocwa.com)>; Jenna Porter <[JPorter2@ocwa.com](mailto:JPorter2@ocwa.com)>; Melissa Cortes <[MCortes@ocwa.com](mailto:MCortes@ocwa.com)>  
**Subject:** RE: Shelburne WWTP

Hi

I initially found out about this product through the email correspondence attached by Don. Another OCWA facility used this product last year and had great success.

Looking at the website, <https://teamaquafix.com/products/midge-flies/aquabac-xt-midge-flies/>  
It is a product specifically designed for use at WWTP to eliminate red worms which develop into midge flies. These flies in turn attract spiders into the plant.

"It contains a species of bacteria called ***bacillus thuringiensis***, an approved larvicide for controlling red worms and midge flies in wastewater treatment plants and waterways. Highly effective against red worms but safe for fish, birds, mammals, and other lifeforms. AQUABACxt is safe to use and will only kill a very narrow set of target species; larvae of the mosquito, midge flies, and black flies. It will not cause effluent toxicity issues."

I am also a member of a wastewater operator group, and within this group, there have been many post about how other operators around the world manage the flies at their facilities, and the operators that have used this product highly recommend it.

Only other way to reduce/eliminate these flies at the source is through chlorination (which can negatively impact the microorganisms in the RAS). All other methods (bug zappers, etc,) are only treating the symptoms and are not effective.



Attached is the product sheet which can be found on the AQUAFIX website, and states the recommended doses.

Attached is the calculations I performed to determine how much product is required this year based off of the plant's flow per day.

There are 2 products that will be used.

Bug Juice draws out the red worms that are hiding in rags/grit and degrades their protective cocoons. The AQUABACxt is fed upon by these red worms which kills them, thereby eliminating the midge flies.

Bug Juice also carries the added benefit of improving digester settling and denser sludge (similar to XLR8 product used at the plant a couple of years ago). <https://teamaquafix.com/products/aerobic-digester-sludge-storage-tank/bug-juice-sludge-reduction/>

Attached is the SDS for both Bug Juice and AQUABACxt.

Attached is email correspondence with Landon from AQUAFIX, with some answers to questions I had earlier this year.

Let me know if there's any other info required.

Thanks,

**Monika Kowalska, C.Tech.**

*Water & Wastewater Operator | Ontario Clean Water Agency  
Highlands Hub | Georgian Highlands Region  
300 Centennial Rd, Shelburne, Ontario L9V 2Z4  
Cell 519-940-6057 | [mkowalska@ocwa.com](mailto:mkowalska@ocwa.com)*



**2022 Annual Performance Report  
Shelburne Wastewater Treatment Plant  
Amended Environmental Compliance Approval No. 6413-ABLQQS**

Appendix F

ECA Limit Exceedance Email/Written Notifications

2022

## Melissa Cortes

---

**From:** Melissa Cortes  
**Sent:** June-17-22 3:51 PM  
**To:** martha.weber@ontario.ca  
**Cc:** Stephen Burnett - S. Burnett & Associates Limited  
(stephen.burnett@sbaengineering.com); jmoss@shelburne.ca; Don Irvine; Camille Leung; Mike Mortimer; Monika Kowalska; Jenna Porter  
**Subject:** Shelburne Wastewater Treatment Plant (WWTP) ECA Compliance Limit Exceedance (CBOD5) - May 2022

Hello Martha,

This is a notification that the Shelburne Wastewater Treatment Plant (WWTP) has met all but one of its ECA compliance limits (**CBOD5**) for the month of **May 2022**.

**Facility:** Shelburne WWTP  
**ECA #** 6413-ABLQQS  
**ECA Issued:** July 19, 2016

### May 2022

Shelburne WWTP			3 <sup>rd</sup>	10 <sup>th</sup>	17 <sup>th</sup>	24 <sup>th</sup>	31 <sup>st</sup>	MONTHLY AVERAGE	Reportable
PARAMETER	LIMIT	OBJECTIVE							
CBOD5	5.0mg/L	4.0mg/L	4	13	4	2	4	5.40	Monthly

### Results Summary

- **CBOD<sub>5</sub>** – the monthly average concentration of 5.40 mg/L was above the ECA Compliance Limit.

### Reporting Actions

Verbally notified Martha Weber, Provincial Office/Water Inspector with the MECP Guelph District Office of the exceedance on Friday June 17<sup>th</sup>, 2022 via phone call, left voicemail with details.

### Process Observations

- North Clarifier out of service since April 28 while repairs were being scheduled and plant may have taken a shock load of BOD from possible industrial section of town (North Clarifier returned to service June 6)
- Sludge blanket in South Clarifier was higher due to the extra loading with the North Clarifier being out of service

### Corrective Actions taken

- Operator adjusted raw sewage and RAS flows daily until blanket in South Clarifier returned to normal operating levels

If there are any questions or comments concerning this matter, please let us know.

Thank you,

*Melissa Cortes*

Process & Compliance Technician  
Highlands Hub, Georgian Highlands Region  
300 Centennial Road  
Shelburne ON, L9V 2Z4  
519-938-6909



## Melissa Cortes

**From:** Melissa Cortes  
**Sent:** January-13-23 12:43 PM  
**To:** martha.weber@ontario.ca  
**Cc:** Stephen Burnett - S. Burnett & Associates Limited (stephen.burnett@sbaengineering.com); jmoss@shelburne.ca; Don Irvine; Camille Leung; Caralynn McRae; Monika Kowalska; Suhail Auzam  
**Subject:** Shelburne Wastewater Treatment Plant (WWTP) ECA Compliance Limit Exceedance Total Suspended Solids - December 2022

Hello Martha,

This is a notification that the Shelburne Wastewater Treatment Plant (WWTP) has met all but one of its ECA compliance limits (**Total Suspended Solids**) for the month of **December 2022**.

**Facility:** Shelburne WWTP

**ECA #** 6413-ABLQQS

**ECA Issued:** July 19, 2016

### December 2022

Shelburne WWTP			6 <sup>th</sup>	13 <sup>th</sup>	20 <sup>th</sup>	28 <sup>th</sup>		MONTHLY AVERAGE	Reportable
PARAMETER	LIMIT	OBJECTIVE							
TSS	5.0mg/L	4.0mg/L	2	7	5	8		5.50	Monthly

### Results Summary

- **TSS (Total Suspended Solids)** – the monthly average concentration of **5.50** mg/L was above the ECA Compliance Limit.

### Reporting Actions

Verbally notified Martha Weber, Provincial Office/Water Inspector with the MECP Guelph District Office of the exceedance on Friday January 13, 2023 at 12:39 via phone call, left voicemail with exceedance information.

### Process Observations

13<sup>th</sup> - Possible high concentration of solids entering plant after hours

28<sup>th</sup> - Operations observed on December 20<sup>th</sup>, 2022 incoming raw sewage was black (unsure of source), H2S gas in headworks was high.

- December 21<sup>st</sup>, 2022 final effluent was cloudy and ammonia was high (0.94 mg/L).
- December 23<sup>rd</sup>, 2022 grit vortex was clogged and needed to be unclogged.
- December 23<sup>rd</sup>-24<sup>th</sup>, 2022 power failure due to snow storm.
- December 24<sup>th</sup>, 2022 aeration blower 1 failure due to snow storm, filters were clogged.
- December 25<sup>th</sup>-28<sup>th</sup> wasting didn't occur due to return activated sludge pump 2 failure and pump 3 out of service
- December 26<sup>th</sup>, 2022 return activated sludge pump 2 failure due to electrical cable issue

### Corrective Actions taken

13<sup>th</sup> - Cleaned UV channel, auto-sampler suction/discharge lines, increased aeration blower and return activated sludge into aeration

28<sup>th</sup> - December 21<sup>st</sup>, 2022 increased aeration blower 1, decreased raw sewage into plant, increased return activated sludge into aeration.

- December 23<sup>rd</sup>, 2022 unclogged grit vortex
- December 24<sup>th</sup>, 2022 changed filters on aeration blower 1
- December 26<sup>th</sup>, 2022 return activated sludge pump 2 running, electrical issue temporarily solved
- December 30<sup>th</sup>, 2022 return activated sludge pump 3 back in service, wasting issue resolved

If there are any questions or comments concerning this matter, please let us know.

Thank you,

*Melissa Cortes*

Process & Compliance Technician  
Highlands Hub, Georgian Highlands Region  
300 Centennial Road  
Shelburne ON, L9V 2Z4  
519-938-6909

