

# **REQUEST FOR QUOTATION 02-2023**

## **Chain Link Fence at Hyland Park – Addendum #1**

Issued: April 17, 2023

Deadline for Submissions: May 08, 2023



### **The Corporation of the Town of Shelburne**

203 Main Street East | Shelburne, ON L9V3K7

Phone: 519-925-2600 | Fax: 519-925-6134 | Email: [treasurer@shelburne.ca](mailto:treasurer@shelburne.ca)



## SCHEDULE B: PRICING FOR INSTALLATION OF GALVINZED CHAIN LINK FENCE AT HYLAND PARK

DESCRIPTION	ESTIMATED QUANTITY	UNIT	UNIT PRICE	AMOUNT
Chain link fence		Linear Ft.		
3 1/2" diameter post		Per Unit		
2 3/8" diameter post		Per Unit		
1 11/16" diameter top rail and middle brace rail		Linear Ft.		
Other:				
Working Days:			Subtotal:	
			HST (13%)	
			Total:	

Signature of Authorized Person: \_\_\_\_\_

Print Name: \_\_\_\_\_

Title: \_\_\_\_\_

Signature of Witness: \_\_\_\_\_

Please note: Person signing must be authorized to conduct business on behalf of the company represented and to bind the company/individual to statements on this RFQ/Contract. Failure to sign submission will result in a rejection of the proposal.



## QUESTIONS RECEIVED

**Q1.** Confirm thickness for posts and rail. OPSD / OPSS is schedule 40.

**A:** Please see the specifications on within the RFP for thickness of posts and rails

**Q2.** Is there tree clearing or any grubbing along fence lines or this work by others?

**A:** There would be a little bit of clearing a site visit may help with this.

**Q3.** Are bidders to submit through the Merx platform or to email bids to the Treasurer?

**A:** It can be submitted through either one platform both are acceptable.

**Q4.** Is the town able to adjust the bid form to one line item RE: Supply & install 1.5m high chain link as per specifications = 220 LM.

**A:** Prefer to leave it how it is formatted for pricing.

**Q5.** Will the town provide layout?

**A:** Please see page 8 on the RFQ for a general layout.

<https://www.shelburne.ca/en/town-hall/resources/Documents/RFP/2023/RFQ-02-2023---Chain-Link-Fence-at-Hyland-Park.pdf>

**Q6.** The specifications are calling for a middle fence brace with 1-11/16" diameter. Is this a brace at the corners and ends only or is it a middle rail that is to be completely around the entire fence line?

**A:** It would be at the corners and ends only.

**Q7.** What gauge is the bottom wire? We typically use a 6 gauge galvanized bottom wire for commercial fencing. Is this what we should price?

**A:** 6 gauge is appropriate for the bottom wire.



**Q8.** There is no specification for the tie wires. We typically use a hard aluminum tie for commercial fencing. Is this what we should price?

**A:** Please price hard aluminum tie wires for this project.

**Q9.** The specifications call for 12" and 10" footings, does that mean these posts are to be sunk in 12" and 10" sonotubes respectively?

**A:** Yes.

**Q10.** If so, are we to dome the top of the concrete sonotube footings for proper drainage?

**A:** Yes or put the footings just below grade and add soil.

**Q11.** Secondly, since the chain link is to be grey galvanized, not vinyl coated in any way?

**A:** Galvanized is the option no vinyl coating.

**Q12.** Lastly, could you provide some clarification by what is meant by offsetting the entrance to dirt bikes and such?

**A:** To prevent dirt bikes and four wheelers going through the park.