

REQUEST FOR PROPOSAL 02-2026

Replacement of AAON MAU Unit

Addendum #1

Questions and Answers: February 09, 2026

Deadline for Submissions: February 13, 2026



The Corporation of the Town of Shelburne

203 Main Street East | Shelburne, ON L9V 3K7

Phone: 519-925-2600 | Fax: 519-925-6134

Email: treasurer@shelburne.ca

QUESTION PERIOD

Questions relating to this tender were accepted by email only until 4:30pm on February 06, 2026. Responses and clarifications requests have been provided in writing below.

QUESTIONS RECEIVED

Q1: Can you please provide a contact for the base building automation?

A1: Peter @ Concept Controls - peter@constantcontrols.ca.

Q2: Can the unit replacement be completed during regular business hours (including hoisting and rigging)?

A2: Work can be completed during regular business hours.

Q3: Required power source for new unit(s) available? (Does new spec'd equipment translate to existing?) if not, is there a specified panel with available room to power new unit(s)?

A3: Yes new specs translate to existing.

Q4: Who is responsible for control wiring and terminations?

A4: Successful Proponent.

Q5: "Pitch pockets" available for reuse?

A5: Yes.