

Town of Shelburne RFP 01-2024

Walter's Creek Park – Landscape Works

Addendum #1 - Questions and Answers

Issued: February 20, 2024

Deadline for Submissions: February 23, 2024



The Corporation of the Town of Shelburne

203 Main Street East | Shelburne, ON L9V3K7

Phone: 519 925-2600 | Fax: 519 925-6134 | Email: treasurer@shelburne.ca



QUESTIONS RECEIVED

Q1: Who covers the costs of the testing for of materials, compaction, strengths etc.?

A1: Awarded bidder/proponent are responsible for costs of all tests.

Q2: Size of footings for swing set and qty of footings 4?

A2: Diameter of footing is 1.5ft with a depth of minimum 4ft and 4 footings required.

Q3: Who is installing the swing set?

A3: Awarded bidder/proponent is responsible for installing the swing set. Town is responsible for third party inspection of the swing set.

Q4: Soil removal and disposal?

A4: Soil can be moved to the Town's transfer yard for disposal located at 601 Victoria Street.